



"SHOP DRAWING"

GENERAL NOTES	DATE	REVISIONS	REQUIRED APPROVALS	IMMUCELL CORPORATION (2014 FREEZER ADDITION) 56 EVERGREEN DRIVE, PORTLAND, ME. 04105	FIRE SPRINKLER PLANS & DETAILS
SPRINKLER SYSTEM INSTALLATION TO COMPLY WITH NFPA PAMPHLET #13 (2007 EDITION). NEW BRANCH LINE PIPING (1 1/2" TO BE BLACK SCHEDULE 40 WITH THREADED ENDS & THREADED DUCTILE IRON FITTINGS. NEW BRANCH LINE PIPING (1 1/2" & 1 1/4") TO BE BLACK SCHEDULE 10 WITH GROOVED ENDS AND WELDED OUTLETS JOINED BY MECHANICAL COUPLINGS. NEW MAIN PIPING (2" & UP) TO BE BLACK SCHEDULE 10 WITH GROOVED ENDS & WELDED OUTLETS JOINED BY MECHANICAL COUP. OWNER TO PROVIDE SUFFICIENT HEAT THROUGHOUT BUILDING TO PREVENT FREEZING OF WATER FILLED SPRINKLER PIPING AND EQUIPMENT. (MIN. 40° F), EXCEPT FOR COLOSTRUM FREEZER.			OWNER / ARCHITECT STATE FIRE MARSHAL PORTLAND FIRE DEPARTMENT DRAWN BY T. PRAY NICET LEVEL III CERT.# 100854 CHECKED BY WAF NICET LEVEL III CERT.# 095574 CONTRACTOR LICENSE # 101 CONTRACTOR RMS # 368	CONTRACT WITH: OWNER EASTERN FIRE PROTECTION AUBURN/LEWISTON INDUSTRIAL AIRPARK, AUBURN, MAINE 04210	DWG. NO. 1 OF 1 JOB NUMBER AU-5216-14 SCALE AS NOTED DATE 11/12/14