

# Record of Completion

Presented To

Immucell

For

Immucell- Industrial Way

175 Industrial Way

Portland ME

USA

This site has been inspected and tested in compliance with applicable standards.

Completed

Wednesday, April 29, 2020

Test Session: 04/29/20

ACCEPTED BY

Immucell  
56 Evergreen Drive  
Portland ME  
USA

TESTED BY

Anthony Morris  
Norris Inc  
2257 Broadway  
South Portland ME 4106  
USA

Norris Inc

 **Norris Inc.**

Advancing security, life safety and communications.

# Inspection Location and Organizations

## Building Information

PROPERTY	Immucell- Industrial Way	CONTACT
ADDRESS	175 Industrial Way	PHONE
CITY/STATE/ZIP	Portland, ME	MOBILE
COUNTRY	USA	EMAIL

## Installer Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

## Service Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com

## Testing Company Information

NAME	Norris Inc
ADDRESS	2257 Broadway South Portland ME 4106
PHONE	(207) 883-3473
EMAIL	NICentralOperations@norrisinc.com
CONTRACT DATE	

## Description of Service

This is an existing system.  
Permit #  
NFPA72 Edition:  
Number of devices participating in Alarm Verification: 0

## Initiating Device Summary

EQUIPMENT TYPE	TOTAL
Water-Based Fire Protection Systems	1
Initiating Device	23
Emergency Control Equipment	5
Alarm Notification Appliance	24
Combination System	3
Fire Control Panel	2

## Notification Device Summary

EQUIPMENT TYPE	TOTAL
Water-Based Fire Protection Systems	1
Initiating Device	23
Emergency Control Equipment	5
Alarm Notification Appliance	24
Combination System	3
Fire Control Panel	2

Norris Inc

## Device Summary

EQUIPMENT TYPE	TOTAL
Water-Based Fire Protection Systems	1
Initiating Device	23
Emergency Control Equipment	5
Alarm Notification Appliance	24
Combination System	3
Fire Control Panel	2

## System Control Functions

Function	Count
Fan Control	5
Smoke Damper	0
HVAC Shutdown	0
Elevator Recall	0
Elevator Power Shutdown	0
Elevator Short Trip	0
Door Holder Release	0
Shutter Release	0
Door Unlock	0
Other	0

# Certification Information

## Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, April 29, 2020


INSTALLED BY

4/29/2020

BH Milliken

Installer

TESTED BY



4/29/2020

Anthony Morris

Technician

ACCEPTED BY

4/29/2020

Building Representative

ACCEPTED BY


4/29/2020

AHJ

# Testing Details

## Fire Control Panel

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Panel		Main Entry Vestibule	Manual	4/29/2020 3:03 PM
	Comment:	PFD Sticker 20-0154		
				
Fire Panel Batteries		FACP Batteries	Manual	4/29/2020 3:03 PM
	Comment:	New		

## Initiating Device

Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - General	D01	Main Entry Vestibule	Manual	4/29/2020 3:01 PM
Manual Pull Station	M01	Main Entry Vestibule 001	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D02	Hall 09 OS Rm 006	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D03	Break Room 012	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D04	Fire Sprinkler/Elec Rm 014	Manual	4/29/2020 3:01 PM
Mechanical, Electrosonic, or Pressure Waterflow Device	M04	Sprinkler Main Flow Rm 014	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D05	Clean Corridor 018 OS Rm 013	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D06	Clean Corridor 018 OS Rm 016	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D07	Clean Corridor 018 OS Rm 020	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D08	Clean Corridor 018 OS Vestibule 019	Manual	4/29/2020 3:01 PM
Manual Pull Station	M07	Rear Vestibule 019	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D09	Transition Corridor #2 OS Rm 021	Manual	4/29/2020 3:01 PM
Smoke Detector - General	D10	Transition Corridor #2 OS Rm 025	Manual	4/29/2020 3:01 PM
Manual Pull Station	M08	Warehouse Back Door	Manual	4/29/2020 3:01 PM
Manual Pull Station	M09	Warehouse Side Door	Manual	4/29/2020 3:01 PM
Smoke Detector - Duct	D12	Equipment Mezzanine AHU-2	Manual	4/29/2020 3:02 PM
Smoke Detector - Duct	D13	Equipment Mezzanine AHU-4	Manual	4/29/2020 3:02 PM
Smoke Detector - Duct	D14	Equipment Mezzanine AHU-5	Manual	4/29/2020 3:02 PM
Smoke Detector - Duct	D15	Equipment Mezzanine AHU-6	Manual	4/29/2020 3:02 PM

Norris Inc

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector - Duct	D16	Gowning Room 011 RTU-1	Manual	4/29/2020 3:02 PM
Smoke Detector - General	D17	Office Corridor OS Rm 08	Manual	4/29/2020 3:02 PM
Smoke Detector - General	D18	Clean Corridor OS Room 017	Manual	4/29/2020 3:02 PM
Smoke Detector - General	D19	Transition Corridor OS Room 023	Manual	4/29/2020 3:02 PM

## Alarm Notification Appliance

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Test Switch	D16	Gowning Room 011 RTU-1	Manual	4/29/2020 3:02 PM
Audible And Visible	NAC 3	Warehouse 025	Manual	4/29/2020 3:18 PM
Audible And Visible	NAC 3	Warehouse 025	Manual	4/29/2020 3:18 PM
Audible And Visible	NAC 3	Equipment Mezz 040 EOLR	Manual	4/29/2020 3:18 PM
Audible And Visible	NAC 2	Clean Corridor OS Rm 017	Manual	4/29/2020 3:18 PM
Audible And Visible	NAC 2	Clean Corridor OS Vestibule 019	Manual	4/29/2020 3:18 PM
Audible And Visible	NAC 2	Transition Corridor OS Rm 023	Manual	4/29/2020 3:18 PM
Audible And Visible	NAC 2	Transition Corridor OS Rm 025 EOLR	Manual	4/29/2020 3:18 PM
Visible	NAC 2	Powder Fill Rm 016	Manual	4/29/2020 3:19 PM
Visible	NAC 2	Die Cutting Rm 017	Manual	4/29/2020 3:19 PM
Visible	NAC 2	Powder Assembly Rm 021	Manual	4/29/2020 3:19 PM
Visible	NAC 2	Water Tank Room 002	Manual	4/29/2020 3:19 PM
Visible	NAC 2	Gel Assembly 023	Manual	4/29/2020 3:19 PM
Audible And Visible	NAC 1	Lobby 002	Manual	4/29/2020 3:19 PM
Visible	NAC 1	Conference Room 006	Manual	4/29/2020 3:19 PM
Visible	NAC 1	Break Room 012	Manual	4/29/2020 3:19 PM
Visible	NAC 1	Sub Divide Power Blend Rm 015	Manual	4/29/2020 3:19 PM
Visible	NAC 1	Gowning Room 011	Manual	4/29/2020 3:19 PM
Audible And Visible	NAC 1	Transition Corridor 1 OS Rm 013	Manual	4/29/2020 3:19 PM
Visible	NAC 1	Dishwasher Room 014	Manual	4/29/2020 3:19 PM
Audible And Visible	NAC 1	Gel Formulation and Fill Rm 020	Manual	4/29/2020 3:19 PM
Audible And Visible	NAC 1	Clean Corridor OS RM 015 EOLR	Manual	4/29/2020 3:19 PM
Visible		Lobby Men's Room	Manual	4/29/2020 3:20 PM
Visible		Lobby Women's Room	Manual	4/29/2020 3:20 PM

## Combination System

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
CO Detector	M02	Hall 09 OS Room 006	Manual	4/29/2020 3:01 PM
CO Detector	M10	Equipment Mezzanine	Manual	4/29/2020 3:02 PM
CO Detector	M02	Hall 09 OS Room 006	Manual	4/29/2020 3:02 PM

## Emergency Control Equipment

### Passed

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fan Control	M11	Equipment Mezzanine AHU-2	Manual	4/29/2020 3:02 PM
Fan Control	M12	Equipment Mezzanine AHU-4	Manual	4/29/2020 3:02 PM
Fan Control	M13	Equipment Mezzanine AHU-5	Manual	4/29/2020 3:02 PM
Fan Control	M14	Equipment Mezzanine AHU-6	Manual	4/29/2020 3:02 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fan Control	M15	Gowning Room 011 RTU-1	Manual	4/29/2020 3:02 PM

## Device/Equipment Details

### Fire Control Panel

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Fire Alarm Panel					
	Main Entry Vestibule	Firewarden NFW 100X			4/29/2020
Fire Panel Batteries					
	FACP Batteries	Sigmas Tek	12V-12AH		4/29/2020

### Initiating Device

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Manual Pull Station					
M08	Warehouse Back Door	Notifer	NOT-BG12LX		4/29/2020
M01	Main Entry Vestibule 001	Notifer	NOT-BG12LX		4/29/2020
M09	Warehouse Side Door	Notifer	NOT-BG12LX		4/29/2020
M07	Rear Vestibule 019	Notifer	NOT-BG12LX		4/29/2020
Mechanical, Electrosonic, or Pressure Waterflow Device					
M04	Sprinkler Main Flow Rm 014				4/29/2020
Smoke Detector - Duct					
D15	Equipment Mezzanine AHU-6	System Sensor	DNR		4/29/2020
D13	Equipment Mezzanine AHU-4	System Sensor	DNR		4/29/2020
D14	Equipment Mezzanine AHU-5	System Sensor	DNR		4/29/2020
D16	Gowning Room 011 RTU-1	System Sensor	DNR		4/29/2020
D12	Equipment Mezzanine AHU-2	System Sensor	DNR		4/29/2020
Smoke Detector - General					
D07	Clean Corridor 018 OS Rm 020	Notifer	NP200		4/29/2020
D03	Break Room 012	Notifer	NP200		4/29/2020
D09	Transition Corridor #2 OS Rm 021	Notifer	NP200		4/29/2020
D01	Main Entry Vestibule	Notifer	NP200		4/29/2020
D02	Hall 09 OS Rm 006	Notifer	NP200		4/29/2020
D08	Clean Corridor 018 OS Vestibule 019	Notifer	NP200		4/29/2020
D10	Transition Corridor #2 OS Rm 025	Notifer	NP200		4/29/2020
D17	Office Corridor OS Rm 08	Notifer	NP200		4/29/2020
D05	Clean Corridor 018 OS Rm 013	Notifer	NP200		4/29/2020
D06	Clean Corridor 018 OS Rm 016	Notifer	NP200		4/29/2020
D19	Transition Corridor OS Room 023	Notifer	NP200		4/29/2020
D18	Clean Corridor OS Room 017	Notifer	NP200		4/29/2020
D04	Fire Sprinkler/Elec Rm 014	Notifer	NP200		4/29/2020

### Alarm Notification Appliance

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Audible And Visible					
NAC 2	Transition Corridor OS Rm 023				4/29/2020
NAC 3	Warehouse 025				4/29/2020
NAC 2	Clean Corridor OS Rm 017				4/29/2020
NAC 1	Lobby 002				4/29/2020
NAC 1	Clean Corridor OS RM 015 EOLR				4/29/2020
NAC 3	Warehouse 025				4/29/2020
NAC 3	Equipment Mezz 040 EOLR				4/29/2020



ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
NAC 1	Gel Formulation and Fill Rm 020				4/29/2020
NAC 2	Transition Corridor OS Rm 025 EOLR				4/29/2020
NAC 1	Transition Corridor 1 OS Rm 013				4/29/2020
NAC 2	Clean Corridor OS Vestibule 019				4/29/2020

#### Remote Test Switch

D16	Gowning Room 011 RTU-1	System Sensor	DNR		4/29/2020
-----	------------------------	---------------	-----	--	-----------

#### Visible

	Lobby Women's Room				4/29/2020
NAC 1	Gowning Room 011				4/29/2020
NAC 1	Break Room 012				4/29/2020
NAC 2	Powder Assembly Rm 021				4/29/2020
NAC 2	Water Tank Room 002				4/29/2020
NAC 1	Dishwasher Room 014				4/29/2020
NAC 1	Sub Divide Power Blend Rm 015				4/29/2020
NAC 1	Conference Room 006				4/29/2020
	Lobby Men's Room				4/29/2020
NAC 2	Powder Fill Rm 016				4/29/2020
NAC 2	Die Cutting Rm 017				4/29/2020
NAC 2	Gel Assembly 023				4/29/2020

#### Combination System

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
CO Detector					
M10	Equipment Mezzanine	System Sensor	C01224 Round		4/29/2020
M02	Hall 09 OS Room 006	System Sensor	C01224 Round		4/29/2020
M02	Hall 09 OS Room 006				4/29/2020

#### Emergency Control Equipment

ADDRESS	DESCRIPTION	Manufacturer	Model	SERIAL	INSTALL DATE
Fan Control					
M13	Equipment Mezzanine AHU-5	System Sensor	DNR		4/29/2020
M15	Gowning Room 011 RTU-1	System Sensor	DNR		4/29/2020
M12	Equipment Mezzanine AHU-4	System Sensor	DNR		4/29/2020
M11	Equipment Mezzanine AHU-2	System Sensor	DNR		4/29/2020
M14	Equipment Mezzanine AHU-6	System Sensor	DNR		4/29/2020

# Supplementary Information