

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

YOUNG MARY E ETALS TRUSTEES /Indian Falls
Construction

Located at

987 RIVERSIDE ST (Unit # 979)

PERMIT ID: 2014-00876

ISSUE DATE: 06/09/2014

CBL: 329 B011001

has permission to **Replace 10'x10' overhead warehouse door in Unit # 979 tenant, Garda, Money Transport, with a new 12'x12' overhead door. Replace 3 interior wooden doors with metal doors. Paint interior walls and install new vinyl floor.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Jeanie Bourke

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Commercial bakery (Izzy's) & Recreational use (fencing) & warehouse with offices

Building Inspections

Use Group: S/B **Type:** 3B
Storage - Warehouse - Money transport services
Business - Offices for same
Unit # 979 First Floor
MUBEC/IBC2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Electrical Close-in

Final - Commercial

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2014-00876	Date Applied For: 04/28/2014	CBL: 329 B011001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: Warehouse with offices/ commercial bakery/ recreational use		Proposed Project Description: Replace 10'x10' overhead warehouse door in Unit # 979 tenant, Garda, Money Transport, with a new 12'x12' overhead door. Replace 3 interior wooden doors with metal doors. Paint interior walls and install new vinyl floor.		
Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 05/09/2014	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
Dept: Building	Status: Approved w/Conditions	Reviewer: Jeanie Bourke	Approval Date: 06/09/2014	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Fire	Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 05/22/2014	
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) All outstanding code violations shall be corrected prior to final inspection.				
2) All means of egress to remain accessible at all times.				
3) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve.				
4) Shall meet the requirements of NFPA 101, Chapter 39, Existing Business Occupancies				
5) All construction shall comply with City Code Chapter 10.				