



Jason Grant <jgrant@portlandmaine.gov>

Re: EL Printing

Joe Delaney <joe@whipplecallender.com>
To: Jason Grant <jgrant@portlandmaine.gov>
Cc: Chris LeFevre <chris@checksforless.com>, service@seacoastsecurity.com

Tue, Oct 24, 2017 at 4:48 PM

Hi Jason-

Attached is the response regarding the alarm system at Form Systems-

The owner would like to emphasize his business is just shy of 80 people and the floor space is largely bulky equipment- the calcs per NFPA seem off.

Please call with any questions-

Joe

On Oct 24, 2017, at 4:29 PM, Chris LeFevre <chris@checksforless.com> wrote:

Chris LeFevre
chris@checksforless.com
207 797-4838
800 245-5775
800 893-0177 fax
checksforless.com | rxpads.com | filerx.com

Begin forwarded message:

From: Service Dept <service@seacoastsecurity.com>
Subject: EL Printing
Date: October 24, 2017 at 4:29:10 PM EDT
To: chris@checksforless.com

The system at this location [200 riverside industrial parkway Portland Maine](#) has no AES radio system at location. Has 2 phone lines that are connect to system for form of contact for the fire system. The 2 lines that are connected to panel is [\(207\)878-3609](tel:(207)878-3609) and [\(207\)878-3597](tel:(207)878-3597)