

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

DORLER RONALD J SR

Located at

222 Riverside Ind Pkwy

PERMIT ID: 2017-01623

ISSUE DATE: 11/27/2017

CBL: 330 H005002

has permission to **Reinforce tower foundation, modifications to existing antenna equipment. Re-route cables, add stiff arms, and replace/add antennas on existing mounts.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

N/A

/s/ Brian Stephens

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

communications Tower

Building Inspections

Use Group: U

Type: 2B

Tower (Telecommunication and antennas)

ENTIRE

MUBEC/IBC-2009

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

Final - Electric

Footings

Foundation/Rebar

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-01623	Date Applied For: 10/17/2017	CBL: 330 H005002
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Communications Tower	Proposed Project Description: Reinforce tower foundation, modifications to existing antenna equipment. Re-route cables, add stiff arms, and replace/add antennas on existing mounts.			
Dept: Zoning Status: Approved w/Conditions Reviewer: Christina Stacey Approval Date: 11/02/2017				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
<hr/>				
Dept: Building Inspecti Status: Approved w/Conditions Reviewer: Brian Stephens Approval Date: 11/27/2017				
Note:				Ok to Issue: <input checked="" type="checkbox"/>
Conditions:				
1) A final report of special inspections is required stating conformance with the approved construction documents and Statement of Special Inspections. This shall include a sealed letter from the SER, which must be submitted prior to the City's final inspection, or issuance of a certificate of occupancy. This report shall document any discrepancies and corrective measures that were taken. Please email electronic documents to the plan reviewer of record and permitting@portlandmaine.gov				
2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
3) The installation shall comply with the wind load requirements of the IBC 2009, Sec. 16091.1 pre TIA-222-G.				
4) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				