

•
•
•
•
•
•
•

389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal


To: John Leasure **From:** Mike Nugent

Fax: 799-5432 **Date:** May 12, 2004

Phone **Pages:** 1

Re: 1039 Riverside St

Urgent For Review Please Comment Please Reply Please Recycle



I have commenced a partial review the submissions for the above permit and have the following questions:

- 1) The building was certified as being type 3A construction. There are no implied fire ratings for the exterior walls, roof, and interior structural elements. (table 602)
- 2) This is a mixed use building, is this being designed pursuant to Section 313.1.1 or 313.1.2
- 3) The egress for the Office space passes through an adjoining space, this is noncompliant with the provisions of Chapter 10.
- 4) Complete cross sections of all intended fire separation assemblies with associated UL listings are required.
- 5) HVAC, Plumbing and Electrical plans are required , complete with fire separation assembly penetration plans (see Section 714)

• • • • •