

•
•
•
•
•
•
•

389 Congress St.rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal


To: Dennis Waters **From:** Mike Nugent

Fax: **Date:** December 29, 2005

Phone **Pages:** 1

Re: 1039 Riverside St. (051694 331 A001)

Urgent For Review Please Comment Please Reply Please Recycle



I have completed the review of Permit # 051694 and need the following:

- 1) COMCheck Energy Conservation compliance Report.
- 2) Information detailing interior finishes and establishing compliance with Chapter 8 of the 2003 IBC.
- 3) HVAC, Plumbing and Electrical plans created by a licensed engineer.
- 4) Door 1 and the glazing panel next to it need to be class II Safety Glazing.
- 5) All doors are shown as landing at grade. If this is not the case, code compliant stair plans must be submitted and approved.
- 6) The Architecturals did not have any details, really none! Except the simple wall cross section. The general contractor is disallowed by law from doing design work, so the architect needs to provide detail work for the complete construction.

• • • • •