

**STATEMENT OF SPECIAL
CONSTRUCTION MONITORING**

**PROJECT: 1039 RIVERSIDE ST, UNIT #2 – NEW BUILDING
1039 Riverside St, Portland Maine 04103**

**PERMIT APPLICANT: Biskup Construction Inc
APPLICANT'S ADDRESS: 16 Danielle Dr, Windham, ME 04062**

STRUCTURAL ENGINEER OF RECORD: Associated Design Partners, Inc

CONTRACTOR: Biskup Construction Inc

This Statement of Special Construction Monitoring is submitted as a condition for building permit issuance in accordance with Section 1704.0 of the 2009 International Building Code. It includes the Schedule of Special Construction Monitoring and Testing as applicable to this project. Also included is a listing of agents and other approved agencies to be retained for conducting the monitoring and testing applicable to this project.

The Special Construction Monitoring Coordinator shall keep records of all observations listed herein, and shall furnish field reports to the Registered Design Professional of Record. All discrepancies shall be brought to the immediate attention of the Contractor for correction, and to the Registered Design Professional of Record. If the discrepancies are not corrected, the discrepancies shall be brought to the attention of the Registered Design Professional of Record. Interim reports shall be submitted to the Registered Design Professional of Record monthly, unless more frequent submissions are requested.

The Special Inspection program does not relieve the Contractor of his or her responsibilities. Job site safety is solely the responsibility of the Contractor. Materials and activities covered under the monitoring schedule are not to include the Contractor's equipment and methods used to erect or install the materials listed.

Prepared by:

Aaron S. Wilson, P.E.

(type or print name)

Aaron S. Wilson

Signature

6/16/16

Date



Owner's Authorization:

Building Official's Acceptance:

[Signature] 6/18/16

Signature

Date

Signature

Date

SPECIAL CONSTRUCTION MONITORING AGENTS

This Statement of Special Construction Monitoring / Quality Assurance Plan includes the following building systems:

- | | |
|---|--|
| <input checked="" type="checkbox"/> Soils and Foundations
<input checked="" type="checkbox"/> Cast-in-Place Concrete
<input type="checkbox"/> Precast Concrete
<input type="checkbox"/> Masonry
<input checked="" type="checkbox"/> Structural Steel
<input checked="" type="checkbox"/> Cold-Formed Steel Framing | <input type="checkbox"/> Spray Fire Resistant Material
<input type="checkbox"/> Wood Construction
<input type="checkbox"/> Exterior Insulation and Finish System
<input type="checkbox"/> Mechanical & Electrical Systems
<input type="checkbox"/> Architectural Systems
<input type="checkbox"/> Special Cases |
|---|--|

AGENT	FIRM	CONTACT INFORMATION
1. Engineer of Record	Associated Design Partners	80 Leighton Rd Falmouth ME 04105 Ph: 878-1751
2. Special Construction Monitoring Coordinator	Associated Design Partners	80 Leighton Rd Falmouth ME 04105 Ph: 878-1751
3. Field Monitor	S.W. Cole	286 Portland Road Gray, ME 04039-9586 P: (207) 657.2866
4. Testing Agency	S.W. Cole	286 Portland Road Gray, ME 04039-9586 P: (207) 657.2866
5. Other		

Note: The construction monitoring agent and testing agency shall be engaged by the Owner or the Owner's Agent, and not by the Contractor or Subcontractor whose work is to be inspected or tested. Any conflict of interest must be disclosed to the Building Official, prior to commencing work.

QUALITY ASSURANCE FOR LATERAL SYSTEMS

Quality Assurance for Seismic Requirements

Seismic Design Category	C
Quality Assurance Plan Required (Y/N)	Y

If seismic design category C, and plan is not required, explain:

Description of seismic force resisting system and designated seismic systems:

Ordinary Steel Moment Resisting Frames, Ordinary Steel Concentric Braced Frames.

Quality Assurance for Wind Requirements

Basic Wind Speed (3 second gust)	100MPH
Quality Assurance Plan Required (Y/N)	N

Description of wind force resisting system and designated wind resisting components:

Ordinary Steel Moment Resisting Frames, Ordinary Steel Concentric Braced Frames.

Statement of Responsibility

Each contractor responsible for the construction or fabrication of a system or component designated above must submit a Statement of Responsibility in accordance with section 1705.3, and 1706.3 of the 2003 IBC code.

The qualifications of all personnel performing Special Inspection and testing activities are subject to the approval of the Building Official. The credentials of all Inspectors and testing technicians shall be provided if requested.

Key for Minimum Qualifications of Inspection Agents:

When the Registered Design Professional in Responsible Charge deems it appropriate that the individual performing a stipulated test or inspection have a specific certification or license as indicated below, such designation shall appear below the *Agency Number* on the Schedule.

- PE/SE** Structural Engineer – a licensed SE or PE specializing in the design of building structures
- PE/GE** Geotechnical Engineer – a licensed PE specializing in soil mechanics and foundations
- EIT** Engineer-In-Training – a graduate engineer who has passed the Fundamentals of Engineering examination

American Concrete Institute (ACI) Certification

- ACI-CFTT** Concrete Field Testing Technician – Grade 1
- ACI-CCI** Concrete Construction Inspector
- ACI-LTT** Laboratory Testing Technician – Grade 1&2
- ACI-STT** Strength Testing Technician

American Welding Society (AWS) Certification

- AWS-CWI** Certified Welding Inspector
- AWS/AISC-SSI** Certified Structural Steel Inspector

American Society of Non-Destructive Testing (ASNT) Certification

- ASNT** Non-Destructive Testing Technician – Level II or III.

International Code Council (ICC) Certification

- ICC-SMSI** Structural Masonry Special Inspector
- ICC-SWSI** Structural Steel and Welding Special Inspector
- ICC-SFSI** Spray-Applied Fireproofing Special Inspector
- ICC-PCSI** Prestressed Concrete Special Inspector
- ICC-RCSI** Reinforced Concrete Special Inspector

National Institute for Certification in Engineering Technologies (NICET)

- NICET-CT** Concrete Technician – Levels I, II, III & IV
- NICET-ST** Soils Technician - Levels I, II, III & IV
- NICET-GET** Geotechnical Engineering Technician - Levels I, II, III & IV

Exterior Design Institute (EDI) Certification

- EDI-EIFS** EIFS Third Party Inspector

TABLE 1 – SCHEDULE OF SPECIAL CONSTRUCTION MONITORING

MATERIAL / ACTIVITY	EXTENT of MONITORING (Continuous, Periodic, Other, Exempt, None)	COMMENTS	AGENT #	DATE COMPLETED	REV #
1704.3 STEEL CONSTRUCTION					
1. Material Verification of high strength bolts, nuts, and washers.	a. Identification markings to conform to ASTM standards specified in the approved construction documents.	Periodic	3		
	b. Manufacturers Certificate of Compliance required.	Exempt	5		
2. Inspection of High – Strength Bolting	a. Bearing type connections	Periodic	3		
	b. Slip – critical connections	None			
3. Material Verification of structural steel	a. Identification marking to conform to ASTM standards specified in the contract documents.	Exempt	5		
	b. Manufacturers certified mill test Reports.	Other	5		
4. Material Verification of weld filler materials:	a. Identification marking to conform to AWS standards specified in the contract documents.	Exempt	5		
	b. Manufacturers Certificate of Compliance required.	Exempt	5		
5. Inspection of Welding – Structural Steel	a. Single Pass fillet welds < 5/16"	Exempt	5		
	b. Roof deck attachment	Periodic	3		
6. Inspection of Steel Frame Joint details for compliance with approved documents.	a. Bracing / moment frame connections	Periodic	3		
	b. Member locations	Periodic	3		
	c. Application of joint details at each connection.	Periodic	3		

TABLE 1 – STATEMENT OF SPECIAL INSPECTIONS, cont.

MATERIAL/ACTIVITY	EXTENT of INSPECTION (Continuous, Periodic, Other, None)	COMMENTS	AGENT #	DATE COMPLETED	REV #
1704.4 CONCRETE CONSTRUCTION					
1. Inspection of reinforcing steel, including placement.	Periodic		3		
2. Inspection of reinforcing steel welding	None	No welding of rebar specified in contract drawings			
3. Inspect bolts embedded into concrete prior to and during placement of concrete where allowable loads have been increased.	None	Allowable loads have not been increased for lateral loads.			
4. Verify concrete mix design(s)	Periodic	SER to review and approve mix design(s) prior to delivery. Field agent to verify delivery ticket matches approved mix design.	1,3		
5. Sample fresh concrete for strength tests, perform slump and air content tests, and determine temperature of concrete.	Continuous		3,4		
6. Inspection of concrete placement for proper techniques.	Continuous		3		
7. Inspection for maintenance of specified curing temperature and techniques.	Periodic		3		
1704.5 MASONRY CONSTRUCTION - Level 1 Special Inspection for non-essential facility – 1704.5.2					
1. As Masonry Construction begins, the following shall be verified to ensure conformance	a. Proportions of site-prepared mortar		3		
	b. Construction of mortar joints		3		
	c. Location of reinforcement		3		
	d. Pre-stressing technique	No pre-stressing in building			
	e. Grade and size of pre-stressing tendons.	No pre-stressing in building			
2. The Inspection program shall verify the following:	a. Size and location of structural elements.		3		
	b. Type, size, and location of embedded anchors.		3		
	c. Size, grade, and type of reinforcing		3		

TABLE 1 – STATEMENT OF SPECIAL INSPECTIONS, cont.

MATERIAL/ACTIVITY	EXTENT of INSPECTION (Continuous, Periodic, Other, None)	COMMENTS	AGENT #	DATE COMPLETED	REV #
1704.5 MASONRY CONSTRUCTION - Level 1 Special Inspection for non-essential facility – 1704.5.2					
2. The Inspection program shall verify the following, cont:	d. welding of reinforcing bars	None			
	e. Protection of Masonry during cold weather (temp. below 40 deg F.)	Periodic	3		
	f. Application and measurement of pre-stressing reinforcement	None			
3. Prior to grouting, the following shall be verified to ensure compliance.	a. Grout space is clean	Periodic	3		
	b. Placement of reinforcement	Periodic	3		
	c. Proportions of site-prepared grout	Periodic	3		
	None	Periodic	3		
4. Grout placement shall be verified to ensure compliance with code and construction document provisions.	Periodic	No pre-stressing in building	3		
5. Preparation of any grout specimens, mortar specimens and/or prisms shall be observed	Periodic		3		
6. Compliance with required inspection provisions of the construction documents and the approved submittals shall be verified.	Periodic		3		
1704.6 WOOD CONSTRUCTION					
1. Horizontal Diaphragms and Vertical Shearwalls	a. Inspect sheathing size, grade, and thickness for conformance with construction documents.	None			
	b. Inspect sheathing fastener size and pattern for conformance with construction documents.	None			
	c. Verify attachment to supporting elements is per contract documents.	None			
2. Wood truss fabricator certification / quality control procedures	Verify shop fabrication and quality control procedures for wood truss plant.	None			
3. Material Grading	Verify material grading for sawn lumber for compliance with construction documents. Verify manufactured lumber (LVL, S, PSL's) for conformance with construction documents.	None			

TABLE 1 – STATEMENT OF SPECIAL INSPECTIONS, cont.

MATERIAL/ACTIVITY	EXTENT of INSPECTION (Continuous, Periodic, Other, None)	COMMENTS	AGENT #	DATE COMPLETED	REV #
1704.6 WOOD CONSTRUCTION					
4. Wood Connections	None	Verify that connections are made as shown in the contract documents. For connections not specifically detailed, verify conformance with IBC 2003 Ch. 23			
5. Framing	None	Verify that framing is installed in accordance with construction documents.			
6. Pre-Fabricated Wood Trusses	None	Inspect truss and all bracing installation. Bracing to be installed per fabricator's recommendations and BCSI 1-03			
1704.7 SOILS					
1. Site Preparation	Periodic	Inspect preparation of site for conformance with Geotechnical recommendations prior to placement of prepared fill.	3		
2. Fill Placement	Periodic	During Fill Placement verify that material and lift thickness comply with approved Geotechnical report.	3		
3. In-Place Soil Density	Periodic	Verify compliance of in-place compacted dry density with approved Geotechnical report.	3		
1704.7 PILE FOUNDATIONS					
	None	Record installation and testing of procedures of each pile. Submit reports to building official and EOR. Reports to include pile tip cutoff elevation relative to a common benchmark.		No Piles on Job	
1704.10 ARCHITECTURAL WALL PANELS AND VENEERS					
	None	Verify compliance of attachment of interior and exterior Architectural veneers to supporting structure for building in Seismic Design Category E or F.			
1704.11 SPRAYED FIRE-RESISTANT MATERIAL					
a.	None	Verify conformance of the prepared surface with manufacturer's specifications prior to application of material.		No Sprayed Fire-Resistant material in building.	

TABLE 1 – STATEMENT OF SPECIAL INSPECTIONS, cont.

MATERIAL/ACTIVITY	EXTENT OF INSPECTION (Continuous, Periodic, Other, None)	COMMENTS	AGENT #	DATE COMPLETED	REV #
	None				
b. Verify that substrate's ambient temperature meet manufacturer's specifications.	None				
c. Verify that material thickness meets design specifications.	None				
d. Verify that the material density meets the design specifications. Test in accordance with ASTM E 605.	None				
e. Verify that bond strength between material and substrate is greater than or equal to 150 psf. Test in accordance with ASTM E 736 and IBC 2003 1704.11.5.1 – 1704.11.5.2	None				
1704.12 EXTERIOR AND INSULATION AND FINISH SYSTEMS (EIFS)	None	No EIFS on building.			
1704.13 SPECIAL CASES COLD FORMED METAL FRAMING					
1. Framing	Periodic	Roof Purlins	3		
2. Framing Connections	Periodic	Roof Purlins	3		
3. Welding	None				
4. Light Gage Trusses	None				
	None				
	None				
	None				
	None				
	None				
	None				
	None				
	None				
	None				

TABLE 1 – STATEMENT OF SPECIAL INSPECTIONS, cont.

MATERIAL/ACTIVITY	EXTENT of INSPECTION (Continuous, Periodic, Other, None)	COMMENTS	AGENT #	DATE COMPLETED	REV #
		contract documents, and BCSI 1-03 guidelines.			
1704.10 SMOKE CONTROL	None	a. Test ductwork for leakage and recode device locations prior to concealment of mechanical systems.			
	None	b. Prior to building occupation, perform pressure difference testing, flow measurements and detection, and control monitoring.			