

1 LIFE SAFETY PLAN
SCALE: 1/8" = 1'-0"


IBC 2009 CODE DATA		NFPA 101 2009 CODE DATA	
FLOOR AREA	3,343 SF	FLOOR AREA	3,343 SF
NUMBER OF STORIES	1	NUMBER OF STORIES	1
USE AND OCCUPANCY CLASSIFICATION – SECTION 311.2	FACTORY INDUSTRIAL F-1 MODERATE HAZARD	USE GROUP CLASSIFICATION – SECTION 3.3.178.15	INDUSTRIAL - ORDINARY HAZARD
TYPE OF CONSTRUCTION – TABLE 601	II-B	TYPE OF CONSTRUCTION – NFPA 220	II (000)
FIRE RESISTANT CONSTRUCTION – TABLE 601:		FIRE RESISTANT CONSTRUCTION – NFPA 220:	
STRUCTURAL FRAME	0 HOUR	EXTERIOR BEARING WALLS	0 HOUR
EXTERIOR BEARING WALLS	0 HOUR	INTERIOR BEARING WALLS	0 HOUR
INTERIOR BEARING WALLS	0 HOUR	COLUMNS	0 HOUR
EXTERIOR NONBEARING WALLS	0 HOUR	BEAMS, GIRDERS, TRUSSES, AND ARCHES	0 HOUR
INTERIOR NONBEARING WALLS	0 HOUR	FLOOR CONSTRUCTION	0 HOUR
FLOOR CONSTRUCTION	0 HOUR	ROOF CONSTRUCTION	0 HOUR
ROOF CONSTRUCTION	0 HOUR	EXIT STAIR ENCLOSURES – SECTION 7.1.3.2.1	N/A
FIRE RATING STAIR ENCLOSURES – SECTION 1022.1.1	N/A	OCCUPANT LOAD – TABLE 7.3.1.2	34
FIRE ALARM SYSTEM REQUIRED – SECTION 907	NOT REQUIRED	PROTECTION OF VERTICAL OPENINGS – SECTION 40.3.1.1	N/A
OCCUPANT LOAD – TABLE 1004.1.1	34	MINIMUM NUMBER OF EXITS – SECTION 40.2.4.1	2 REQUIRED
MAXIMUM COMMON PATH OF TRAVEL DISTANCE – NFPA 101-2009 TABLE A7.6	50 FEET	DEAD END CORRIDOR LENGTH – TABLE TABLE A7.6	50 FEET
MAXIMUM EXIT TRAVEL DISTANCE – TABLE 1016.1	200 FEET	MAXIMUM COMMON PATH OF TRAVEL DISTANCE – TABLE A7.6	50 FEET
FIRE RATED CORRIDORS – TABLE 1018.1	N/A	MAXIMUM EXIT TRAVEL DISTANCE – TABLE A7.6	200 FEET
DEAD END CORRIDOR LENGTH – SECTION 1018.4	20 FEET	FIRE ALARM SYSTEM REQUIRED – SECTION 40.3.4.1	NOT REQUIRED
MINIMUM NUMBER OF EXITS – TABLE 1021.2	1 REQUIRED	FIRE RATED CORRIDORS – SECTION 40.3.6	N/A
FIRE EXTINGUISHERS	1 AT EACH EXIT 3-A 10-B:C	FIRE EXTINGUISHERS	1 AT EACH EXIT 3-A 10-B:C
NOTES		NOTES	



MICHAEL CHAREK ARCHITECTS
PORTLAND, MAINE

UNIT 2 WEST, SECOND TEE BUSINESS PARK
1039 RIVERSIDE STREET
PORTLAND, ME 04103

A2 - LIFE SAFETY PLAN



BY	CKD	SCALE	1/8" = 1'-0"	DATE	10/24/17
JOB NO.		DWG.			2 OF 2