Cross Section Framing Plan for Bio Rad

Inspections Division
Date: 05/02/14

Existing Building is noncombustible type 2B; no wood framing is allow except as per IBC Sec. 603

* Bottom Sill Track to be fastened by tap cons concrete fasteners