

Switchboard: MSB

Location: ELECTRICAL 133
Supply From: MSB
Mounting: Surface
Enclosure: Type 1

Volts: 480Y/277V
Phases: 3
Wires: 4

A.I.C. Rating: 65000
Mains Type: MCB
Mains Rating: 2000 A
MCB Rating: 2000 A

Notes:

Table with columns: CKT, Circuit Description, # of Poles, Frame Size, Trip Rating, Load, Remarks. Lists various circuit breakers and their specifications.

Legend:

Table with columns: Load Classification, Connected Load, Demand Factor, Estimated Demand, Panel Totals. Summarizes electrical load data.

Notes:

Branch Panel: DP2-2

Location: MECHANICAL/ELECTRICAL 209
Supply From: DP2
Mounting: Surface
Enclosure: Type 1

Volts: 480Y/277V
Phases: 3
Wires: 4

A.I.C. Rating: 65,000 AIC
Mains Type: MCB
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

Table with columns: CKT, Circuit Description, Feeder Size, Trip, Poles, A, B, C, Poles, Trip, Feeder Size, Circuit Description, CKT. Lists branch panel circuits.

Legend:

Table with columns: Load Classification, Connected Load, Demand Factor, Estimated Demand, Panel Totals. Summarizes load data for DP2-2.

Notes: DOUBLE MAIN LUGS

Branch Panel: PP1

Location: MECHANICAL 112
Supply From: T2
Mounting: Surface
Enclosure: Type 1

Volts: 208Y/120V
Phases: 3
Wires: 4

A.I.C. Rating:
Mains Type: MCB
Mains Rating: 250 A
MCB Rating: 250 A

Notes:

Table with columns: CKT, Circuit Description, Feeder Size, Trip, Poles, A, B, C, Poles, Trip, Feeder Size, Circuit Description, CKT. Lists branch panel circuits for PP1.

Legend:

Table with columns: Load Classification, Connected Load, Demand Factor, Estimated Demand, Panel Totals. Summarizes load data for PP1.

Notes: DOUBLE MAIN LUGS

Branch Panel: DP1

Location: MECHANICAL 112
Supply From: MSB
Mounting: Surface
Enclosure: Type 1

Volts: 480Y/277V
Phases: 3
Wires: 4

A.I.C. Rating: 65,000 AIC
Mains Type: MCB
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

Table with columns: CKT, Circuit Description, Feeder Size, Trip, Poles, A, B, C, Poles, Trip, Feeder Size, Circuit Description, CKT. Lists branch panel circuits for DP1.

Legend:

Table with columns: Load Classification, Connected Load, Demand Factor, Estimated Demand, Panel Totals. Summarizes load data for DP1.

Notes:

Branch Panel: DP2

Location: ELECTRICAL ROOM 215
Supply From: MSB
Mounting: Surface
Enclosure: Type 1

Volts: 480Y/277V
Phases: 3
Wires: 4

A.I.C. Rating: 65,000 AIC
Mains Type: MCB
Mains Rating: 400 A
MCB Rating: 400 A

Notes:

Table with columns: CKT, Circuit Description, Feeder Size, Trip, Poles, A, B, C, Poles, Trip, Feeder Size, Circuit Description, CKT. Lists branch panel circuits for DP2.

Legend:

Table with columns: Load Classification, Connected Load, Demand Factor, Estimated Demand, Panel Totals. Summarizes load data for DP2.

Notes: DOUBLE MAIN LUGS

Branch Panel: PP2

Location: ELECTRICAL ROOM 215
Supply From: PP1
Mounting: Surface
Enclosure: Type 1

Volts: 208Y/120V
Phases: 3
Wires: 4

A.I.C. Rating:
Mains Type: MCB
Mains Rating: 250 A
MCB Rating: 250 A

Notes:

Table with columns: CKT, Circuit Description, Feeder Size, Trip, Poles, A, B, C, Poles, Trip, Feeder Size, Circuit Description, CKT. Lists branch panel circuits for PP2.

Legend:

Table with columns: Load Classification, Connected Load, Demand Factor, Estimated Demand, Panel Totals. Summarizes load data for PP2.

Notes: GFI BREAKER



Stantec Consulting Services Inc.
3 Columbia Circle Suite 6
Albany, NY 12203-5189
Tel: (518) 452-4358 / Fax: (518) 452-9234

www.stantec.com

Copyright Reserved

The Contractor shall verify and be responsible for all dimensions, DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay. The Copyright to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Client

ImmuCell

Lot 11 - Second Tee Business Park
1039 Riverside Street
Portland, Maine 04103

Consultants

0 - INTERIOR FIT-OUT - ISSUED FOR CONSTRUCTION 08/19/2016

Revision By App'd DD.MAY.YYYY


PACKAGE C - INTERIOR FIT-OUT 08/19/2016

PACKAGE B - SUPERSTRUCTURE & SHELL 08/05/2016

PACKAGE A - FOUNDATIONS & BELOW SLAB 07/22/2016

Issued By App'd DD.MAY.YYYY

Permit/Seal



Client/Project

IMMUCELL

Lot 11 - Second Tee Business Park
1039 Riverside Street
Portland, Maine 04103

Title
PANEL SCHEDULES (1 OF 3)

Project No. 191504176 Scale

Revision Drawing No.

0

E-802-C