

PUBLIC ADDRESS SYSTEM RISER DIAGRAM

E-805-C N.T.S.

PUBLIC ADDRESS SYSTEM NOTES

INTERVALS.

- SEE DWG. E-000-C FOR DRAWING LIST, SYMBOLS, ABBREVIATIONS AND GENERAL
- RISER IS DIAGRAMMATIC, NOT ALL SPEAKERS ARE SHOWN. FOR EXACT QUANTITIES AND LOCATION OF DEVICES REFER TO DWGS. E-301-C, E-302-C.
- PUBLIC ADDRESS SYSTEM RECESSED CEILING AND WALL MOUNTED SPEAKERS SHALL BE 8" AS MANUFACTURED BY ELECTRO-VOICE. AMPLIFIERS SHALL BE MODEL MA-1212 AS MANUFACTURED BY ELECTRO-VOICE INC.
- 4. UNLESS OTHER WISE NOTED ALL CABLING SHALL BE INSTALLED IN CABLE TRAY AND AS FOLLOWS: A. WALLS OR PARTITIONS - IN CONDUIT. B. ABOVE SUSPENDED CEILING AND IN UNFINISHED AREAS - SUPPORTED BY J-HOOKS MOUNTED AS HIGH AS POSSIBLE TO BUILDING STEEL ON MAXIMUM 3"
- COORDINATE AMPLIFIER LOCATION INSIDE ROOM #216 WITH OWNER AND PROVIDE ALL RACKS, MOUNTING HARDWARE AND OTHER ACCESSORIES REQUIRED FOR A COMPLETE INSTALLATION. PROVIDE ADDITIONAL AMPLIFIER/CIRCUIT IF LOADING EXCEEDS MAXIMUM AMPLIFIER CAPACITY.
- 2#14 STANDARD NON-SHIELDED, PLENUM RATED. GENERAL CABLE #C3128 OR APPROVED EQUAL.

GYP CEILING W/ ACCESS PANELS — ✓ 4" SLEAVES TYPICAL OFFICE SECOND FLOOR 3/4" C TO FACP - COMBINATION

TELE/DATA

OUTLET MOUNTED

IN WALL (TYP.)

TELEPHONE / DATA SYSTEM NOTES

- DEVICES SHOWN ARE TYPICAL ONLY. FOR EXACT LOCATIONS AND QUANTITIES REFER TO FLOOR PLANS.
- 2. ELECTRICAL CONTRACTOR SHALL PROVIDE A 4" BOX WITH A REDUCING RING TO SINGLE DUPLEX AND A 1" STUB ABOVE THE FINISHED CEILING FOR ALL TEL/DATA OUTLETS. REFER TO TEL/DATA DRAWINGS FOR EXACT LOCATIONS AND QUANTITIES.
- PROVIDE JUNCTION BOX AT CEILING ADJACENT TO POWER JUNCTION BOX FOR EACH TEL/DATA DROP IN AREAS WITH NO SUSPENDED CEILING. 4. FOR ALL FIRST FLOOR AREAS, PROVIDE CONDUIT WITH PULL STING ALL THE WAY BACK TO THE DATA ROOM. HOME RUNS SHALL BE SIZED BASED ON 40% MAXIMUM FILL, WITH 4 CABLES 0.22" DIAMETER EACH, AT EACH STATION.

5. IT ROOM TELE/DATA EQUIPMENT SHALL BE PROVIDED BY OWNER.

SEE SITE PLAN FOR CONTINUATION

INTERIOR EXTERIOR

TYPICAL 1ST FLOOR

SPACE W/ GYP

BOARD CEILING.

TELEPHONE / DATA RISER DIAGRAM

FIRST FLOOR

Stantec Consulting Services Inc. 3 Columbia Circle Suite 6 Albany, NY 12203-5158 Tel: (518) 452-4358 / Fax: (518) 452-9234

www.stantec.com

Copyright Reserved The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay. The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Lot 11 - Second Tee Business Park 1039 Riverside Street Portland, Maine 04103

Consultants

_____ INTERIOR FIT OUT - ISSUED FOR 08/19/2016 CONSTRUCTION Revision PACKAGE C - INTERIOR FIT-OUT PACKAGE B - SUPERSTRUCTURE & SHELL PACKAGE A - FOUNDATIONS & BELOW SLAB

ISSUED

By Appd DD.MM.YYYY

Permit-Seal



Client/Project **IMMUCELL**

Lot 11 - Second Tee Business Park 1039 Riverside Street Portland, Maine 04103

COMMUNICATION RISER DIAGRAMS

Project No. N.T.S. 191504176 Revision

ORIGINAL SHEET - ANSI E (34"x44")