


GENERAL NOTES

- BOD DIMENSIONS AND RATINGS ARE DIAGRAMMATIC IN NATURE. MECHANICAL CONTRACTOR IS RESPONSIBLE FOR FIELD VERIFICATION, ROUTING AND COORDINATION OF NEW DUCTWORK.
- ALL BOD DIMENSIONS ARE IN REFERENCE THE FIRST FLOOR FINISHED FLOOR.
- OUTLINES INDICATE UNIT COIL FULL ORIENTATION AND CLEARANCES.
- FURNISH AND INSTALL FLEXIBLE CONNECTION TO EQUIPMENT. SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION.
- ALL DUCTWORK SHALL BE SUPPORTED AS PER DETAILS ON SHEET MH-802. ALL EQUIPMENT SHALL BE SUPPORTED AS PER THE SPECIFICATIONS.

KEYED NOTES

- PROVIDE A 20" VERTICAL EXHAUST STACK FOR FAN DISCHARGE WEST OF FAN. DISCHARGE POINT SHALL BE NO LESS THAN 10' ABOVE TOP OF ROOF. STACK SHALL HAVE SLANTED BOTTOM PLATE AND DRAIN CONNECTION. STACK DISCHARGE SHALL BE SEE HVAC DETAILS FOR ADDITIONAL INFORMATION.
- PROVIDE A 20" VERTICAL EXHAUST STACK FOR FAN DISCHARGE EAST OF FAN. DISCHARGE POINT SHALL BE NO LESS THAN 10' ABOVE TOP OF ROOF. STACK SHALL HAVE SLANTED BOTTOM PLATE AND DRAIN CONNECTION. STACK DISCHARGE SHALL BE SEE HVAC DETAILS FOR ADDITIONAL INFORMATION.
- BOILER VENT STACK SHALL EXTEND 10' BEYOND ROOF LEVEL. COORDINATE PENETRATION THROUGH DRAINAGE WITH STRUCTURAL DISCIPLINE. VENT STACK SHALL BE DOUBLE WALL DUCTWORK WITH AN 18" INNER MEASUREMENT. SEE MH-603-C FOR ADDITIONAL DETAILS.



Revision	By	App'd	DD.MM.YYYY
0	INTERIOR FIT-OUT ISSUED FOR CONSTRUCTION		08/19/2016
	PACKAGE C - INTERIOR FIT-OUT		08.19.2016
	PACKAGE B - SUPERSTRUCTURE & SHELL		08.05.2016
	PACKAGE A - FOUNDATIONS & BELOW SLAB		07.22.2016
	Issued	By	App'd DD.MM.YYYY

Permit-Seal

Client/Project
IMMUCELL

Lot 11 - Second Tee Business Park
1039 Riverside Street
Portland, Maine 04103

Title
ROOF - MECHANICAL DUCTWORK PLAN


Project No.
191504176

Scale
1/4" = 1'-0"

Revision
0

Drawing No.

MH-603-C



1 ROOF - HVAC PLAN
1/4" = 1'-0"

DRAWING MADE BY: P:\Projects\191504176\191504176-0000-0000-0000-0000-0000.dwg, immucell, 11/20/16, 11/20/16

ORIGINAL SHEET: A08 E (3/14/16)

