

GENERAL NOTES

- PERFORM ALL WORK IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE, NFPA 72 AND AUTHORITY HAVING JURISDICTION.
- REFER TO DRAWING E-401-C FOR FIRE ALARM SYMBOLS, NOTES, RISER DIAGRAM AND ADDITIONAL INFORMATION.
- ELECTRICAL CONTRACTOR TO FURNISH AND WIRE DUCT MOUNTED SMOKE DETECTORS. MECHANICAL CONTRACTOR TO INSTALL PER MANUFACTURERS RECOMMENDATIONS. COORDINATE EXACT LOCATION WITH MECHANICAL DRAWINGS AND CONTRACTOR, (TYPICAL).



1
E-401-C
FIRST FLOOR - FIRE ALARM PLAN
 1/4" = 1'-0"



Revision	By	App'd	DATE
0			08/19/2016
PACKAGE C - INTERIOR FIT-OUT			
PACKAGE B - SUPERSTRUCTURE & SHELL			
PACKAGE A - FOUNDATIONS & BELOW SLAB			
Issued			08.19.2016
			08.05.2016
			07.22.2016



Client/Project
IMMUCELL
 Lot 11 - Second Tee Business Park
 1039 Riverside Street
 Portland, Maine 04103

Title
FIRST FLOOR - FIRE ALARM PLAN
 Project No.
 191504176
 Scale
 1/4" = 1'-0"
 Revision
 0
 Drawing No.

E-401-C

PRINTED AND PLOTTED BY: [unreadable] DATE: 08/19/2016
 PLOTTER: HP DesignJet T1100e