1 E-402-C **SECOND FLOOR - FIRE ALARM PLAN**
1/4" = 1'-0"

GRAPHIC SCALE (FEET)
1/4" = 1'-0"
0 2 4 8

NORTH

Stantec

Stantec Consulting Services Inc.
3 Columbia Circle Suite 6
Albany, NY 12203-5158
Tel: (518) 452-4358 / Fax: (518) 452-9234

www.stantec.com

Copyright Reserved

The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay.
The Copyrights to all designs and drawings are the property of Stantec. Reproduction or use for any purpose other than that authorized by Stantec is forbidden.

Client

ImmuCell

Lot 11 - Second Tee Business Park
1039 Riverside Street
Portland, Maine 04103

Consultants

GENERAL NOTES

1. PERFORM ALL WORK IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE, NFPA 72, AND AUTHORITY HAVING JURISDICTION.
2. REFER TO DRAWING E-400-C FOR FIRE ALARM SYMBOLS, NOTES, RISER DIAGRAM AND ADDITIONAL INFORMATION.
3. ELECTRICAL CONTRACTOR TO FURNISH AND WIRE DUCT MOUNTED SMOKE DETECTORS. MECHANICAL CONTRACTOR TO INSTALL PER MANUFACTURER'S RECOMMENDATIONS. COORDINATE EXACT LOCATION WITH MECHANICAL DRAWINGS AND CONTRACTOR. (TYPICAL).

Revision	By	App'd	DD/MM/YYYY
0 INTERIOR FIT OUT - ISSUED FOR CONSTRUCTION			08/19/2016

Issued	By	Appd	DD/MM/YYYY
PACKAGE C - INTERIOR FIT-OUT			**08.19.2016**
PACKAGE B - SUPERSTRUCTURE & SHELL			08.05.2016
PACKAGE A - FOUNDATIONS & BELOW SLAB			07.22.2016

Permit-Seal

STATE OF MAINE
Licensed
4271
LICENSED PROFESSIONAL ENGINEER
8/19/2016

Client/Project
IMMUCELL

Lot 11 - Second Tee Business Park
1039 Riverside Street
Portland, Maine 04103

Title
SECOND FLOOR - FIRE ALARM PLAN

Project No. 191504176
Scale 1/4" = 1'-0"
Revision 0
Drawing No. **E-402-C**

Reviewed for Code Compliance
Jack Ward Thomas
Authority Having Jurisdiction
Date: 03/16/17

ORIGINAL SHEET - ANSI E (34"x44")