

... Fire Protection by Computer Design

EASTERN FIRE
170 KITTYHAWK AVE. / P.O. BOX
AUBURN, ME , 04210
207-784-1507

Job Name : IMMUCELL
Building : 1 OF 2
Location : PORTLAND
System : 1
Contract : 5568
Data File : Immucell system #2 interstitial space.WXF

HYDRAULIC CALCULATIONS
for

Project name: IMMUCELL
Location: PORTLAND
Drawing no: 1 OF 2
Date: 2/28/17

Design

Remote area number: 1
Remote area location: LEVEL 2 INTERSTITIAL SPACE
Occupancy classification: OH2
Density: .2 - Gpm/SqFt
Area of application: 1545 - SqFt
Coverage per sprinkler: 130 - SqFt
Type of sprinklers calculated: 5.6K BRASS UPRIGHTS
No. of sprinklers calculated: 13
In-rack demand: - GPM
Hose streams: 250 - GPM
Total water required (including hose streams): 564.08 - GPM @ 52.3 - Psi
Type of system: WET
Volume of dry or preaction system: - Gal

Water supply information

Date: 07-12-16
Location: FLOW HYDRANT LOCATED ON WELCH ST. & CADDIE ST.
Source: EASTERN FIRE PROTECTION

Name of contractor: EASTERN FIRE
Address: 170 KITTYHAWK AVE. / P.O. BOX / / AUBURN, ME , 04210
Phone number: 207-784-1507
Name of designer: RJP
Authority having jurisdiction: STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

EASTERN FIRE
IMMUCELL

Page 2
Date 2/28/17

City Water Supply:
C1 - Static Pressure : 82
C2 - Residual Pressure: 51
C2 - Residual Flow : 950

Demand:
D1 - Elevation : 13.365
D2 - System Flow : 414.081
D2 - System Pressure : 52.269
Hose (Demand) : 150
D3 - System Demand : 564.081
Safety Margin : 17.912



Fittings Used Summary

EASTERN FIRE
IMMUCELL

Page 3
Date 2/28/17

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zma	Maxim M200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Unit Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

EASTERN FIRE
IMMUCELL

Page 4
Date 2/28/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
SP03	0.0	5.6	15.43	na	22.0	0.2	110	7.0
EQ03	0.0		16.36	na				
SP02	0.0	5.6	15.43	na	22.0	0.2	110	7.0
EQ02	0.0		15.9	na				
SP01	0.0	5.6	15.43	na	22.0	0.2	110	7.0
EQ01	0.0		15.9	na				
SP04	0.0	5.6	15.43	na	22.0	0.2	110	7.0
EQ04	0.0		15.9	na				
SP05	0.0	5.6	15.43	na	22.0	0.2	110	7.0
EQ05	0.0		16.36	na				
42	130.86	K = K @ EQ05	16.36	na	22.0			
43	130.86		16.69	na				
44	129.7		19.44	na				
45	129.7	K = K @ EQ03	19.71	na	24.15			
46	129.7	K = K @ EQ03	21.74	na	25.35			
47	129.7		24.89	na				
48	129.7		25.12	na				
69	129.7		28.81	na	50.0			
TOR2	129.7		31.63	na				
HDR1	107.0		43.42	na	50.0			
BFP	102.0		46.12	na				
BASE	100.0		50.91	na				
TEST	100.0		52.27	na	150.0			
49	130.86	K = K @ EQ04	16.31	na	22.28			
50	130.86	K = K @ EQ04	16.43	na	22.36			
51	130.86	K = K @ EQ05	16.48	na	22.08			
52	129.7	K = K @ EQ01	19.2	na	24.18			
53	129.7	K = K @ EQ03	19.26	na	23.87			
54	127.53	K = K @ EQ02	19.43	na	24.32			
55	129.7		21.86	na				
56	129.7	K = K @ EQ03	22.06	na	25.55			
57	129.7	K = K @ EQ03	22.57	na	25.83			
58	129.7	K = K @ EQ03	23.43	na	26.32			
59	129.7		25.0	na				
60	129.7	K = K @ EQ01	21.85	na	25.79			

The maximum velocity is 16.35 and it occurs in the pipe between nodes 46 and 47

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE
IMMUCELL

Page 5
Date 2/28/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
SP03 to EQ03	22.00 22.0 0.0 22.00	1.049 120.0 0.1552	T 5.0 0.0 0.0	1.000 5.000 6.000	15.434 0.0 0.931		K Factor = 5.60 Vel = 8.17		
					16.365		K Factor = 5.44		
SP02 to EQ02	22.00 22.0 0.0 22.00	1.049 120.0 0.1550	E 2.0 0.0 0.0	1.000 2.000 3.000	15.434 0.0 0.465		K Factor = 5.60 Vel = 8.17		
					15.899		K Factor = 5.52		
SP01 to EQ01	22.00 22.0 0.0 22.00	1.049 120.0 0.1550	E 2.0 0.0 0.0	1.000 2.000 3.000	15.434 0.0 0.465		K Factor = 5.60 Vel = 8.17		
					15.899		K Factor = 5.52		
SP04 to EQ04	22.00 22.0 0.0 22.00	1.049 120.0 0.1550	E 2.0 0.0 0.0	1.000 2.000 3.000	15.434 0.0 0.465		K Factor = 5.60 Vel = 8.17		
					15.899		K Factor = 5.52		
SP05 to EQ05	22.00 22.0 0.0 22.00	1.049 120.0 0.1552	T 5.0 0.0 0.0	1.000 5.000 6.000	15.434 0.0 0.931		K Factor = 5.60 Vel = 8.17		
					16.365		K Factor = 5.44		
42 to 43	44.28 44.28	2.157 120.0 0.0169	J 10.461 0.0 0.0	9.000 10.461 19.461	16.365 0.0 0.329		K Factor @ node EQ05 Vel = 3.89		
43 to 44	44.45 88.73	2.157 120.0 0.0612	2J 20.921 4.307 0.0	11.420 25.228 36.648	16.694 0.502 2.243		Vel = 7.79		
44 to 45	48.04 136.77	2.157 120.0 0.1365	0.0 0.0 0.0	2.000 0.0 2.000	19.439 0.0 0.273		Vel = 12.01		
45 to 46	24.15 160.92	2.157 120.0 0.1841	0.0 0.0 0.0	11.000 0.0 11.000	19.712 0.0 2.025		K Factor @ node EQ03 Vel = 14.13		
46 to 47	25.35 186.27	2.157 120.0 0.2413	J 10.461 0.0 0.0	2.610 10.461 13.071	21.737 0.0 3.154		K Factor @ node EQ03 Vel = 16.35		
47 to 48	0.0 186.27	4.26 120.0 0.0088	J 21.067 0.0 0.0	4.640 21.067 25.707	24.891 0.0 0.225		Vel = 4.19		
48 to 69	127.81 314.08	4.26 120.0 0.0231	8I 73.736 0.0 0.0	86.250 73.736 159.986	25.116 0.0 3.690		Vel = 7.07		
69 to TOR2	50.00 364.08	4.26 120.0 0.0303	2I 18.434 J 21.067 0.0	53.583 39.501 93.084	28.806 0.0 2.822		Qa = 50.00 Vel = 8.20		

Final Calculations - Hazen-Williams

EASTERN FIRE
IMMUCELL

Page 6
Date 2/28/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
TOR2 to HDR1	0.0 364.08	4.26 120.0 0.0303	B S	15.8 28.968 0.0	20.000 44.768 64.768	31.628 9.831 1.964				Vel = 8.20
HDR1 to BFP	50.00 414.08	4.26 120.0 0.0384	I G	9.217 2.633 0.0	2.000 11.850 13.850	43.423 2.166 0.532				Qa = 50.00 Vel = 9.32
BFP to BASE	0.0 414.08	4.26 120.0 0.0385	Zma I	0.0 9.217 0.0	2.000 9.217 11.217	46.121 4.357 0.432				* Fixed Loss = 3.491 Vel = 9.32
BASE to TEST	0.0 414.08	6.16 140.0 0.0048	3I J G	43.037 35.864 4.304	200.000 83.205 283.205	50.910 0.0 1.359				Vel = 4.46
	150.00 564.08									Qa = 150.00 K Factor = 78.02
49 to 42	22.28 22.28	2.157 120.0 0.0047		0.0 0.0 0.0	11.000 0.0 11.000	16.313 0.0 0.052				K Factor @ node EQ04 Vel = 1.96
	0.0 22.28									K Factor = 5.51
50 to 51	22.36 22.36	2.157 120.0 0.0047		0.0 0.0 0.0	11.000 0.0 11.000	16.430 0.0 0.052				K Factor @ node EQ04 Vel = 1.96
51 to 43	22.08 44.44	2.157 120.0 0.0170	J	10.461 0.0 0.0	2.000 10.461 12.461	16.482 0.0 0.212				K Factor @ node EQ05 Vel = 3.90
	0.0 44.44									K Factor = 10.88
52 to 53	24.18 24.18	2.157 120.0 0.0055		0.0 0.0 0.0	11.000 0.0 11.000	19.202 0.0 0.060				K Factor @ node EQ01 Vel = 2.12
53 to 44	23.86 48.04	2.157 120.0 0.0197		0.0 0.0 0.0	9.000 0.0 9.000	19.262 0.0 0.177				K Factor @ node EQ03 Vel = 4.22
	0.0 48.04									K Factor = 10.90
54 to 55	24.32 24.32	1.049 120.0 0.1869	E T	2.0 5.0 0.0	11.040 7.000 18.040	19.427 -0.940 3.371				K Factor @ node EQ02 Vel = 9.03
55 to 56	25.79 50.11	2.157 120.0 0.0212		0.0 0.0 0.0	9.700 0.0 9.700	21.858 0.0 0.206				Vel = 4.40
56 to 57	25.54 75.65	2.157 120.0 0.0455		0.0 0.0 0.0	11.000 0.0 11.000	22.064 0.0 0.501				K Factor @ node EQ03 Vel = 6.64
57 to 58	25.84 101.49	2.157 120.0 0.0785		0.0 0.0 0.0	11.000 0.0 11.000	22.565 0.0 0.863				K Factor @ node EQ03 Vel = 8.91

Final Calculations - Hazen-Williams

EASTERN FIRE
IMMUCELL

Page 7
Date 2/28/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
58 to 59	26.32 127.81	2.157 120.0 0.1203	J	10.461 0.0	2.610 10.461 13.071	23.428 0.0			K Factor @ node EQ03	
59 to 48	0.0 127.81	4.26 120.0 0.0043	J	21.067 0.0	5.610 21.067 26.677	25.000 0.0			Vel = 11.22	
	0.0 127.81					0.116			Vel = 2.88	
						25.116			K Factor = 25.50	
60 to 55	25.79 25.79	2.067 120.0 0.0077		0.0 0.0	1.300 0.0 1.300	21.848 0.0			K Factor @ node EQ01	
	0.0 25.79					0.010			Vel = 2.47	
						21.858			K Factor = 5.52	