



... Fire Protection by Computer Design

EASTERN FIRE
170 KITTYHAWK AVE. / P.O. BOX
AUBURN, ME , 04210
207-784-1507

Job Name : IMMUCELL
Building : 1 OF 2
Location : PORTLAND
System : 5
Contract : 5568
Data File : Immucell system #2 walk in cooler.WXF

HYDRAULIC CALCULATIONS
for

Project name: IMMUCELL
Location: PORTLAND
Drawing no: 1 OF 2
Date: 2/28/17

Design

Remote area number: 5
Remote area location: LEVEL 2 WALKIN COOLER
Occupancy classification: EXTRA HAZARD
Density: .3 - Gpm/SqFt
Area of application: 440 - SqFt
Coverage per sprinkler: 80 - SqFt
Type of sprinklers calculated: DRY PENDENTS 8.OK
No. of sprinklers calculated: 6
In-rack demand: - GPM
Hose streams: 500 - GPM
Total water required (including hose streams): 598.5 - GPM @ 31.98 - Psi
Type of system: WET
Volume of dry or preaction system: - Gal

Water supply information

Date: 07-12-2016
Location: FLOW HYDRANT LOCATED ON WELCH ST. & CADDIE ST.
Source: EASTERN FIRE

Name of contractor: EASTERN FIRE
Address: 170 KITTYHAWK AVE. / P.O. BOX / / 170 KITTYHAWK AVE. / P.O.
Phone number: 207-784-1507
Name of designer: RJP
Authority having jurisdiction: STATE FIRE MARSHAL
Notes: (Include peaking information or gridded systems here.)


Water Supply Curve C

EASTERN FIRE
IMMUCELL

Page 2
Date 2/28/17

City Water Supply:
C1 - Static Pressure : 82
C2 - Residual Pressure: 51
C2 - Residual Flow : 950

Demand:
D1 - Elevation : 13.461
D2 - System Flow : 198.511
D2 - System Pressure : 31.974
Hose (Demand) : 400
D3 - System Demand : 598.511
Safety Margin : 36.839



Fittings Used Summary

EASTERN FIRE
IMMUCELL

Page 3
Date 2/28/17

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
I	90' Grvd-Vic Elbow #10	0	0	2	3	4	3.5	6	5	8	7	8.5	10	13	17	20	23	25	33	36	40
J	90'Tee-Branch Grv Vic #20	0	0	4.5	6	8	8.5	10.8	13	17	16	21	25	33	41	50	65	78	88	98	120
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zma	Maxim M200 Horz Butt	Fitting generates a Fixed Loss Based on Flow																			

Unit Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

EASTERN FIRE
IMMUCELL

Page 4
Date 2/28/17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP02	0.0	8	9.0	na	24.0	0.3	80	7.0
EQ02	0.0		10.09	na				
DP04	0.0	8	9.0	na	24.0	0.3	80	7.0
EQ04	0.0		10.81	na				
DP01	0.0	8	9.0	na	24.0	0.3	80	7.0
EQ01	0.0		10.09	na				
DP03	0.0	8	9.0	na	24.0	0.3	80	7.0
EQ03	0.0		10.81	na				
85	131.08	K = K @ EQ04	10.86	na	24.05			
86	131.08		11.13	na				
87	131.08		11.71	na				
88	131.08		12.92	na				
89	129.33		14.67	na				
69	130.36		14.52	na				
70	129.83		14.89	na				
TOR2	129.7		15.34	na				
HDR1	107.0		25.55	na	50.0			
BFP	102.0		27.85	na				
BASE	100.0		31.62	na				
TEST	100.0		31.97	na	400.0			
90	131.08	K = K @ EQ01	10.71	na	24.72			
91	131.08	K = K @ EQ02	10.76	na	24.78			
91A	131.08		11.06	na				
92	131.08	K = K @ EQ03	10.81	na	24.0			
93	131.08	K = K @ EQ01	11.35	na	25.45			
94	131.08	K = K @ EQ02	11.4	na	25.51			

The maximum velocity is 8.91 and it occurs in the pipe between nodes DP02 and EQ02

Final Calculations - Hazen-Williams - 2007

EASTERN FIRE
IMMUCELL

Page 5
Date 2/28/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP02 to EQ02	24.00 24.0	1.049 120.0 0.1823	T 5.0 0.0 0.0	1.000 5.000 6.000	9.000 0.0 1.094			K Factor = 8.00 Vel = 8.91	
	0.0 24.00					10.094		K Factor = 7.55	
DP04 to EQ04	24.00 24.0	1.049 120.0 0.1824	E 2.0 T 5.0 0.0	2.920 7.000 9.920	9.000 0.0 1.809			K Factor = 8.00 Vel = 8.91	
	0.0 24.00					10.809		K Factor = 7.30	
DP01 to EQ01	24.00 24.0	1.049 120.0 0.1823	T 5.0 0.0 0.0	1.000 5.000 6.000	9.000 0.0 1.094			K Factor = 8.00 Vel = 8.91	
	0.0 24.00					10.094		K Factor = 7.55	
DP03 to EQ03	24.00 24.0	1.049 120.0 0.1824	T 5.0 E 2.0 0.0	2.920 7.000 9.920	9.000 0.0 1.809			K Factor = 8.00 Vel = 8.91	
	0.0 24.00					10.809		K Factor = 7.30	
85 to 86	48.05 48.05	2.157 120.0 0.0197	J 10.461 0.0 0.0	3.670 10.461 14.131	10.856 0.0 0.278			K Factor @ node EQ04 Vel = 4.22	
86 to 87	49.51 97.56	2.635 120.0 0.0276	J 14.827 0.0 0.0	6.080 14.827 20.907	11.134 0.0 0.576			Vel = 5.74	
87 to 88	50.95 148.51	2.635 120.0 0.0599	2I 16.474 0.0 0.0	3.750 16.474 20.224	11.710 0.0 1.211			Vel = 8.74	
88 to 89	0.0 148.51	2.635 120.0 0.0598	J 14.827 0.0 0.0	1.750 14.827 16.577	12.921 0.758 0.992			Vel = 8.74	
89 to 69	0.0 148.51	4.26 120.0 0.0058	2I 18.434 0.0 0.0	32.250 18.434 50.684	14.671 -0.446 0.292			Vel = 3.34	
69 to 70	0.0 148.51	4.26 120.0 0.0058	0.0 0.0 0.0	25.420 0.0 25.420	14.517 0.230 0.147			Vel = 3.34	
70 to TOR2	0.0 148.51	4.26 120.0 0.0058	2I 18.434 J 21.067 0.0	28.260 39.501 67.761	14.894 0.056 0.391			Vel = 3.34	
TOR2 to HDR1	0.0 148.51	4.26 120.0 0.0058	B 15.8 S 28.968 0.0	20.000 44.768 64.768	15.341 9.831 0.374			Vel = 3.34	
HDR1 to BFP	50.00 198.51	4.26 120.0 0.0098	I 9.217 G 2.633 0.0	2.000 11.850 13.850	25.546 2.166 0.136			Qa = 50.00 Vel = 4.47	
BFP to BASE	0.0 198.51	4.26 120.0 0.0099	Zma 0.0 I 9.217 0.0	2.000 9.217 11.217	27.848 3.666 0.111			* Fixed Loss = 2.8 Vel = 4.47	

Final Calculations - Hazen-Williams

EASTERN FIRE
IMMUCELL

Page 6
Date 2/28/17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BASE	0.0	6.16	3I	43.037	200.000	31.625				
to		140.0	J	35.864	83.205	0.0				
TEST	198.51	0.0012	G	4.304	283.205	0.349			Vel = 2.14	
	400.00								Qa = 400.00	
	598.51					31.974			K Factor = 105.85	
90	24.72	2.157		0.0	8.750	10.713			K Factor @ node EQ01	
to		120.0		0.0	0.0	0.0				
91	24.72	0.0057		0.0	8.750	0.050			Vel = 2.17	
91	24.79	2.157	J	10.461	3.667	10.763			K Factor @ node EQ02	
to		120.0		0.0	10.461	0.0				
91A	49.51	0.0208		0.0	14.128	0.294			Vel = 4.35	
91A	0.0	2.635		0.0	9.917	11.057				
to		120.0		0.0	0.0	0.0				
86	49.51	0.0078		0.0	9.917	0.077			Vel = 2.91	
	0.0									
	49.51					11.134			K Factor = 14.84	
92	24.00	2.157		0.0	8.750	10.809			K Factor @ node EQ03	
to		120.0		0.0	0.0	0.0				
85	24.0	0.0054		0.0	8.750	0.047			Vel = 2.11	
	0.0									
	24.00					10.856			K Factor = 7.28	
93	25.45	2.157		0.0	8.750	11.347			K Factor @ node EQ01	
to		120.0		0.0	0.0	0.0				
94	25.45	0.0061		0.0	8.750	0.053			Vel = 2.23	
94	25.50	2.157	J	10.461	3.670	11.400			K Factor @ node EQ02	
to		120.0		0.0	10.461	0.0				
87	50.95	0.0219		0.0	14.131	0.310			Vel = 4.47	
	0.0									
	50.95					11.710			K Factor = 14.89	