

# City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: <i>F. 7695 Forest</i>		Owner: <i>Gildard, Barbara</i>		Phone: <i>6244</i>	Permit No: <i>910543</i>
Owner Address: <i>48 Bailey Ave</i>		Lessee/Buyer's Name:		Phone: <i>878-1588</i>	<div style="border: 2px solid black; padding: 5px; text-align: center;"> <b>PERMIT ISSUED</b>  <b>JUN - 5 1997</b>  <b>CITY OF PORTLAND</b> </div>
Contractor Name: <i>Owner</i>		Address:		BusinessName:	
Past Use: <i>1-lam</i>		Proposed Use: <i>Same</i>		<b>COST OF WORK:</b> \$ <i>2,850.00</i> <b>PERMIT FEE:</b> \$ <i>35.00</i>	
		<b>FIRE DEPT.</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied Signature: _____ <b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b> Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		<b>INSPECTION:</b> Use Group: _____ Type: _____ Signature: _____ <b>Special Zone or Reviews:</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Proposed Project Description: <i>Construct Screened in porch (10 x 24)</i>					
Permit Taken By: <i>Mary Gresik</i>		Date Applied For: <i>28 May 1997</i>			

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

**PERMIT ISSUED  
WITH REQUIREMENTS**

## CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT *Sherry Gildard* ADDRESS: \_\_\_\_\_ DATE: *28 May 1997* PHONE: \_\_\_\_\_

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE \_\_\_\_\_ PHONE: \_\_\_\_\_

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT



# COMMENTS

6/10/97 Owner called & left # - N/A @ Home or work - left message @ Both - have not rec'd foundation plan as required per condition of permit yet @

6/10/97 Visited Site - Some tubes in & backfilled - no body at premises - no way to determine depth -

5 front tubes 6' o/c 2E side 50" o/c - Seaboard ok @

8" tubes used I/P/O 10" as required as per condition of permit @

6/12/97 Spoke w/owner on phone - I explained the probability of sagging (8" tubes) & front heaves (no footings) - owner choose to proceed "as is" -

No C of O Can be issued on this job @ 6/12/97

3-11-98 Not Done No Roof or Sides

Sherry Dillard

## Inspection Record

Type	Date
Foundation: _____	_____
Framing: _____	_____
Plumbing: _____	_____
Final: _____	_____
Other: _____	_____

# City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, TEL: 877-8716 FAX: 877-8716

Location of Construction: 48 Bailey Ave		Owner: Gildard, Barbara 1-800-440-6071, ext 244		Permit No: 970543
Owner Address: SAA Portland, ME 04103		Lessee/Buyer's Name:	Phone: 878-7588	<div style="border: 1px solid black; padding: 5px;"> <b>PERMIT ISSUED</b>  <b>JUN - 5 1997</b>  <b>CITY OF PORTLAND</b> </div>
Contractor Name: Owner		Address:		
Past Use: 1-fam		Proposed Use: Same	<b>COST OF WORK:</b> \$ 2,850.00 <b>PERMIT FEE:</b> \$ 35.00 <b>FIRE DEPT.</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied <b>INSPECTION:</b> Use Group R3 Type: 5K Signature: <i>Huffman</i> Signature: <i>Huffman</i>	
Proposed Project Description: Construct Screened in porch (10 x 24)		<b>PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)</b> Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied Signature: _____ Date: _____		Zone: 3 CBL: 332-6009 Zoning Approval: 2331036 <b>Special Zone or Reviews:</b> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm
Permit Taken By: Mary Gresik		Date Applied For: 28 May 1997		<b>Zoning Appeal</b> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

**PERMIT ISSUED  
WITH REQUIREMENTS**

## CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

*Sherry Gildard*  
SIGNATURE OF APPLICANT

Sherry Gildard

ADDRESS:

DATE:

28 May 1997

PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT

7

*K Carroll*

## BUILDING PERMIT REPORT

DATE: 4 June 97 ADDRESS: 48 Bailey Ave.  
REASON FOR PERMIT: To Construct a 10' x 24' Screened in porch  
BUILDING OWNER: Barbara Gildard  
CONTRACTOR: ↑  
PERMIT APPLICANT: Cheryl Gildard APPROVAL: \*1, \*2, \*7, \*9, \*20, \*28 **DENIED**


### CONDITION(S) OF APPROVAL

- X 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
- X 2. Before concrete for foundation is placed, approvals from the ~~Development Review Coordinator~~ and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Precaution must be taken to protect concrete from freezing.
4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) U.L. 103.
- X 7. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
8. Headroom in habitable space is a minimum of 7'6".
- X 9. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread, 7" maximum rise.
10. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
11. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
12. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
13. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's.
14. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
15. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
  - In the immediate vicinity of bedrooms
  - In all bedrooms
  - In each story within a dwelling unit, including basements


In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)




16. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
17. The Fire Alarm System shall be maintained to NFPA #72 Standard.
18. The Sprinkler System shall maintained to NFPA #13 Standard.
19. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023, & 1024. Of the City's building code. (The BOCA National Building Code/1996)
20. All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued or demolition permit is granted.
21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
23. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
24. Ventilation shall meet the requirements of Chapter 12 Sections 1210. of the City's Building Code.
25. All electrical and plumbing permits must be obtained by a Master Licensed holders of their trade.
26. Your plans did not show a foundation plan, please submit this plan before starting construction. a minimum of 10' Sono resting on a footing with anchor between the two - IF this is going to be heated it must have a minimum of a 4' Frost wall.
- 28.



  
P. Samuel Hoffses, Chief of Code Enforcement

cc: Lt. McDougall, PFD  
Marge Schmuckal



11.00  
60.13  
A 34





foundation  
detail





# SPECIAL SERVICES CUSTOMER AGREEMENT

Store 2401 PORTLAND  
245 RIVERSIDE STREET  
PORTLAND ME 04102  
Phone (207) 761-0600

Salesperson: LP Reviewer:

Page 1 of 2

VALIDATION	
Date	05/24/97 11:33 am
Transaction	2401 00020 65621
Order Total	\$1,155.75
Amount Paid	\$1,155.75

No. 8421

## CUSTOMER INFORMATION

Last Name	GILDARD	First Name	BARBARA
Phone-Home	(207) 878-7588	Phone-Work	
Address	48 BAILEY AVE		
	04103		
City	PORTLAND	State	ME
		Zip	04103-
Company		Reference	;

REF. #	SKU	QTY	UM	DESCRIPTION	TAX	PRICE EACH	EXTENSION
R01	162-787	22.00	EA	2X10 - 12 P.T. .40 CCA Y/P NO. 2	Y	\$13.94	\$306.68
R02	162-876	2.00	EA	4X6 - 12 P.T. .40 CCA Y/P NO. 2	Y	\$16.97	\$33.94
R03	162-841	13.00	EA	4X4 - 12 P.T. .40 CCA Y/P NO. 2	Y	\$11.40	\$148.20
R04	473-227	2.00	EA	2X8 - 12 P.T. .40 CCA Y/P NO. 2	Y	\$9.95	\$19.90
R05	161-756	17.00	EA	2X6 - 12 KD WW/SPF NO.2 BTR	Y	\$6.35	\$107.95
R06	640-565	48.00	EA	5/4X6 - 10 P.T..40 CCA Y/P PREM DECK	Y	\$6.75	\$324.00
R07	675-199	3.00	EA	2X4 - 8 NO.1 PRESSURE TREATED Y/P	Y	\$3.25	\$9.75
				675261			
R08	675-253	4.00	EA	2X4 - 10 NO.1 PRESSURE TREATED Y/P.40	Y	\$4.55	\$18.20
R09	462-144	36.00	EA	2X4 JOIST HANGER	Y	\$0.39	\$14.04
R10	196-290	2.00	BX	16D BRT COMMON NAIL 5 LB BX	Y	\$3.28	\$6.56
R11	593-876	2.00	BX	8D S/T STAINLESS PATIO NAIL 5 LB BX	Y	\$26.97	\$53.94
				3.			
V13	515-663	1.00		DELIVERY	N	\$50.00	\$50.00
						SUBTOTAL	\$1,093.16
						SALES TAX	\$62.59
						TOTAL	\$1,155.75
						AMOUNT PAID	\$1,155.75

SCREENING & FLOORING

1500.00

265.75

## DETAILED DESCRIPTION OF SERVICES

START OF DELIVERY NO. 008421V13				DELIVERY DATE: Not sched
515-663 DELIVERY				
MERCHANDISE TO BE DELIVERED:				
REF. #	SKU	QTY	UM	ITEM DESCRIPTION
R0100	162-787	22.00	EA	2X10 - 12 P.T. .40 CCA Y/P NO. 2
R0200	162-876	2.00	EA	4X6 - 12 P.T. .40 CCA Y/P NO. 2
R0300	162-841	13.00	EA	4X4 - 12 P.T. .40 CCA Y/P NO. 2
R0400	473-227	2.00	EA	2X8 - 12 P.T. .40 CCA Y/P NO. 2
R0500	161-756	17.00	EA	2X6 - 12 KD WW/SPF NO.2 BTR
R0600	640-565	48.00	EA	5/4X6 - 10 P.T..40 CCA Y/P PREM DECK
R0700	675-199	3.00	EA	2X4 - 8 NO.1 PRESSURE TREATED Y/P
R0800	675-253	4.00	EA	2X4 - 10 NO.1 PRESSURE TREATED Y/P.40

Customer Copy

No. 8421



# SPECIAL SERVICES CUSTOMER AGREEMENT

Store 2401 PORTLAND  
245 RIVERSIDE STREET  
PORTLAND ME 04102  
Phone (207) 761-0600

Salesperson: LP      Reviewer:

Page 2 of 2

VALIDATION	
Date	05/24/97 11:33 am
Transaction	2401 00020 65621
Order Total	\$1,155.75
Amount Paid	\$1,155.75

REF. #	SKU	QTY	UM	ITEM DESCRIPTION
R0900	462-144	36.00	EA	2X4 JOIST HANGER
R1000	196-290	2.00	BX	16D BRT COMMON NAIL 5 LB BX
R1100	593-876	2.00	BX	8D S/T STAINLESS PATIO NAIL 5 LB BX

## Special Instructions:

OFF 302, RIVERTON AREA. RIVERSIDE ST. TO 302, TAKE RIGHT,  
ACROSS FROM PAPAS PLACE.

## The Home Depot will deliver merchandise to:

GILDARD, BARBARA  
48 BAILEY AVE  
04103  
PORTLAND, ME 04103-  
CUMBERLAND

Sales Tax Rate 6.000%

END OF DELIVERY NO.

008421V13

## TERMS AND CONDITIONS

### DELIVERY TERMS

The Home Depot provides curb service delivery only and is not responsible for property damage beyond curbside delivery. If you, the customer, assist The Home Depot with any delivery, it will be at your own risk and you hereby release The Home Depot from any claims for loss or damage you may have by reason of your assisting with any delivery.

If you require additional delivery service, The Home Depot may assist you; however, any additional delivery service shall be your sole responsibility. The Home Depot is not responsible for any damage to property or injury to persons arising out of The Home Depot's assistance with additional delivery service, and in consideration of such assistance, you release The Home Depot from any claims for loss or damage you may have and shall indemnify and hold The Home Depot harmless from such claims by third parties.

By signing below, the Customer accepts the terms of this special services Customer Agreement

Customer Signature <b>X</b>	Date
--------------------------------	------

No. 8421

No. 8421

SVP020

GILDARD

8421

HOME DEPOT U.S.A., INC.  
CUSTOMER PICK-UP CONFIRMATION

PAGE: 1

STORE: 2401 PORTLAND

DATE: 05/24/97

TIME: 04:28 pm

----- CUSTOMER PICK-UP WILL-CALL NUMBER 008421W14

Customer : GILDARD, BARBARA

Company :



Phone : Home ( ) - Work ( ) - Ext

Site :

Reference :

REF #	SKU	ITEM DESCRIPTION	----- QUANTITY -----	
			PICKED UP	REMAINING
01 R01	162-787	2X10 -12 P.T. .40 CCA Y/P NO. 2	22.00	.00
/ R02	162-876	4X6 - 12 P.T. .40 CCA Y/P NO. 2	2.00	.00
R03	162-841	4X4 - 12 P.T. .40 CCA Y/P NO. 2	13.00	.00
R04	473-227	2X8 - 12 P.T. .40 CCA Y/P NO. 2	2.00	.00
✓ R05	161-756	2X6 -12 KD WW/SPF NO.2 BTR	17.00	.00
R06	640-565	5/4X6 - 10 P.T..40 CCA Y/P PREM DECK	48.00	.00
✓ R07	675-199	2X4 - 8 NO.1 PRESSURE TREATED Y/P	3.00	.00
✓ R08	675-253	2X4 -10 NO.1 PRESSURE TREATED Y/P.40	4.00	.00
R09	462-144	2X4 JOIST HANGER	36.00	.00
R10	196-290	16D BRT COMMON NAIL 5 LB BX	2.00	.00
R11	593-876	8D S/T STAINLESS PATIO NAIL 5 LB BX	2.00	.00

Balance Due : \$0.00

I HEREBY ACKNOWLEDGE RECEIPT OF THE ABOVE  
ITEMS IN THE QUANTITIES SHOWN IN THE  
"PICKED-UP" COLUMN ABOVE:  
SPECIAL SERVICES EMPLOYEE'S SIGNATURE  
FRONT END SUPERVISOR'S SIGNATURE

----- END OF CUSTOMER PICK-UP WILL-CALL NUMBER 008421W14

CUSTOMER COPY

24x10' screened deck - no electricity

materials to date: 1356.34

(see attached)

screening: roof (fiberglass) 1000.00

2356.34

labor (family) no charge 0.00

2356.34

Barbara A. Gilson

7/24/97  
0588\$  
payt  
has  
paid

169 ent 0081

THE HOME DEPOT 2401  
245 RIVERSIDE ST  
PORTLAND, ME 04102 (207)761-0600

2401 00007 89305 05/26/97  
SALE 404 11:13 AM

084298008397 HAMMER HLD	3.98
076670011530 3PC BR SET	4.94
076670011530 3PC BR SET	4.94
082474084014 EXT STAIN	15.61
082474084014 EXT STAIN	15.61
082474084014 EXT STAIN	15.61
082474084014 EXT STAIN	15.61
SUBTOTAL	76.30
TAX ME 6.00%	4.58
TOTAL	\$80.88
CHECK	80.88

45879029  
DL# ME5412015  
AUTH CODE 189608

ORIGINAL RECEIPT REQUIRED FOR REFUND  
THANK YOU FOR SHOPPING AT THE HOME DEPOT  
WAREHOUSE PRICES - DAY IN, DAY OUT.

THE HOME DEPOT 2401  
245 RIVERSIDE ST  
PORTLAND, ME 04102 (207)761-0600

2401 00012 56643 05/24/97  
SALE 194 11:12 AM

030192001257 FT. THINNER	1.97
082474084014 EXT STAIN	15.61
720434906203 TARP	5.79
084298000065 CVS APRON	1.27
084298000065 CVS APRON	1.27
084298000065 CVS APRON	1.27
084298000065 CVS APRON	1.27
076670011530 3PC BR SET	4.94
076670011530 3PC BR SET	4.94
929514 60LB. CONC	
8.000 @ \$1.98	15.84
SUBTOTAL	54.17
TAX ME 6.00%	3.26
TOTAL	\$57.43
CASH	60.00
CHANGE DUE	2.57

ORIGINAL RECEIPT REQUIRED FOR REFUND  
THANK YOU FOR SHOPPING AT THE HOME DEPOT  
WAREHOUSE PRICES - DAY IN, DAY OUT.

THE HOME DEPOT 2401  
245 RIVERSIDE ST  
PORTLAND, ME 04102 (207)761-0600

2401 00007 88497	05/25/97
SALE 137	01:12 PM
229514 60LB. CONC	
7.000 @ \$1.98	17.82
17.82 TAX ME 6.00%	1.07
TOTAL	\$18.89
CASH	20.00
CHANGE DUE	1.11

ORIGINAL RECEIPT REQUIRED FOR REFUND  
THANK YOU FOR SHOPPING AT THE HOME DEPOT  
WAREHOUSE PRICES - DAY IN, DAY OUT

THE HOME DEPOT 2401  
245 RIVERSIDE ST  
PORTLAND, ME 04102 (207)761-0600

2401 00012 57229	05/24/97
SALE 194	02:10 PM
039645692219 QUIK-TUBE	
7.000 @ \$4.15	29.05
039645110164 60LB. CONC	
6.000 @ \$1.98	11.88
SUBTOTAL	40.93
40.93 TAX ME 6.00%	2.46
TOTAL	\$43.39
CASH	43.39

ORIGINAL RECEIPT REQUIRED FOR REFUND  
THANK YOU FOR SHOPPING AT THE HOME DEPOT  
WAREHOUSE PRICES - DAY IN, DAY OUT

Applicant: Sherry Gildard

Date: 6/4/97

Address: 40 Bailey Ave

C-B-L: 332-G-9 & 10

**CHECK-LIST AGAINST ZONING ORDINANCE**

Date - 4/8/97 1916

Zone Location - R-3

Interior or corner lot -

Back of 19-21 Timbell

Proposed Use/Work -

construct screened in porch 10' x 24'

Sewage Disposal -

Lot Street Frontage -

Front Yard -

Rear Yard -

25' req - 80' + shown

Side Yard -

8' req - 15' shown on closest side

Projections -

Width of Lot -

Height -

Lot Area -

13,600<sup>sq</sup>

Lot Coverage/ Impervious Surface -

25% - JH

Area per Family -

Off-street Parking -

Loading Bays -

Site Plan -

Shoreland Zoning/ Stream Protection -

Flood Plains -



228	229	230	231	232
357	358	359	360	361
44	43	42	41	40
2800	2100	2100	2100	2100
40	30			

DEPT. OF BUILDING INSPECTION  
CITY OF PORTLAND, ME  
MAY 28 1997  
RECEIVED  
320

The map shows a rectangular tract divided into 21 numbered sections. The dimensions and area calculations for each section are as follows:

Section	Dimensions	Area
1	30.73' x 33.80'	1046.00
2	30.11' x 31.81'	1049.35
3	30.73' x 29.81'	96.05
4	30.11' x 27.81'	83.40
5	40.92' x 33.99'	80.54
6	2400' x 30'	72000
7	2400' x 30'	72000
8	2400' x 30'	72000
9	2400' x 30'	72000
10	2400' x 30'	72000
11	2400' x 30'	72000
12	2400' x 30'	72000
13	2400' x 30'	72000
14	2400' x 30'	72000
15	2400' x 30'	72000
16	2400' x 30'	72000
17	2400' x 30'	72000
18	2400' x 30'	72000
19	2400' x 30'	72000
20	2400' x 30'	72000
21	2400' x 40'	96000

A large 'G' is marked in section 29. The map also includes a scale bar and a north arrow.

Hand-drawn map of a 6x2 grid of land parcels. The parcels are numbered 1 through 12. The map includes dimensions for each parcel and a scale bar at the bottom. A north arrow is located in the top right corner.

Parcel Number	Width (Top)	Depth (Right)
1	3200	40
2	2400	43
3	2400	42
4	2400	41
5	2100	40
6	2400	39
7	3200	41
8	2400	44
9	2400	45
10	2400	46
11	2100	47
12	2400	48

Scale bar: 40, 30, 20, 10

North arrow: [Symbol]

## DOVER

[illegible]

SHEET 337-D