

ELECTRICAL PERMIT

City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical code and the following specification:

LOCATION: 125 Beverly St

Date 23 May 1996

Permit # 4229

OWNER Custom Built Homes of Maine

ADDRESS _____

						TOTAL EACH FEE			
OUTLETS		Receptacles	25	Switches	20	Smoke Detector	5	50	.20
FIXTURES		(number of)							10.00
		incandescent		fluorescent				12	.20
		fluorescent strip							2.40
SERVICES									.20
		Overhead				TTL AMPSTO	800		15.00
		Underground					800	100	15.00
TEMPORARY SERV.									15.00
		Overhead				AMPS OVER	800		25.00
		Underground					800		25.00
METERS		(number of)						1	1.00
MOTORS		(number of)							2.00
RESID/COM		Electric units							1.00
HEATING		oil/gas units							5.00
APPLIANCES		Ranges	1	Cook Tops		Wall Ovens			2.00
		Water heaters		Fans	1	Dryers	1		2.00
Disposals	1	Dishwasher	1	Compactors		Others (denote)			2.00
MISC. (number of)		Air Cond/win							10.00
		Air Cond/cent							3.00
		Signs							10.00
		Pools							5.00
		Alarms/res							10.00
		Alarms/com							5.00
		Heavy Duty							15.00
		Outlets							2.00
		Circus/Carnv							25.00
		Alterations							5.00
		Fire Repairs							15.00
		E Lights							1.00
		E Generators							20.00
		Panels							4.00
TRANSFORMER		0-25 Kva							5.00
		25-200 Kva							8.00
		Over 200 Kva							10.00
						TOTAL AMOUNT DUE			
						MINIMUM FEE			
						25.00			
						38.40			

INSPECTION:

Will be ready 5/24 AM Service

or will call _____

CONTRACTORS NAME Jeff Hight

ADDRESS 17 Racine Ave

TELEPHONE 797-9693

MASTER LICENSE No. 4229

LIMITED LICENSE No. _____

SIGNATURE OF CONTRACTOR

Jeff Hight

333-K-003

ELECTRICAL INSTALLATIONS—

INSPECTION: Service 5/28/96 by [Signature]
 Service called in 1 5/28/96
 Closing-in 6/3/96 by [Signature]

Permit Number 4229
 Location 125 Bevelly St,
 Owner Custom Built Homes
 Date of Permit 5/23/96
 Final Inspection 7/1/96
 By Inspector [Signature]

PROGRESS INSPECTIONS: 5/28/96 (SERVICE)
6/3/96 (ROUGH-IN)
7/9/96 (Final)

DATE:	REMARKS:
<u>5/28/96</u>	<u>600V red wire needs to be protected by</u> <u>running up inside PVC conduit to meter</u> <u>(Not OK)</u>
<u>6/3/96</u>	<u>All OK (ROUGH-IN)</u>
<u>7/9/96</u>	<u>Bond around meter</u> <u>3-way from bulk head to stairs (not done)</u>

INSPECTION: Will be ready by 7/1/96
 CONTRACTOR'S NAME [Signature]
 ADDRESS [Signature]
 TELEPHONE [Signature]
 MASTER LICENSE NO. [Signature]
 LIMITED LICENSE NO. [Signature]