

8/12/02 for Setbacks - 13' Min Req on Right
to Close to Call - Contractor to install Trought line
Pin to Pin & do Pasatru ID on O/S Foundation
Wall & Call for Re-Inspect before Pour

8/20/02 AM Forms in place 13'.25" to Closest Point ^(K)
OK to Pour (D)

10/18/02 OK for electric, framing, plumbing
OK

12-12-02 final insp. done
OK to Close
am