



Douglas Morin <drm@portlandmaine.gov>

11 Buca Run Portland

ashotelectric@yahoo.com <ashotelectric@yahoo.com>
To: drm@portlandmaine.gov

Mon, Apr 3, 2017 at 6:25 PM

Hi Doug

This is what A & A ELECTRIC LLC. has done at 11 Buca Run Portland ME. After the owner Sinisa Bukarac wired his own basement we went in and replaced all of the receptacles with the tamper resistant receptacles. We also replaced all of the necessary regular breakers with arc fault breakers. We have checked all of the switches to make sure all of the wiring was done right. We have supported all of the recessed lights to the grid and to the floor joist. We covered up the three junction boxes and replaced all of the smoke detectors in the house and added one smoke/carbon monoxide detector on every level.

Ashot Sarkisov
A & A ELECTRIC LLC.
135 Braintree St.
Portland ME
207-415-7332

Sent from my iPad