

# ELECTRICAL PERMIT

## City of Portland, Me.

*3/26 Monday 11:30 AM PM.*



To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical Code and the following specifications:

Date 4/9/99  
 Permit # MC 13294  
 CBL# 336-E-066

**SITE LOCATION:** 21 Buca Run Portland, ME

**OWNER** Melissa Plante **TENANT** 3 Belfort Apt. 2 Portland, ME

								TOTAL EACH FEE		
<b>OUTLETS</b>	Receptacles	52	Switches	24	Smoke Detectors	6	82	.20	16.40	
<b>FIXTURES</b>	incandescent	18	fluorescent		Strips		18	.20	3.60	
					Fluorescent Strip	4			.80	
<b>SERVICES</b>	Overhead		Underground	x	TTL AMPS	<800	1	15.00	15.00	
	Overhead		Underground			>800		25.00		
<b>Temporary Service</b>	Overhead		Underground		TTL AMPS			25.00		
								25.00		
<b>METERS</b>	(number of)	1					1	1.00	1.00	
<b>MOTORS</b>	(number of)							2.00		
<b>RESID/COM</b>	Electric units							1.00		
<b>HEATING</b>	oil/gas units	1	Interior		Exterior			5.00	5.00	
<b>APPLIANCES</b>	Ranges	1	Cook Tops		Wall Ovens			2.00	2.00	
	Insta-Hot		Water heaters		Fans			2.00		
	Dryers	1	Disposals	1	Dishwasher		2	2.00	4.00	
	Compactors	1	Spa		Washing Machine		1	2.00	2.00	
	Others (denote)							2.00		
<b>MISC. (number of)</b>	Air Cond/win							3.00		
	Air Cond/cent				Pools			10.00		
	HVAC		EMS		Thermostat	2		5.00	10.00	
	Signs							10.00		
	Alarms/res							5.00		
	Alarms/com							15.00		
	Heavy Duty(CRKT)							2.00		
	Circus/Carnv							25.00		
	Alterations							5.00		
	Fire Repairs							15.00		
	E Lights							1.00		
	E Generators							20.00		
<b>PANELS</b>	Service	1	Remote		Main		1	4.00	4.00	
<b>TRANSFORMER</b>	0-25 Kva							5.00		
	25-200 Kva							8.00		
	Over 200 Kva							10.00		
								<b>TOTAL AMOUNT DUE</b>		63.80
								<b>MINIMUM FEE/COMMERCIAL 35.00</b>		
								<b>MINIMUM FEE</b>		25.00

**INSPECTION:** Will be ready \_\_\_\_\_ or will call \_\_\_\_\_  
 D/B/A Target Electric

**CONTRACTORS NAME** George W. Phelps  
**ADDRESS** P.O. Box 335 Gardiner, ME 04345  
**TELEPHONE** 582-1987

**MASTER LIC. #** MC 60013294  
**LIMITED LIC. #** \_\_\_\_\_

**SIGNATURE OF CONTRACTOR** *[Signature]*

ELECTRICAL INSTALLATIONS

Permit Number \_\_\_\_\_

Location \_\_\_\_\_

Owner \_\_\_\_\_

Date of Permit \_\_\_\_\_

Final Inspection 04/14/11

By Inspector MB

INSPECTION: Service \_\_\_\_\_ by \_\_\_\_\_

Service called in \_\_\_\_\_

Closing-in 26/APR/98 by [Signature]

PROGRESS INSPECTIONS: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
\_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

DATE:	REMARKS:
<u>26/APR/11</u>	<u>Smoke detectors To Far down on walls</u>
	<u>IF ACCESS TO ATTIC IS required needs light in</u>
	<u>attic - Called Mike and told him -</u>
	<u>S</u>