Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 09/09/16

FRAMING DETAIL

2x8 FLOOR JOIST 16" o/c
2x8 SOLID BRIDGING

(2) 2x10 GIRDER w/ 1/2" EXT. PLYWOOD FLITCH

MAIN GIRDER 8'0" o/c SPAN

GIRDER SPAN 5'0" o/c

GIRDER (2) 2x10 w/ 1/2" EXT. PLYWOOD FLITCH

1/4" = 1'0"
SCALE