

Inspection Services  
Michael J. Nugent  
Manager

Department of Urban Development  
Joseph E. Gray, Jr.  
Director



## CITY OF PORTLAND

July 28, 1999

Amy Strum  
Albert Cecere  
36 Newton St  
Portland ME 04103

RE: 36 Newton St  
CBL: 337-C-054

Dear Ms. Strum & Mr. Cecere:

It was recently noted that your swimming pool was not installed in accordance with Section 421.0 of the 1996 BOCA Code as stipulated in your permit issued May 26, 1999.

The deck around your pool was not built according to plan. The balusters were horizontal so as to create a ladder affect. The gate did not meet height requirements.

I will be glad to meet with you on site to fully explain these requirements.

Please note the failure to contact this office within 10 days will result in legal action being taken.

Sincerely,

Arthur Rowe  
Code Enforcement Officer

/sap