

**Marge Schmuckal - Permit application for 122 Lynn Street**

---

**From:** Marge Schmuckal  
**To:** easternshore@maine.rr.com  
**Date:** 7/23/2013 9:32 AM  
**Subject:** Permit application for 122 Lynn Street

2013-01550 337-C-083

Hi Scott,

I am in receipt of your permit application to add an 8' x 15' sun room on the single family dwelling at 122 Lynn Street. I will need a more accurate plot plan. The setbacks that you have given can not be accurate. For side setbacks you have given 49' + 36' (house length) + 8'(deck width) + 18' which adds up to 111'. The lot is only 75' wide, so these figures can not be correct. Please recheck your figures and resubmit an accurate, revised drawing.

Your permit will be on hold until such time I can determine that the Land Use Zoning Ordinance requirements are being met.

Thank you,  
Marge Schmuckal  
Zoning Administrator