Maine State Security Services

A Division of L'Heureux Inc.

1308 New County RD Dayton, ME 04005
Tel: 207-247-4371
Fax: 207-929-8484
Email: info@mainestatesecurity.com

CITY OF PORTLAND, MAINE · RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/20/18

Janurary 23, 2018

Portland Fire Prevention
380 Congress Street
Portland, Me 04101

Re: 1519 Forest Ave

Scope of work: We intend to install a Fire Alarm System for the building, This is a 2 story residential building that was converted into a residential boarding care facility, We plan on installing the fire alarm per NFPA 101 Ch 32, there will be pull stations and all exit doors, horn strobes in common area, strobes in the bathrooms and mini horns in the bedrooms, The fire panel will be in the basement with a smoke detector covering it, there will be an annunciatior at the front main entry, and a Knox Box outside that door. The alarm system will be all hard wired devices all UL listed for commercial fire. Communication to the UL listed Remote Station will be accomplished by using a commercial Fire Alarm Cellular (GSM) Communicator.

Please feel free to give me a call after reviewing the submittals if you have any questions.

Sincerely,

Chris L'Heureux