Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/20/18

NOTES:

1.) INSTALL (1) COMBINATION (PHOTOELECTRIC) SMOKE / CO DETECTOR ON EACH FLOOR

2.) INSTALL (PHOTOELECTRIC) SMOKE DETECTOR IN EACH BEDROOM

REGISTERED ARCHITECT
RYAN J. SENATORE
No. 3352
STATE OF MAINE

© 2017 RYAN SENATORE ARCHITECTURE

RENOVATIONS TO
1519 FOREST AVENUE
PORTLAND, MAINE

RSA
RYAN SENATORE ARCHITECTURE
MAIN STREET
PORTLAND, MAINE 04101
207-828-0414
www.rsarchitecture

CONSULTANTS:

REVISIONS:
1 - REVISED - 12/21/17

DATE: DECEMBER 8, 2017
PROJECT NO: 1793
DRAWN BY: RJS, JPP
CHECKED BY: RJS
SCALE: AS NOTED

SHEET TITLE:
FIRST FLOOR PLAN

A1-1

FA2 1ST FLOOR