Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/20/18

Notes:

(1) Smoke Alarms as per code

(2) Hearing Impared bedrooms require 177 cd horn/strobes

(3) Smoke Detector over Fire Alarm Panel

(4) Knox Box

RECORDED ARCHITECT RYAN J. SENATORE No. 3334 STATE OF MAINE

© 2017 RYAN SENATORE ARCHITECTURE

RENOVATIONS TO
1519 FOREST AVENUE
PORTLAND, MAINE

RSA
RYAN SENATORE ARCHITECTURE
866 CONGRESS STREET
PORTLAND, MAINE 04101
207-865-9114
www.ryansenatore.com

CONSULTANTS

REVISIONS
△ - REVISED - 12/8/17

DATE: DECEMBER 8, 2017
PROJECT No: 1783
DRAWN BY: RJS, JPF
CHECKED BY: RJS
SCALE: AS NOTED

SHEET TITLE:
SECOND FLOOR PLAN

A1-2

FA 3 2nd Floor.