Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 02/20/18

NOTES:

1.) INSTALL (1) COMBINATION (PHOTOELECTRIC) SMOKE / CO DETECTOR ON EACH FLOOR

2.) INSTALL (PHOTOELECTRIC) SMOKE DETECTOR IN EACH BEDROOM

Pull
horn/strobe
horn
strobe
S smoke
RA - Annunciator
KB - Key Box

1 BASEMENT PLAN

REGISTERED ARCHITECT RYAN J. SENATORE No. 3035 STATE OF MAINE

© 2017 RYAN SENATORE ARCHITECTURE

RENOVATIONS TO
1519 FOREST AVENUE
PORTLAND, MAINE

RSA

RYAN SENATORE ARCHITECTURE
446 CONGRESS STREET
PORTLAND, MAINE 04101
207-956-0612
www.ryansenatorearchitecture.com

CONSULTANTS:

REVISIONS

DATE	DECEMBER 8, 2017
PROJECT No	1719
DRAWN BY:	RJS, JPP
CHECKED BY	RJS
SCALE:	AS NOTED

SHEET TITLE:
BASEMENT PLAN

A1-0

FA1 Basement