



# CITY OF PORTLAND

DEPARTMENT OF PLANNING & URBAN DEVELOPMENT  
INSPECTION SERVICES DIVISION

June 5, 1984

Mr. Steven L. Morgan  
12 Range Street  
Portland, Maine 04103

Re: Lots 127-8, 129, 130 and part of 131 Harris Avenue

Dear Sir:

Your application to construct a single family dwelling 28' X 36' with a 24' X 28' attached garage has been reviewed and a building permit is herewith issued subject to the following requirements:

1. The 8" foundation wall must be at least 10"
2. Private garages attached to dwellings shall be completely separated from the dwellings and their attic area by means of one-half inch gypsum board or equivalent applied to the garage side.

If you have any questions concerning these requirements, please contact this office.

Sincerely,

  
Samuel Hoffses  
Chief of Inspection Services

PSH/mwp