



. . . Fire Protection by Computer Design

Sprinkler Systems Inc.
2-4 Avon Street
P O Box 1285
Lewiston, Maine 04240
207-782-0104

Job Name : 137 NEWTON STREET
Building :
Location : 137 NEWTON STREET, PORTLAND, MAINE 04102
System : 1 OF 1
Contract : 13094
Data File : 13094137NEWTONSTPTLDA2.WXF

Hydraulic Design Information Sheet

Name - GOODWILL GROUP HOME Date - 11-15-2013
 Location - 137 NEWTON STREET, PORTLAND, MAINE 04102
 Building - System No. - 1 OF 1
 Contractor - OWNER Contract No. - 13094
 Calculated By - SCOTT E. GARLAND Drawing No. - 1 OF 1
 Construction: (X) Combustible () Non-Combustible Ceiling Height - 7-2
 Occupancy - BASEMENT - ORDINARY HAZARD GROUP 2

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. (X) 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

E

M	Area of Sprinkler Operation - 900 SF	System Type	Sprinkler/Nozzle
	Density - .15	(X) Wet	Make RELIABLE
D	Area Per Sprinkler - 127.932	() Dry	Model F1FR56
E	Elevation at Highest Outlet - 74.5	() Deluge	Size 1/2 X 1/2
S	Hose Allowance - Inside -	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance -	() Other	Temp.Rat.155 DEG
G	Hose Allowance - Outside - 250		

N

Note DESIGN AREA #2 - BASEMENT

Calculation Flow Required - 185.803 Press Required - 42.757 AT BASE OF RISER
 Summary C-Factor Used: 120 Overhead 150 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 9-8-2011		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 68	@ Press -	
R	Residual Press - 66	Elev. -	Well
	Flow - 1087		Proof Flow
S	Elevation - 105.0		

U

P Location - ON FOREST AVENUE NEAR FARNHAM STREET, APPROX 2500'AWAY

P

L Source of Information - PORTLAND WATER DISTRICT

Y

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	% Palletized	% Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row	() Open Shelf	

O

R	K	Flue Spacing	Clearance:Storage to Ceiling
A		Longitudinal	Transverse

G

E Horizontal Barriers Provided:

Pressure / Flow Summary - STANDARD

Sprinkler Systems Inc.
137 NEWTON STREET

Page 10
Date 11-15-2013

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
11	74.5	5.6	10.92	na	18.51	0.15	116.087	9.669
12	74.5	5.6	12.07	na	19.45	0.15	116.087	9.669
13	74.5	5.6	13.19	na	20.34	0.15	116.087	9.669
14	74.5	5.6	14.41	na	21.26	0.15	98.775	7.0
15	74.5	5.6	14.9	na	21.62	0.15	98.775	7.0
16	74.5	5.6	11.74	na	19.19	0.15	127.932	11.743
M	74.5		12.76	na				
17	74.5	5.6	12.81	na	20.05	0.15	127.932	11.743
F	74.5		13.93	na				
18	74.5	5.6	14.02	na	20.97	0.15	127.932	11.743
19	74.5	5.6	19.02	na	24.42	0.15	127.932	11.743
HH	74.5		15.67	na				
H	74.5		15.89	na				
J	74.5		16.44	na				
G	74.5		16.65	na				
K	74.5		19.52	na				
RT	74.5		22.15	na				
TV	71.042		27.67	na				
RB	69.042		42.76	na				
X1	70.0		65.92	na	250.0			
X2	110.0		52.6	na				
X3	110.0		52.68	na				
X4	105.0		54.87	na				
TEST	105.0		54.94	na				

The maximum velocity is 19.78 and it occurs in the pipe between nodes RB and X1

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
137 NEWTON STREET

Page 11
Date 11-15-2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
11 to 12	18.51	1.049 120.0		0.0 0.0	10.167 0.0	10.923 0.0			K Factor = 5.60	
12 to 13	18.51	0.1127		0.0	10.167	1.146			Vel = 6.87	
12 to 13	19.45	1.380 120.0		0.0 0.0	10.000 0.0	12.069 0.0			K Factor = 5.60	
13 to HH	37.96	0.1120		0.0	10.000	1.120			Vel = 8.14	
13 to HH	20.34	1.380 120.0	1T	6.0 0.0	4.000 6.000	13.189 0.0			K Factor = 5.60	
	58.3	0.2477		0.0	10.000	2.477			Vel = 12.51	
	0.0 58.30					15.666			K Factor = 14.73	
14 to H	21.26	1.049 120.0	1T	5.0 0.0	5.209 5.000	14.406 0.0			K Factor = 5.60	
	21.26	0.1457		0.0	10.209	1.487			Vel = 7.89	
	0.0 21.26					15.893			K Factor = 5.33	
15 to J	21.62	1.049 120.0	1T	5.0 0.0	5.209 5.000	14.902 0.0			K Factor = 5.60	
	21.62	0.1503		0.0	10.209	1.534			Vel = 8.03	
	0.0 21.62					16.436			K Factor = 5.33	
16 to M	19.19	1.049 120.0		0.0 0.0	8.417 0.0	11.743 0.0			K Factor = 5.60	
M to 17	19.19	0.1206		0.0	8.417	1.015			Vel = 7.12	
M to 17	0.0	1.380 120.0		0.0 0.0	1.750 0.0	12.758 0.0				
17 to F	19.19	0.0314		0.0	1.750	0.055			Vel = 4.12	
17 to F	20.05	1.380 120.0		0.0 0.0	9.375 0.0	12.813 0.0			K Factor = 5.60	
F to 18	39.24	0.1190		0.0	9.375	1.116			Vel = 8.42	
F to 18	0.0	1.380 120.0		0.0 0.0	0.792 0.0	13.929 0.0				
18 to G	39.24	0.1199		0.0	0.792	0.095			Vel = 8.42	
18 to G	20.97	1.380 120.0	1T	6.0 0.0	4.000 6.000	14.024 0.0			K Factor = 5.60	
	60.21	0.2629		0.0	10.000	2.629			Vel = 12.92	
	0.0 60.21					16.653			K Factor = 14.75	
19 to K	24.42	1.380 120.0	1T	6.0 0.0	4.000 6.000	19.023 0.0			K Factor = 5.60	
	24.42	0.0495		0.0	10.000	0.495			Vel = 5.24	
	0.0 24.42					19.518			K Factor = 5.53	
HH to H	58.30	1.380 120.0		0.0 0.0	0.917 0.0	15.666 0.0				
H to J	58.3	0.2475		0.0	0.917	0.227			Vel = 12.51	
H to J	21.25	2.067 120.0		0.0 0.0	8.833 0.0	15.893 0.0				
	79.55	0.0615		0.0	8.833	0.543			Vel = 7.61	

Final Calculations - Hazen-Williams

Sprinkler Systems Inc.
137 NEWTON STREET

Page 12
Date 11-15-2013

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
J	21.62	2.067		0.0	2.250	16.436				
to		120.0		0.0	0.0	0.0				
G	101.17	0.0964		0.0	2.250	0.217		Vel = 9.67		
G	60.21	2.067		0.0	12.583	16.653				
to		120.0		0.0	0.0	0.0				
K	161.38	0.2277		0.0	12.583	2.865		Vel = 15.43		
K	24.42	2.067	1E	5.0	3.917	19.518				
to		120.0		0.0	5.000	0.0				
RT	185.8	0.2956		0.0	8.917	2.636		Vel = 17.76		
RT	0.0	2.067	1Fsp	0.0	3.458	22.154				
to		120.0		0.0	0.0	4.498		* Fixed loss = 3		
TV	185.8	0.2955		0.0	3.458	1.022		Vel = 17.76		
TV	0.0	2.067	1E	5.0	2.500	27.674				
to		120.0		0.0	5.000	12.866		* Fixed loss = 12		
RB	185.8	0.2956		0.0	7.500	2.217		Vel = 17.76		
RB	0.0	1.959	1G	1.164	80.000	42.757				
to		150.0	1T	11.635	12.799	-0.415				
X1	185.8	0.2540		0.0	92.799	23.575		Vel = 19.78		
X1	250.00	8.39	1G	3.641	1800.000	65.917		Qa = 250		
to		100.0	1T	31.863	35.504	-17.324				
X2	435.8	0.0022		0.0	1835.504	4.008		Vel = 2.53		
X2	0.0	16.6	1E	46.767	950.000	52.601				
to		100.0	1G	9.353	56.121	0.0				
X3	435.8	0.0001		0.0	1006.121	0.079		Vel = 0.65		
X3	0.0	12.46	1T	52.745	25.000	52.680				
to		100.0		0.0	52.745	2.166				
X4	435.8	0.0003		0.0	77.745	0.024		Vel = 1.15		
X4	0.0	12.24		0.0	200.000	54.870				
to		100.0		0.0	0.0	0.0				
TEST	435.8	0.0004		0.0	200.000	0.070		Vel = 1.19		
	0.0									
	435.80					54.940		K Factor = 58.80		

Water Supply Curve (C)

Sprinkler Systems Inc.
137 NEWTON STREET

Page 13
Date 11-15-2013

City Water Supply:
C1 - Static Pressure : 68
C2 - Residual Pressure: 66
C2 - Residual Flow : 1087

Demand:
D1 - Elevation : -13.210
D2 - System Flow : 185.803
D2 - System Pressure : 54.940
Hose (Adj City) : _____
Hose (Demand) : 250
D3 - System Demand : 435.803
Safety Margin : 12.692

