

30 DAYTON STALL
off H. A. 10

227-11-10



Full cut #920R - Half cut #920R - Third cut #920R - Fifth cut #920R



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Dec. 20, 19 77
Receipt and Permit number A-03589

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 30 Dayton St.

OWNER'S NAME: Clifford Welch ADDRESS: same

OUTLETS: (number of) Clifford 777-7991

Lights	_____	FEES
Receptacles	_____	
Switches	_____	
Plugmold	_____ (number of feet)	
TOTAL	_____	

FIXTURES: (number of)

Incandescent	_____
Fluorescent	_____ (Do not include strip fluorescent)
TOTAL	_____
Strip Fluorescent, in feet	_____

SERVICES:

Permanent, total amperes	_____
Temporary	_____

METERS: (number of) _____

MOTORS: (number of)

Fractional	_____
1 HP or over	_____

RESIDENTIAL HEATING:

Oil or Gas (number of units)	<u>X</u>	<u>3.00</u>
Electric (number of rooms)	_____	_____

COMMERCIAL OR INDUSTRIAL HEATING:

Oil or Gas (by a main boiler)	_____
Oil or Gas (by separate units)	_____
Electric (total number of kws)	_____

APPLIANCES: (number of)

Ranges	_____	Water Heaters	_____
Cook Tops	_____	Disposals	_____
Wall Ovens	_____	Dishwashers	_____
Dryers	_____	Compactors	_____
Fans	_____	Others (denote)	_____
TOTAL	_____		_____

MISCELLANEOUS: (number of)

Branch _____	
Trans _____	
Air Conditioners _____	
Signs _____	
Fire/Burglar Alarms _____	
Circus, Fairs, etc. _____	
Alterations to wires _____	
Repairs after fire _____	
Heavy Duty, 220v outlets _____	
Emergency Lights, battery _____	
Emergency Generators _____	

INSTALLATION FEE DUE: _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b) _____

FOR PERFORMING WORK WITHOUT A PERMIT (304-9) _____

TOTAL AMOUNT DUE: 3.00

INSPECTION:
Will be ready on 12-20, 19 77 or Will Call _____

CONTRACTOR'S NAME: Ballard Oil & Equipment Co.

ADDRESS: 135 Marginal Way

TEL.: 772-1991

MASTER LICENSE NO.: on file SIGNATURE OF CONTRACTOR: _____

LIMITED LICENSE NO.: _____

INSPECTOR'S COPY

A.P.- 30 Dayton St.

Jan. 13, 1966

Suburban Propane Gas Corp.
Thompson's Point

cc to: Arthur Girard
1348 Forest Avenue
cc to: Fire Department

Gentlemen:

Permit is being issued to install (1)-100 gallon propane gas storage tank at the above location with the provision that this installation meet fire department requirements as stated in N.F.P.A. pamphlet #58 that there be at least 5 feet distance between the tank and any door or window opening in the building.

Very truly yours,

Gerald L. Hayberry
Building Inspection Director

INTER-OFFICE CORRESPONDENCE

CITY OF PORTLAND, MAINE
FIRE DEPARTMENT


To: Mr. Gerald E. Myberry, Building Inspector Date: January 12, 1966


From: Haswell M. Bruns, District Chief

Subject: Permit to install (1)-100 gallon propane gas storage tank
outside above ground at 30 Dayton Street

N.F.P.A. Pamphlet 458 requires a 5 foot spacing on this
type of installation.

Haswell M. Bruns
Haswell M. Bruns
District Chief





REQUEST FOR PERMIT
OF
100 GAL BULK STORAGE TANK OF PROPANE GAS
AT
RESIDENCE OF CLIFFORD WELCH
30 MAYTON ST
PORTLAND, ME
OWNER
ARTHUR GIRARD
PORTLAND
INSTALLER
SUBURBAN PROPANE
THOMPSON'S POINT
PORTLAND, ME

