

---

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> DERRIG THOMAS A		<b>Inspector</b> Jon Rioux	<b>Inspection Date</b> 11/2/2007
<b>Locatation</b> 1445 FOREST AVE	<b>CBL</b> 340 D003001	<b>Status</b> Re-Inspect 30 Days	<b>Inspection Type</b> Complaint-Inspection

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-108.e	Exterior				
<b>Violation:</b>	Chimneys, flues and vent.				
<b>Notes:</b>	Repair the chimney so that it is structurally sound.				
	(e) Chimneys, flues and vent. Every chimney and every flue, vent, and smokepipe and any attachments thereto shall be structurally sound, in good repair, and safe to use.				

---

**Comments:**