

5/12/03 set back, some tubes OK

10/27/03 - Checked ht of Lech - is 14 1/2 - 15 inches
from grade - no handrails/guardrails needed.
Stairs OK - no problems seen. OK to

CBL # 340-J-6

permit # 03-0467

Close out

