

SnapNrack Series 100 Roof Mount System

COVER LETTER

The loading criteria used in this report is from ASCE 7-10. For codes that reference ASCE 7-05, Appendix A is provided to convert the wind speeds in ASCE 7-05 to the wind speeds used in this report. Instructions for this conversion are provided in Appendix A. This report covers wind speeds (V_{ult}) to 190 MPH, ground snow to 120 PSF, building heights to 60 feet, and tilt angles to 60 degrees.

The following codes are covered in this report:

- IBC 2015
- IBC 2012
- IBC 2009
- IBC 2006


The mounting system structural submittal package shall consist of the following:

- Pages 1-17 of the report (this includes this cover letter).
- Applicable page from the following:
 - C1 – C15 for 0 to 30 ft. Mean Roof Height and 6063 alloy rail
 - C17 – C32 for 31 to 60 ft. Mean Roof Height and 6063 alloy rail
 - C33 – C48 for 0 to 30 ft. Mean Roof Height and 6005 alloy rail
 - C49 – C64 for 31 to 60 ft. Mean Roof Height and 6005 alloy rail
- Appendix A (if applicable).
- The applicable installation details (listed on page 17 of this report).

This report provides structural engineering calculations and installation criteria for the mounting system only. It does not certify the capacity of the supporting members. The capacity of the supporting structure is to be certified by the licensed professional responsible for the building's structural certification.

Please contact SnapNrack at (877) 732-2860, or Contact@snapnrack.com, for questions regarding this report.

Norman Scheel, PE, SE
Fellow ASCE
Fellow SEAOC
LEED AP BD+C, LEED AP HOMES
E-mail: info@nsse.com



Series 100

Structural Report and Calculations

SnapNrack™
PV Mounting Systems

Structural Report and Calculations

Series 100 Roof Mount

For

SnapNrack
775 Fiero Lane, Suite 200
San Luis Obispo, CA 93401

Prepared By

Norman Scheel Structural Engineer
5022 Sunrise Boulevard
Fair Oaks, CA 95628
(916) 536-9585

July 6, 2016

Table of Contents

<i>Section</i>	<i>Page</i>
Cover Letter	1
Summary Report	2 to 17

Building Department Support Calculations

Calculations 0 to 30 ft. Mean Roof Height (6063 Rail)	C1 to C15
Wind Calculations	
Velocity Pressures & MFRS	C1
Component and Cladding	C3
Seismic Calculations	C7
Snow Loads	C8
Rail Properties	C9
65" PV Panel Connection to Rail	C10
78" PV Panel Connection to Rail	C11
Lag Bolt Connection to Roof	C12
Rail Span Chart Tilt Angle 0-19 degrees	C13
Rail Span Chart Tilt Angle 20-36 degrees	C14
Rail Span Chart Tilt Angle 37-45 degrees	C15
Rail Span Chart Tilt Angle 45-60 degrees	C16

Building Department Support Calculations

Calculations 31 to 60 ft. Mean Roof Height (6063 Rail)	C17 to C32
Wind Calculations	
Velocity Pressures & MFRS	C17
Component and Cladding	C19
Seismic Calculations	C23
Snow Loads	C24
Rail Properties	C25
65" PV Panel Connection to Rail	C26
78" PV Panel Connection to Rail	C27
Lag Bolt Connection to Roof	C28
Rail Span Chart Tilt Angle 0-19 degrees	C29
Rail Span Chart Tilt Angle 20-36 degrees	C30
Rail Span Chart Tilt Angle 37-45 degrees	C31
Rail Span Chart Tilt Angle 45-60 degrees	C32

Building Department Support Calculations

Calculations 0 to 30 ft. Mean Roof Height (6005 Rail)	C33 to C48
Wind Calculations	
Velocity Pressures & MFRS	C33
Component and Cladding	C35
Seismic Calculations	C39
Snow Loads	C40
Rail Properties	C41
65" PV Panel Connection to Rail	C42
78" PV Panel Connection to Rail	C43
Lag Bolt Connection to Roof	C44
Rail Span Chart Tilt Angle 0-19 degrees	C45
Rail Span Chart Tilt Angle 20-36 degrees	C46
Rail Span Chart Tilt Angle 37-45 degrees	C47
Rail Span Chart Tilt Angle 45-60 degrees	C48

Building Department Support Calculations

Calculations 31 to 60 ft. Mean Roof Height (6005 Rail)	C49 to C64
Wind Calculations	
Velocity Pressures & MFRS	C49
Component and Cladding	C51
Seismic Calculations	C55
Snow Loads	C56
Rail Properties	C57
65" PV Panel Connection to Rail	C58
78" PV Panel Connection to Rail	C59
Lag Bolt Connection to Roof	C60
Rail Span Chart Tilt Angle 0-19 degrees	C61
Rail Span Chart Tilt Angle 20-36 degrees	C62
Rail Span Chart Tilt Angle 37-45 degrees	C63
Rail Span Chart Tilt Angle 45-60 degrees	C64

Appendix: ASCE-2010 to 2005 Conversion Sheet	A1
--	----

Introduction

This report describes, illustrates, and explains the Structural Calculation Packet for SnapNrack's Series 100 Mounting System, dated 7/6/2016. The calculations have been performed in accordance with the codes referenced in the cover letter. The racking system has been designed to withstand code-prescribed forces due to its own weight, the weight of the solar panels, the snow loads, and both the wind and seismic forces.

Rail Spans

This report covers two different material options for the system rails. Although they are both aluminum, one rail option uses a 6063 alloy (25 ksi yield) and the other uses a 6005 alloy (35 ksi yield).

Despite having different yield strengths, both types of rails support the PV panels. As for the rails themselves, they are supported by mounting hardware which attaches them to the roof structure with spans that are expressed in inches. Refer to the tables below for rail spans under varying conditions of rail alloy and roof height. Shaded cells require an edge zone adjustment (see details following charts).

Notes for Tables 1A thru 2H

1. Determine the mean roof height, tilt angle, and rail alloy (if you are unsure, use the 6063 alloy values). For mean roof heights less than 30 feet, use Table 1A/2A for tilt angles less than 19 degrees, Table 1B/2B for tilt angles between 20 and 36 degrees, Table 1C/2C for tilt angles between 37 and 45 degrees, and Table 1D/2D for tilt angles between 46 and 60 degrees. For mean roof heights between 31 and 60 feet use Table 1E/2E for tilt angles less than 19 degrees, Table 1F/2F for tilt angles between 20 and 36 degrees, Table 1G/2G for tilt angles between 37 and 45 degrees, and Table 1H/2H for tilt angles between 46 and 60 degrees.
2. Determine the wind and snow load for the project site from the building department. Make certain to use 2015 IBC wind loads. Locate the wind load in the table across top rows and the snow load down the left columns to find corresponding maximum rail span.
3. For snow loads, column Pg equals the ground snow.
4. Shaded cells require application of an edge zone adjustment (details to follow).

6063 Alloy Rail Tables

0-30 ft. Roof Height

Table 1A: Rail Spans (in) for Roof Slopes and Tilt Angles 0° to 19° 6063 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-10.7	-11.7	-12.7	-13.8	-14.9	-16.1	-17.3	-18.6	-19.9	-21.2	-22.6	-25.5	-28.6	-31.9	
	0	0	116	110	104	99	95	91	87	83	80	77	75	70	65	62
	10	8	114	110	104	99	95	91	87	83	80	77	75	70	65	62
	20	15	89	89	89	89	89	89	87	83	80	77	75	70	65	62
	30	23	75	75	75	75	75	75	75	75	75	75	75	70	65	62
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	65	62
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43	
120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

0-30 ft. Roof Height

Table 1B: Rail Spans (in) for Roof Slopes and Tilt Angles 20° to 36° 6063 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-7.0	-7.6	-8.3	-9.0	-9.7	-10.5	-11.3	-12.1	-13.0	-13.8	-14.7	-16.6	-18.7	-20.8	
	0	0	120	120	120	120	120	118	112	108	103	99	95	89	83	78
	10	8	112	111	110	109	108	107	105	104	103	99	95	89	83	78
	20	15	89	89	89	89	89	89	88	88	87	87	86	85	83	78
	30	23	75	75	75	75	75	75	75	75	75	75	75	75	74	73
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43	
120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

0-30 ft. Roof Height

Table 1C: Rail Spans (in) for Roof Slopes and Tilt Angles 37° to 45° 6063 Alloy																
Wind Load																
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190	
q _h		15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
P _g	P _s	-6.7	-7.3	-7.9	-8.6	-9.3	-10.0	-10.8	-11.6	-12.4	-13.2	-14.1	-15.9	-17.8	-19.9	
Ground Snow Load (psf)	0	0	120	120	120	120	120	120	116	111	106	102	98	91	85	80
	10	8	112	111	110	109	108	107	105	104	103	102	98	91	85	80
	20	15	89	89	89	89	89	89	88	88	87	87	86	85	83	80
	30	23	75	75	75	75	75	75	75	75	75	75	75	75	74	73
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40

0-30 ft. Roof Height

Table 1D: Rail Spans (in) for Roof Slopes and Tilt Angles 46° to 60° 6063 Alloy																
Wind Load																
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190	
q _h		15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
P _g	P _s	-6.3	-6.9	-7.6	-8.2	-8.9	-9.6	-10.3	-11.0	-11.8	-12.6	-13.4	-15.2	-17.0	-18.9	
Ground Snow Load (psf)	0	0	120	120	120	120	118	115	113	110	107	105	101	94	88	82
	10	8	106	105	104	102	101	100	98	97	96	94	93	90	88	82
	20	15	89	88	87	87	86	85	84	83	82	82	81	79	77	76
	30	23	75	75	75	75	75	75	75	74	74	73	72	71	70	69
	40	31	66	66	66	66	66	66	66	66	66	66	66	65	64	63
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	59
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40

31-60 ft. Roof Height

Table 1E: Rail Spans (in) for Roof Slopes and Tilt Angles 0° to 19° 6063 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g P _s	-12.3	-13.5	-14.7	-15.9	-17.2	-18.6	-20.0	-21.4	-22.9	-24.5	-26.1	-29.4	-33.0	-36.7	
	0	0	106	101	96	91	87	83	80	77	74	71	69	64	61	57
	10	8	106	101	96	91	87	83	80	77	74	71	69	64	61	57
	20	15	89	89	89	89	87	83	80	77	74	71	69	64	61	57
	30	23	75	75	75	75	75	75	75	75	74	71	69	64	61	57
	40	31	66	66	66	66	66	66	66	66	66	66	66	64	61	57
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	57
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40

31-60 ft. Roof Height

Table 1F: Rail Spans (in) for Roof Slopes and Tilt Angles 20° to 36° 6063 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g P _s	-8.0	-8.8	-9.6	-10.4	-11.2	-12.1	-13.0	-14.0	-14.9	-16.0	-17.0	-19.2	-21.5	-24.0	
	0	0	120	120	120	119	113	108	103	99	95	91	88	82	77	72
	10	8	110	109	108	107	106	104	103	99	95	91	88	82	77	72
	20	15	89	89	89	89	89	88	87	86	86	85	84	82	77	72
	30	23	75	75	75	75	75	75	75	75	75	75	75	74	73	72
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40

31-60 ft. Roof Height

Table 1G: Rail Spans (in) for Roof Slopes and Tilt Angles 37° to 45° 6063 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190
	q _h		17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3
	P _g P _s		-7.7	-8.4	-9.1	-9.9	-10.7	-11.6	-12.4	-13.3	-14.3	-15.2	-16.2	-18.3	-20.6	-22.9
	0	0	120	120	120	120	116	111	106	101	97	93	90	84	79	74
	10	8	110	109	108	107	106	104	103	101	97	93	90	84	79	74
	20	15	89	89	89	89	89	88	87	86	86	85	84	83	79	74
	30	23	75	75	75	75	75	75	75	75	75	75	75	74	73	72
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

31-60 ft. Roof Height

Table 1H: Rail Spans (in) for Roof Slopes and Tilt Angles 46° to 60° 6063 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190
	q _h		17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3
	P _g P _s		-7.3	-8.0	-8.7	-9.5	-10.2	-11.0	-11.9	-12.7	-13.6	-14.5	-15.5	-17.5	-19.6	-21.8
	0	0	120	120	119	116	113	110	107	104	100	96	93	86	81	76
	10	8	104	103	101	100	98	97	96	94	93	91	90	86	81	76
	20	15	88	87	86	85	84	83	82	81	81	80	79	77	75	73
	30	23	75	75	75	75	75	74	73	73	72	72	71	70	68	67
	40	31	66	66	66	66	66	66	66	66	66	65	65	64	63	62
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	59	58
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	54
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

6005 Alloy Rail Tables

0-30 ft. Roof Height

Table 2A: Rail Spans (in) for Roof Slopes and Tilt Angles 0° to 19° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-10.7	-11.7	-12.7	-13.8	-14.9	-16.1	-17.3	-18.6	-19.9	-21.2	-22.6	-25.5	-28.6	-31.9	
	0	0	140	132	125	119	114	109	104	100	96	93	89	84	79	74
	10	8	137	132	125	119	114	109	104	100	96	93	89	84	79	74
	20	15	106	106	106	106	106	106	104	100	96	93	89	84	79	74
	30	23	90	90	90	90	90	90	90	90	90	90	89	84	79	74
	40	31	79	79	79	79	79	79	79	79	79	79	79	79	79	74
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	72
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48	

0-30 ft. Roof Height

Table 2B: Rail Spans (in) for Roof Slopes and Tilt Angles 20° to 36° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-7.0	-7.6	-8.3	-9.0	-9.7	-10.5	-11.3	-12.1	-13.0	-13.8	-14.7	-16.6	-18.7	-20.8	
	0	0	144	144	144	144	144	141	135	129	124	119	114	107	100	94
	10	8	134	133	132	130	129	128	127	125	124	119	114	107	100	94
	20	15	106	106	106	106	106	106	106	105	105	104	103	101	100	94
	30	23	90	90	90	90	90	90	90	90	90	90	90	90	89	88
	40	31	79	79	79	79	79	79	79	79	79	79	79	79	79	79
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	72
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48	

0-30 ft. Roof Height

Table 2C: Rail Spans (in) for Roof Slopes and Tilt Angles 37° to 45° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
		q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2
		P _g P _s	-6.7	-7.3	-7.9	-8.6	-9.3	-10.0	-10.8	-11.6	-12.4	-13.2	-14.1	-15.9	-17.8	-19.9
		0 0	144	144	144	144	144	144	139	133	127	122	118	109	102	96
		10 8	134	133	132	130	129	128	127	125	124	122	118	109	102	96
		20 15	106	106	106	106	106	106	106	105	105	104	103	101	100	96
		30 23	90	90	90	90	90	90	90	90	90	90	90	90	89	88
		40 31	79	79	79	79	79	79	79	79	79	79	79	79	79	79
		50 39	72	72	72	72	72	72	72	72	72	72	72	72	72	72
		60 46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
		70 54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
		80 62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
		100 77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
		120 92	48	48	48	48	48	48	48	48	48	48	48	48	48	48

0-30 ft. Roof Height

Table 2D: Rail Spans (in) for Roof Slopes and Tilt Angles 46° to 60° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
		q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2
		P _g P _s	-6.3	-6.9	-7.6	-8.2	-8.9	-9.6	-10.3	-11.0	-11.8	-12.6	-13.4	-15.2	-17.0	-18.9
		0 0	144	144	144	144	142	139	135	132	129	126	121	113	105	99
		10 8	128	126	124	123	121	120	118	116	115	113	112	109	105	99
		20 15	106	106	105	104	103	102	101	100	99	98	97	95	93	91
		30 23	90	90	90	90	90	90	90	89	88	88	87	85	84	82
		40 31	79	79	79	79	79	79	79	79	79	79	79	78	77	76
		50 39	72	72	72	72	72	72	72	72	72	72	72	72	72	71
		60 46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
		70 54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
		80 62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
		100 77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
		120 92	48	48	48	48	48	48	48	48	48	48	48	48	48	48

Series 100

Structural Report and Calculations



31-60 ft. Roof Height

Table 2E: Rail Spans (in) for Roof Slopes and Tilt Angles 0° to 19° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g	P _s	-12.3	-13.5	-14.7	-15.9	-17.2	-18.6	-20.0	-21.4	-22.9	-24.5	-26.1	-29.4	-33.0	-36.7
	0	0	128	121	115	109	105	100	96	92	89	86	83	77	73	69
	10	8	128	121	115	109	105	100	96	92	89	86	83	77	73	69
	20	15	106	106	106	106	105	100	96	92	89	86	83	77	73	69
	30	23	90	90	90	90	90	90	90	90	89	86	83	77	73	69
	40	31	79	79	79	79	79	79	79	79	79	79	79	77	73	69
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	69
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
	120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48

31-60 ft. Roof Height

Table 2F: Rail Spans (in) for Roof Slopes and Tilt Angles 20° to 36° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g	P _s	-8.0	-8.8	-9.6	-10.4	-11.2	-12.1	-13.0	-14.0	-14.9	-16.0	-17.0	-19.2	-21.5	-24.0
	0	0	144	144	144	142	135	129	123	118	114	109	105	98	92	87
	10	8	132	131	129	128	127	125	123	118	114	109	105	98	92	87
	20	15	106	106	106	106	106	105	105	104	103	102	101	98	92	87
	30	23	90	90	90	90	90	90	90	90	90	90	90	89	87	86
	40	31	79	79	79	79	79	79	79	79	79	79	79	79	79	79
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	72
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
	120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48

31-60 ft. Roof Height

Table 2G: Rail Spans (in) for Roof Slopes and Tilt Angles 37° to 45° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g P _s	-7.7	-8.4	-9.1	-9.9	-10.7	-11.6	-12.4	-13.3	-14.3	-15.2	-16.2	-18.3	-20.6	-22.9	
	0	0	144	144	144	144	139	133	127	122	117	112	108	101	94	89
	10	8	132	131	129	128	127	125	124	122	117	112	108	101	94	89
	20	15	106	106	106	106	106	105	105	104	103	102	101	99	94	89
	30	23	90	90	90	90	90	90	90	90	90	90	90	89	87	86
	40	31	79	79	79	79	79	79	79	79	79	79	79	79	79	79
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	72
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
	120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48

31-60 ft. Roof Height

Table 2H: Rail Spans (in) for Roof Slopes and Tilt Angles 46° to 60° 6005 Alloy																
Wind Load																
Ground Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g P _s	-7.3	-8.0	-8.7	-9.5	-10.2	-11.0	-11.9	-12.7	-13.6	-14.5	-15.5	-17.5	-19.6	-21.8	
	0	0	144	144	143	139	136	132	129	125	120	115	111	104	97	91
	10	8	125	123	122	120	118	116	115	113	111	110	108	104	97	91
	20	15	105	104	103	102	101	100	99	98	97	96	95	92	90	88
	30	23	90	90	90	90	90	89	88	87	87	86	85	83	82	80
	40	31	79	79	79	79	79	79	79	79	79	79	78	77	76	74
	50	39	72	72	72	72	72	72	72	72	72	72	72	71	70	69
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	65
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
	120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48

Rail Testing

The aluminum rails have been designed in accordance with the 2015 Aluminum Design Manual (ADM) as referenced in the IBC. Testing was conducted per the standards set forth by the IBC Section 1715; Preconstruction Load Test. The results of this testing procedure were used in comparison with the calculated values to establish the maximum uplift load allowed for the rails.

Racking Connections to the Existing Roof

Contained within the calculation packet are calculations for the connection of the rails to the roof framing. Using the sizes provided by SnapNrack, we have calculated the maximum forces that will be resisted based on the withdrawal value of the lag screws, and the strength of the aluminum components which are involved in transferring these forces from the rail to the roof framing. These components consist of the flashed L-foot (SnapNrack Drawing PEN-D01), Standoff (PEN-D02, D03), Seam Clamp (PEN-D04), Corrugated Block (PEN-D05), Metal Roof Base (PEN-D09, D10, D11, D12) and Hanger Bolt (PEN-D06). All (6) options are acceptable under the parameters shown in SnapNrack's plans. The results from our analysis have been integrated into the summary charts.

The connection of the PV racking system to the roof will use a 5/16" diameter Lag Bolt installed with a minimum 2 1/2" embedment into the framing member. Bolts shall be installed to a rafter or blocking capable of supporting both wind and seismic loads along with the weight of the PV system.

When PEN-D07 is involved, use minimum quantity 2 1/4-20 lag bolts with minimum 1.25" embedment. In addition, SnapNrack's Tile Roof Hooks (Drawing PEN-D13, D14) are also acceptable attachment components when the following limitations are followed:

1. tile roof hooks have been reviewed up to 120 mph, Design Wind Speed
2. rail span is limited to 6 feet with tile roof hooks


Summary Charts and Topographic Factors

The attached pages of this summary contain some of the most common building configurations with varying wind speeds. These charts serve as quick references for looking up maximum rail spans based on the building and site conditions. However, it must be noted that for any building where a topographic factor is applied (e.g. hills, mesas, seashore), the rail span lengths given might exceed what is allowed for the given site condition. In that case, a registered structural engineer shall evaluate the exact topographic conditions for the specific site.

End Zone and Edge Distances

The edge zones and/or end zones of the roof area shall be determined based on the building's least horizontal dimension (LDH). The edge zone, "a", is equal to 10% of the LDH where $a = .1 * LDH$. It should be noted that if the solar panels installed cross two different roof sections, the smaller LDH shall be used.

Rail spans in the corner zone shall be a maximum of 24 inches and this restriction will only apply to the rail attachments located in the end and edge zones (does not apply to modulus or rails that overhang into the zone). Furthermore, all edge zones requiring an adjustment (shaded cells in chart) shall be reduced by 24 inches to a minimum of 32 inches.



Detail 1 roof end /edge and corner zones

Site – Specific Analysis

A site-specific analysis is required if the location of the solar panel installation corresponds to any of the following criteria:

- The total pitch of the solar panel (solar panel pitch & roof pitch) is greater than 60 degrees above the horizontal.
- A topographic factor applied to a location. Generally, topographic factors are applied when the structure is on a hill, mesa or bluff, or is adjacent to a large body of water. For complete descriptions of topographic factors, please refer to ASCE 7-10 section 26.8
- The mean roof height of the structure that the solar panels will be installed on is greater than 60 ft. above grade.
- A combination of loads and/or site conditions applied that is not addressed in the attached rail span charts.

If one or more of these factors corresponds to the project location, please contact NSSE, and we will analyze the site conditions and recommend standoff spacing for each specific site.

Existing Building Limitations

This summary letter addresses the structural adequacy of the solar racking system only and does not investigate or validate the adequacy of the structure the racking system is being placed upon. It does not address the ability of the existing roofing or roof framing to support the new loads imposed upon them by the new system, nor does it address the new localized forces between the roofing and the roof framing which might be imposed by the new standoff connections. It also does not address the additional lateral forces imposed upon the building due to the seismic and wind forces that the new system will add to the existing roof. These various building-specific issues need to be evaluated by the appropriate registered professional(s) prior to the addition of the photovoltaic and racking systems. NSSE may be consulted for building-specific structural evaluation. NSSE assumes the systems will be installed to the specifications presented here and the installer will use good structural judgment.

Series 100

Structural Report and Calculations



Please note that all sizes, materials specifications, and weights have been provided by SnapNrack. Installation must be in accordance with SnapNrack drawings as noted:

Drawing Title	Revision
S100-D01	F
S100-D02	F
S100-D03	F
S100-D03	F
S100-D04	F
S100-D05	F
S100-D06	F
S100-D07	F
S100-D08	F
S100-D09	F
S100-D10	F
S100-D11	F
PEN-D01	F
PEN-D02	F
PEN-D03	F
PEN-D04	F
PEN-D05	F
PEN-D06	F
PEN-D07	F
PEN-D08	F
PEN-D09	F
PEN-D10	F
PEN-D11	F
PEN-D12	F
PEN D13	F
PEN D14	F

Please see SnapNrack plans for limits on the bolt parameters. Torque all 5/16" diameter hardware as specified in SnapNrack's plans (10-16 ft-lbs for Silver Stainless Steel and 7-9ft –lbs for black Stainless Steel, unless otherwise noted). All waterproofing, roofing and drainage issues are the responsibility of SnapNrack's customer(s) otherwise known as the contractor(s) or the professional solar installer(s).

Please let us know if you have any questions.

Norman Scheel PE, SE
LEED-AP BD+C, LEED-AP Homes
Fellow SEAOC
Fellow A.S.C.E.

Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6063 Alloy Rail



Mean Roof Height 0 to 30 ft

Velocity Pressure 28.3.2 ASCE 7-10

Risk Category: II (Table 1.5-2)

$$q_z = q_h = 0.00256 k_z k_{zt} k_d V^2$$

Wind Exposure Category C

- $k_z = 0.98$ Velocity Pressure Exposure Coefficients (Table 26.8-1)
- $K_{zt} = 1.00$ Topographic Factor (Fig. 26.8-1)
- $K_d = 0.85$ Wind Directionality Factor (Table 26.6-1)

Velocity Pressures														
Wind Speed	110	115	120	125	130	135	140	145	150	155	160	170	180	190
q_h	25.80	28.20	30.71	33.32	36.04	38.86	41.80	44.84	47.98	51.23	54.59	61.63	69.09	76.98
ASD (0.6W)	15.48	16.92	18.42	19.99	21.62	23.32	25.08	26.90	28.79	30.74	32.75	36.98	41.46	46.19

$$P = q_h [GC_{pf} - GC_{pi}]$$

- $q_h =$ Velocity Pressure (psf)
- $GC_{pi} =$ +/- Internal Pressure Coefficient
- $GC_{pf} =$ External Pressure Coefficient

GC_{pf}		Roof Zones Fig 28.4-1 ASCE 7-10			
Pitch	Slope	Zone 2	Zone 3	Zone 2E	Zone 3E
0/12	0.0	-0.69	-0.37	-1.07	-0.53
1/12	4.8	-0.69	-0.37	-1.07	-0.53
2/12	9.5	-0.69	-0.40	-1.07	-0.53
3/12	14.0	-0.69	-0.44	-1.07	-0.53
4/12	18.4	-0.69	-0.47	-1.07	-0.54
5/12	22.6	-0.45	-0.35	-0.72	-0.65
6/12	26.6	-0.10	-0.15	-0.19	-0.58
7/12	30.3	0.21	-0.43	0.27	-0.53
8/12	33.7	0.21	-0.43	0.27	-0.53
9/12	36.9	0.21	-0.43	0.27	-0.53
10/12	39.8	0.21	-0.43	0.27	-0.53
11/12	42.5	0.21	-0.43	0.27	-0.53
12/12	45.0	0.21	-0.43	0.27	-0.53
21/12	60.0	0.32	-0.41	0.40	-0.51

Notes

- 1) GC_{pi} equal +/- 0.10 based on published data from the Solar America Board for Codes and Standards.
- 2) Wind Exposure B and C covered in this document.


Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6063 Alloy Rail


SnapNrack™

PV Mounting Systems

Mean Roof Height 0 to 30 ft



Transverse Direction



Longitudinal Direction

Zone Locations Main Force Resisting Systems ASCE 7-10

Series 100

Wind Design ASCE 7-10 Components and Cladding Walls
6063 Alloy Rail

SnapNrack™

PV Mounting Systems

Mean Roof Height 0 to 30 ft


Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


q_h = Velocity Pressure (psf)

GC_{pi} = +/- Internal Pressure Coefficient

GC_p = External Pressure Coefficient



GC _p Walls (Fig. 30.4-1)			
Slope in Degrees	Zone 4	Zone 5	Zone 4 & 5
0 to 10	-1.00	-1.27	0.91
10 to 45	-1.10	-1.39	-1.00



Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
0 to 7 degrees for 6063 Alloy Rail

SnapNrack™



PV Mounting Systems

Mean Roof Height 0 to 30 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$

- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2A				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
0 to 7	-0.99	-1.71	-2.59	0.29

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
7 to 27 degrees for 6063 Alloy Rail




Mean Roof Height 0 to 30 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2B				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
7 to 27	-0.89	-1.64	-2.53	0.48

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
27 to 45 degrees for 6063 Alloy Rail

SnapNrack™


PV Mounting Systems

Mean Roof Height 0 to 30 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2C				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
27 to 45	-0.98	-1.18	-1.18	0.89

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



Series 100

Seismic Design ASCE 7-10 Chapter 11 and 13
6063 Alloy Rail

SnapNrack™

PV Mounting Systems

Mean Roof Height 0 to 30 ft

ASCE 7-10 Seismic Design Section 13.6.9

Site Classification	D	Default "D"
Seismic Use Group	II	Table 11.5-1
R_p	=	2.5 Input from Table 13.6-1 ASCE 7-10
A_p	=	1.0 Input from Table 13.6-1 ASCE 7-10
I_p	=	1.0 Input from Table 11.5-1 ASCE 7-10
S_s	=	3.0 Input from USGS Program
S_1	=	1.5 Input from USGS Program
F_a	=	1.0 Site Coefficient Table 11.4-1
F_v	=	1.5 Site Coefficient Table 11.4-2
S_{ms}	=	3.0 ASCE 7-10 Section 11.4.3
S_{m1}	=	2.3 ASCE 7-10 Section 11.4.3
S_{ds}	=	2.0 ASCE 7-10 Section 11.4.3
S_{d1}	=	1.5 ASCE 7-10 Section 11.4.3
z	=	30.5 Height at point of Attachment (ft.)
h	=	30.0 Average Roof Height of Structure (ft.)

F_p	=	0.97	W_p
$F_{p \max}$	=	3.20	W_p
$F_{p \min}$	=	0.60	W_p
Use F_p	=	0.97	W_p

(Eq. 13.3.1)

$$F_p = \frac{0.4 a_p S_{DS} W_p}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{z}{h}\right)$$

(Eq. 13.3.2) $F_p = 1.6 S_{DS} I_p W_p$ **Max**

(Eq. 13.3.3) $F_p = 0.3 S_{DS} I_p W_p$ **Min**

Vertical Accelerations

$$0.20 (S_{ds}) W_p$$

Notes

- 1) Based on an average dead load of 4 psf the anticipated maximum seismic load is approximately 4 psf with a vertical accelerations of 1.6 psf wind loads govern the design of the PV system.

Series 100

Snow Loads ASCE 7-10 Chapter 7
6063 Alloy Rail



Mean Roof Height 0 to 30 ft

ASCE 7-10 Snow Loads Chapter 7


$$P_f = 0.7 C_e C_t I P_g$$

$$P_s = C_s P_f$$

Snow Load Chart			
Ground Snow P_g	Flat Roof P_f	Sloped Roof P_s Slope < 9/12	Sloped Roof P_s Slope 9/12 to 12/12
10 psf	8	8	8
20 psf	15	15	15
30 psf	23	23	23
40 psf	31	31	31
50 psf	39	39	39
60 psf	46	46	46
70 psf	54	54	54
80 psf	62	62	62
100 psf	77	77	77
120 psf	92	92	92

Calculations for Snow Loads Chapter 7

- $C_e = 1.00$ Exposure Factor (Section 7.3.1)
- $C_t = 1.10$ Thermal Factor (Section 7.3.2)
- $I = 1.00$ Importance Factor (Section 7.3.3)



7-2b: Cold roofs with $C_t=1.1$

Series 100

Rail Properties for 6063 Alloy Rail



Mean Roof Height 0 to 30 ft


Rail Properties for Downward Loads

Section Properties

A	=	0.63	in ²
S	=	0.34	in ³
I	=	0.46	in ⁴

Stresses

F _b	=	15.2	ksi
F _v	=	15.2	ksi
E	=	10000	ksi
M _{allow}	=	5.17	k-in
V _{allow}	=	6.38	k



Rail Section


Rail Properties for Upward Loads

Section Properties

A	=	0.41	in ²
S	=	0.25	in ³
I	=	0.11	in ⁴

Stresses

F _b	=	15.2	ksi
F _v	=	15.2	ksi
E	=	10000	ksi
M _{allow}	=	3.84	k-in
V _{allow}	=	4.16	k



SnapNrack Standard Rail
6063 Alloy

Notes

- 1) Rail section properties determined from test data.
- 2) Rail test date performed per guidelines of chapter 17 of the 2015 IBC.
- 3) This report is using 6063 Alloy Rail

Series 100

PV panel Calculations & Component and Cladding Forces
6063 Alloy Rail




Mean Roof Height 0 to 30 ft

PV Panel Calculations for 39" x 65" Panel Connections

Panel Dimensions

65" Long Panels

Panel Width	=	39.0	in
Panel Length	=	65.0	in
Panel Weight	=	70.4	#
Panel Area	=	17.6	ft ²



Universal End Clamp


Wind Loading

ASCE 7-10 Component and Cladding


Wind Speed	110 to 190 mph
Exposure Cat.	C
Edge Distance (a)	4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-22.96	-30.71	-30.71	68.51
Min	-76.21	-128.56	-197.85	12.64

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)




Adjustable End Clamp




X-Clamp

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamp	-335	-566	-871	302
Int. Clamp	-671	-1132	N/A	603

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone



Mid Clamp 1



Mid Clamp 2

Series 100

PV panel Calculations & Component and Cladding Forces
6063 Alloy Rail




Mean Roof Height 0 to 30 ft

PV Panel Calculations for 39" x 78" Panel Connections

Panel Dimensions

78" Long Panels

Panel Width	=	39.0	in
Panel Length	=	78.0	in
Panel Weight	=	84.5	#
Panel Area	=	21.1	ft ²



Universal End Clamp

Wind Loading

ASCE 7-10 Component and Cladding


Wind Speed 110 to 190 mph

Exposure Cat. C


Edge Distance (a) 4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-22.96	-30.71	-30.71	68.51
Min	-76.21	-128.56	-197.85	12.64

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)




Adjustable End Clamp




X-Clamp

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamps	-402	-679	-1045	362
Int. Clamp	-805	-1358	N/A	724

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone



Mid Clamp 1



Mid Clamp 2

Series 100

Lag Bolt Design 2012 NDS for 6063 Alloy Rail



Mean Roof Height 0 to 30 ft

Lag Bolt Calculations for Roof Connection 65" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

65" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	62.7	62.7	62.7	125.4
4 ft	31.3	31.3	31.3	62.7
6 ft	20.9	20.9	20.9	41.8
8 ft	15.7	15.7	15.7	31.3




Lag Bolt Calculations for Roof Connection 78" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

78" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	52.2	52.2	52.2	104.5
4 ft	26.1	26.1	26.1	52.2
6 ft	17.4	17.4	17.4	34.8
8 ft	13.1	13.1	13.1	26.1



Notes

- 1) Only one corner of one PV panel may be located in zone 3E

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 0 to 19 degrees for 6063 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 0 to 19 Degrees	
Wind Load																
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g	P _s	-10.7	-11.7	-12.7	-13.8	-14.9	-16.1	-17.3	-18.6	-19.9	-21.2	-22.6	-25.5	-28.6	-31.9
	0	0	116	110	104	99	95	91	87	83	80	77	75	70	65	62
	10	8	114	110	104	99	95	91	87	83	80	77	75	70	65	62
	20	15	89	89	89	89	89	89	87	83	80	77	75	70	65	62
	30	23	75	75	75	75	75	75	75	75	75	75	75	70	65	62
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	65	62
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 19 to 37 degrees for 6063 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 20 to 36 Degrees	
Wind Load																
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-7.0	-7.6	-8.3	-9.0	-9.7	-10.5	-11.3	-12.1	-13.0	-13.8	-14.7	-16.6	-18.7	-20.8	
	0 0	120	120	120	120	120	118	112	108	103	99	95	89	83	78	
	10 8	112	111	110	109	108	107	105	104	103	99	95	89	83	78	
	20 15	89	89	89	89	89	89	88	88	87	87	86	85	83	78	
	30 23	75	75	75	75	75	75	75	75	75	75	75	75	74	73	
	40 31	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	50 39	60	60	60	60	60	60	60	60	60	60	60	60	60	60	
	60 46	55	55	55	55	55	55	55	55	55	55	55	55	55	55	
	70 54	51	51	51	51	51	51	51	51	51	51	51	51	51	51	
	80 62	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
	100 77	43	43	43	43	43	43	43	43	43	43	43	43	43	43	
	120 92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 37 to 45 degrees for 6063 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 37 to 45 Degrees	
Wind Load																
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-6.7	-7.3	-7.9	-8.6	-9.3	-10.0	-10.8	-11.6	-12.4	-13.2	-14.1	-15.9	-17.8	-19.9	
	0 0	120	120	120	120	120	120	116	111	106	102	98	91	85	80	
	10 8	112	111	110	109	108	107	105	104	103	102	98	91	85	80	
	20 15	89	89	89	89	89	89	88	88	87	87	86	85	83	80	
	30 23	75	75	75	75	75	75	75	75	75	75	75	75	74	73	
	40 31	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	50 39	60	60	60	60	60	60	60	60	60	60	60	60	60	60	
	60 46	55	55	55	55	55	55	55	55	55	55	55	55	55	55	
	70 54	51	51	51	51	51	51	51	51	51	51	51	51	51	51	
	80 62	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
	100 77	43	43	43	43	43	43	43	43	43	43	43	43	43	43	
	120 92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 45 to 60 degrees for 6063 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angles 46 to 60 Degrees		
Wind Load																	
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190		
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2		
	P _g	P _s	-6.3	-6.9	-7.6	-8.2	-8.9	-9.6	-10.3	-11.0	-11.8	-12.6	-13.4	-15.2	-17.0	-18.9	
	0	0	120	120	120	120	118	115	113	110	107	105	101	94	88	82	
	10	8	106	105	104	102	101	100	98	97	96	94	93	90	88	82	
	20	15	89	88	87	87	86	85	84	83	82	82	81	79	77	76	
	30	23	75	75	75	75	75	75	75	74	74	73	72	71	70	69	
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	65	64	63
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	59	
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55	
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51	
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43	
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6063 Alloy Rail



Mean Roof Height 30 to 60 ft

Velocity Pressure 28.3.2 ASCE 7-10

Risk Category: II (Table 1.5-2)

$$q_z = q_h = 0.00256 k_z k_{zt} k_d V^2$$

Wind Exposure Category C

- $k_z = 1.13$ Velocity Pressure Exposure Coefficients (Table 26.8-1)
- $K_{zt} = 1.00$ Topographic Factor (Fig. 26.8-1)
- $K_d = 0.85$ Wind Directionality Factor (Table 26.6-1)

Velocity Pressures														
Wind Speed	110	115	120	125	130	135	140	145	150	155	160	170	180	190
q_h	29.75	32.52	35.41	38.42	41.56	44.81	48.19	51.70	55.32	59.07	62.95	71.06	79.67	88.77
ASD (0.6W)	17.85	19.51	21.24	23.05	24.93	26.89	28.92	31.02	33.19	35.44	37.77	42.64	47.80	53.26

$$P = q_h [GC_{pf} - GC_{pi}]$$

- $q_h =$ Velocity Pressure (psf)
- $GC_{pi} =$ +/- Internal Pressure Coefficient
- $GC_{pf} =$ External Pressure Coefficient

GC_{pf}		Roof Zones Fig 28.4-1 ASCE 7-10			
Pitch	Slope	Zone 2	Zone 3	Zone 2E	Zone 3E
0/12	0.0	-0.69	-0.37	-1.07	-0.53
1/12	4.8	-0.69	-0.37	-1.07	-0.53
2/12	9.5	-0.69	-0.40	-1.07	-0.53
3/12	14.0	-0.69	-0.44	-1.07	-0.53
4/12	18.4	-0.69	-0.47	-1.07	-0.54
5/12	22.6	-0.45	-0.35	-0.72	-0.65
6/12	26.6	-0.10	-0.15	-0.19	-0.58
7/12	30.3	0.21	-0.43	0.27	-0.53
8/12	33.7	0.21	-0.43	0.27	-0.53
9/12	36.9	0.21	-0.43	0.27	-0.53
10/12	39.8	0.21	-0.43	0.27	-0.53
11/12	42.5	0.21	-0.43	0.27	-0.53
12/12	45.0	0.21	-0.43	0.27	-0.53
21/12	60.0	0.32	-0.41	0.40	-0.51

Notes

- 1) GC_{pi} equal +/- 0.10 based on published data from the Solar America Board for Codes and Standards.
- 2) Wind Exposure B and C covered in this document.


Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6063 Alloy Rail


SnapNrack™

PV Mounting Systems

Mean Roof Height 30 to 60 ft



Transverse Direction



Longitudinal Direction

Zone Locations Main Force Resisting Systems ASCE 7-10

Series 100

Wind Design ASCE 7-10 Components and Cladding Walls
6063 Alloy Rail




Mean Roof Height 30 to 60 ft


Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$

- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Walls (Fig. 30.4-1)			
Slope in Degrees	Zone 4	Zone 5	Zone 4 & 5
0 to 10	-1.00	-1.27	0.91
10 to 45	-1.10	-1.39	-1.00



Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
0 to 7 degrees for 6063 Alloy Rail





Mean Roof Height 30 to 60 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$

- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2A				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
0 to 7	-0.99	-1.71	-2.59	0.29

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
7 to 27 degrees for 6063 Alloy Rail

SnapNrack™


PV Mounting Systems

Mean Roof Height 30 to 60 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2B				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
7 to 27	-0.89	-1.64	-2.53	0.48

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
27 to 45 degrees for 6063 Alloy Rail




Mean Roof Height 30 to 60 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



		GC _p Roofs Fig. 30.4-2C			
Slope in Degrees		Zone 1	Zone 2	Zone 3	Zone 1,2,3
27 to 45		-0.98	-1.18	-1.18	0.89

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



Series 100

Seismic Design ASCE 7-10 Chapter 11 and 13
Alloy Rail

6063

SnapNrack™

PV Mounting Systems

Mean Roof Height 30 to 60 ft

ASCE 7-10 Seismic Design Section 13.6.9

Site Classification	D	Default "D"
Seismic Use Group	II	Table 11.5-1
R_p	=	2.5 Input from Table 13.6-1 ASCE 7-10
A_p	=	1.0 Input from Table 13.6-1 ASCE 7-10
I_p	=	1.0 Input from Table 11.5-1 ASCE 7-10
S_s	=	3.0 Input from USGS Program
S_1	=	1.5 Input from USGS Program
F_a	=	1.0 Site Coefficient Table 11.4-1
F_v	=	1.5 Site Coefficient Table 11.4-2
S_{ms}	=	3.0 ASCE 7-10 Section 11.4.3
S_{m1}	=	2.3 ASCE 7-10 Section 11.4.3
S_{ds}	=	2.0 ASCE 7-10 Section 11.4.3
S_{d1}	=	1.5 ASCE 7-10 Section 11.4.3
z	=	60.5 Height at point of Attachment (ft.)
h	=	60.0 Average Roof Height of Structure (ft.)

$$F_p = 0.97 W_p$$

(Eq. 13.3.1)

$$F_{p \max} = 3.20 W_p$$

$$F_{p \min} = 0.60 W_p$$

$$F_p = \frac{0.4 a_p S_{DS} W_p}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{z}{h}\right)$$

$$\text{Use } F_p = 0.97 W_p$$

(Eq. 13.3.2) $F_p = 1.6 S_{DS} I_p W_p$ Max

(Eq. 13.3.3) $F_p = 0.3 S_{DS} I_p W_p$ Min

Vertical Accelerations

$$0.20 (S_{ds}) W_p$$

Notes

- 1) Based on an average dead load of 4 psf the anticipated maximum seismic load is approximately 4 psf with a vertical accelerations of 1.6 psf wind loads govern the design of the PV system.

Series 100

Snow Loads ASCE 7-10 Chapter 7
6063 Alloy Rail



Mean Roof Height 30 to 60 ft

ASCE 7-10 Snow Loads Chapter 7


$$P_f = 0.7 C_e C_t I P_g$$

$$P_s = C_s P_f$$

Snow Load Chart			
Ground Snow P_g	Flat Roof P_f	Sloped Roof P_s Slope < 9/12	Sloped Roof P_s Slope 9/12 to 12/12
10 psf	8	8	8
20 psf	15	15	15
30 psf	23	23	23
40 psf	31	31	31
50 psf	39	39	39
60 psf	46	46	46
70 psf	54	54	54
80 psf	62	62	62
100 psf	77	77	77
120 psf	92	92	92

Calculations for Snow Loads Chapter 7

- $C_e = 1.00$ Exposure Factor (Section 7.3.1)
- $C_t = 1.10$ Thermal Factor (Section 7.3.2)
- $I = 1.00$ Importance Factor (Section 7.3.3)



7-2b: Cold roofs with $C_t=1.1$

Series 100


Rail Properties for 6063 Alloy Rail

Mean Roof Height 30 to 60 ft

Rail Properties for Downward Loads

Section Properties

A	=	0.63	in ²
S	=	0.34	in ³
I	=	0.46	in ⁴
Stresses			
F _b	=	15.2	ksi
F _v	=	15.2	ksi
E	=	10000	ksi
M _{allow}	=	5.17	k-in
V _{allow}	=	6.38	k




Rail Section

Rail Properties for Upward Loads

Section Properties

A	=	0.41	in ²
S	=	0.25	in ³
I	=	0.11	in ⁴
Stresses			
F _b	=	15.2	ksi
F _v	=	15.2	ksi
E	=	10000	ksi
M _{allow}	=	3.84	k-in
V _{allow}	=	4.16	k



SnapNrack Standard Rail
6063 Alloy

Notes

- 1) Rail section properties determined from test data.
- 2) Rail test date performed per guidelines of chapter 17 of the 2015 IBC.
- 3) This report is using 6063 Alloy Rail

Series 100

PV panel Calculations & Component and Cladding Forces for
6063 Alloy Rail




Mean Roof Height 30 to 60 ft

PV Panel Calculations for 39" x 65" Panel Connections

Panel Dimensions

65" Long Panels

Panel Width	=	39.0 in
Panel Length	=	65.0 in
Panel Weight	=	70.4 #
Panel Area	=	17.6 ft ²



Universal End Clamp


Wind Loading

ASCE 7-10 Component and Cladding


Wind Speed	110 to 190 mph
Exposure Cat.	C
Edge Distance (a)	4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-26.48	-35.41	-35.41	79.00
Min	-87.88	-148.24	-228.13	14.58

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)




Adjustable End Clamp




X-Clamp

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamp	-387	-652	-1004	348
Int. Clamp	-774	-1305	N/A	695

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone



Mid Clamp 1



Mid Clamp 2

Series 100

PV panel Calculations & Component and Cladding Forces for 6063 Alloy Rail




Mean Roof Height 30 to 60 ft

PV Panel Calculations for 39" x 78" Panel Connections

Panel Dimensions

78" Long Panels

Panel Width	=	39.0 in
Panel Length	=	78.0 in
Panel Weight	=	84.5 #
Panel Area	=	21.1 ft ²




Universal End Clamp

Wind Loading

ASCE 7-10 Component and Cladding

Wind Speed	110 to 190 mph
Exposure Cat.	C
Edge Distance (a)	4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-26.48	-35.41	-35.41	79.00
Min	-87.88	-148.24	-228.13	14.58




Adjustable End Clamp

X-Clamp

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamps	-464	-783	-1205	417
Int. Clamp	-928	-1566	N/A	834



Mid Clamp 1

Mid Clamp 2

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone

Series 100

Lag Bolt Design 2012 NDS for 6063 Alloy Rail



Mean Roof Height 30 to 60 ft

Lag Bolt Calculations for Roof Connection 65" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

65" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	62.7	62.7	62.7	125.4
4 ft	31.3	31.3	31.3	62.7
6 ft	20.9	20.9	20.9	41.8
8 ft	15.7	15.7	15.7	31.3




Lag Bolt Calculations for Roof Connection 78" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

78" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	52.2	52.2	52.2	104.5
4 ft	26.1	26.1	26.1	52.2
6 ft	17.4	17.4	17.4	34.8
8 ft	13.1	13.1	13.1	26.1



Notes

- 1) Only one corner of one PV panel may be located in zone 3E

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 0 to 19 degrees for 6063 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 0 to 19 Degrees	
Wind Load																
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190	
q _h		17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
P _g	P _s	-12.3	-13.5	-14.7	-15.9	-17.2	-18.6	-20.0	-21.4	-22.9	-24.5	-26.1	-29.4	-33.0	-36.7	
0	0	106	101	96	91	87	83	80	77	74	71	69	64	61	57	
10	8	106	101	96	91	87	83	80	77	74	71	69	64	61	57	
20	15	89	89	89	89	87	83	80	77	74	71	69	64	61	57	
30	23	75	75	75	75	75	75	75	75	74	71	69	64	61	57	
40	31	66	66	66	66	66	66	66	66	66	66	66	64	61	57	
50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	57	
60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55	
70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51	
80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43	
120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (Lr or S or R)
 4. D + 0.75L + 0.75(Lr or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(Lr or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 19 to 37 degrees for 6063 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 20 to 36 Degrees	
Wind Load																
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190	
q _h		17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
P _g	P _s	-8.0	-8.8	-9.6	-10.4	-11.2	-12.1	-13.0	-14.0	-14.9	-16.0	-17.0	-19.2	-21.5	-24.0	
Snow Load (psf)	0	0	120	120	120	119	113	108	103	99	95	91	88	82	77	72
	10	8	110	109	108	107	106	104	103	99	95	91	88	82	77	72
	20	15	89	89	89	89	89	88	87	86	86	85	84	82	77	72
	30	23	75	75	75	75	75	75	75	75	75	75	75	74	73	72
	40	31	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (Lr or S or R)
 4. D + 0.75L + 0.75(Lr or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(Lr or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 37 to 45 degrees for 6063 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 37 to 45 Degrees	
Wind Load																
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190	
q _h		17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
P _g	P _s	-7.7	-8.4	-9.1	-9.9	-10.7	-11.6	-12.4	-13.3	-14.3	-15.2	-16.2	-18.3	-20.6	-22.9	
0	0	120	120	120	120	116	111	106	101	97	93	90	84	79	74	
10	8	110	109	108	107	106	104	103	101	97	93	90	84	79	74	
20	15	89	89	89	89	89	88	87	86	86	85	84	83	79	74	
30	23	75	75	75	75	75	75	75	75	75	75	75	74	73	72	
40	31	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
50	39	60	60	60	60	60	60	60	60	60	60	60	60	60	60	
60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	55	
70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51	
80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48	
100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43	
120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (Lr or S or R)
 4. D + 0.75L + 0.75(Lr or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(Lr or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 45 to 60 degrees for 6063 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angles 46 to 60 Degrees				
Wind Load																			
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190				
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3				
	P _g	P _s	-7.3	-8.0	-8.7	-9.5	-10.2	-11.0	-11.9	-12.7	-13.6	-14.5	-15.5	-17.5	-19.6	-21.8			
	0	0	120	120	119	116	113	110	107	104	100	96	93	86	81	76			
	10	8	104	103	101	100	98	97	96	94	93	91	90	86	81	76			
	20	15	88	87	86	85	84	83	82	81	81	80	79	77	75	73			
	30	23	75	75	75	75	75	74	73	73	72	72	71	70	68	67			
	40	31	66	66	66	66	66	66	66	66	66	65	65	64	63	62			
	50	39	60	60	60	60	60	60	60	60	60	60	60	60	59	58			
	60	46	55	55	55	55	55	55	55	55	55	55	55	55	55	54			
	70	54	51	51	51	51	51	51	51	51	51	51	51	51	51	51			
	80	62	48	48	48	48	48	48	48	48	48	48	48	48	48	48			
	100	77	43	43	43	43	43	43	43	43	43	43	43	43	43	43			
	120	92	40	40	40	40	40	40	40	40	40	40	40	40	40	40			

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6005 Alloy Rail



Mean Roof Height 0 to 30 ft

Velocity Pressure 28.3.2 ASCE 7-10

Risk Category: II (Table 1.5-2)

$$q_z = q_h = 0.00256 k_z k_{zt} k_d V^2$$

Wind Exposure Category C

- $k_z = 0.98$ Velocity Pressure Exposure Coefficients (Table 26.8-1)
- $K_{zt} = 1.00$ Topographic Factor (Fig. 26.8-1)
- $K_d = 0.85$ Wind Directionality Factor (Table 26.6-1)

Velocity Pressures														
Wind Speed	110	115	120	125	130	135	140	145	150	155	160	170	180	190
q_h	25.80	28.20	30.71	33.32	36.04	38.86	41.80	44.84	47.98	51.23	54.59	61.63	69.09	76.98
ASD (0.6W)	15.48	16.92	18.42	19.99	21.62	23.32	25.08	26.90	28.79	30.74	32.75	36.98	41.46	46.19

- $P = q_h [GC_{pf} - GC_{pi}]$
- $q_h =$ Velocity Pressure (psf)
 - $GC_{pi} =$ +/- Internal Pressure Coefficient
 - $GC_{pf} =$ External Pressure Coefficient

GC_{pf}		Roof Zones Fig 28.4-1 ASCE 7-10			
Pitch	Slope	Zone 2	Zone 3	Zone 2E	Zone 3E
0/12	0.0	-0.69	-0.37	-1.07	-0.53
1/12	4.8	-0.69	-0.37	-1.07	-0.53
2/12	9.5	-0.69	-0.40	-1.07	-0.53
3/12	14.0	-0.69	-0.44	-1.07	-0.53
4/12	18.4	-0.69	-0.47	-1.07	-0.54
5/12	22.6	-0.45	-0.35	-0.72	-0.65
6/12	26.6	-0.10	-0.15	-0.19	-0.58
7/12	30.3	0.21	-0.43	0.27	-0.53
8/12	33.7	0.21	-0.43	0.27	-0.53
9/12	36.9	0.21	-0.43	0.27	-0.53
10/12	39.8	0.21	-0.43	0.27	-0.53
11/12	42.5	0.21	-0.43	0.27	-0.53
12/12	45.0	0.21	-0.43	0.27	-0.53
21/12	60.0	0.32	-0.41	0.40	-0.51

Notes

- 1) GC_{pi} equal +/- 0.10 based on published data from the Solar America Board for Codes and Standards.
- 2) Wind Exposure B and C covered in this document.

6005 Alloy Rail


Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6005 Alloy Rail


SnapNrack™

PV Mounting Systems

Mean Roof Height 0 to 30 ft



Transverse Direction



Longitudinal Direction

Zone Locations Main Force Resisting Systems ASCE 7-10

6005 Alloy Rail

Series 100

Wind Design ASCE 7-10 Components and Cladding Walls
6005 Alloy Rail




Mean Roof Height 0 to 30 ft


Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$

- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Walls (Fig. 30.4-1)			
Slope in Degrees	Zone 4	Zone 5	Zone 4 & 5
0 to 10	-1.00	-1.27	0.91
10 to 45	-1.10	-1.39	-1.00



Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
0 to 7 degrees for 6005 Alloy Rail





Mean Roof Height 0 to 30 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$

- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2A				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
0 to 7	-0.99	-1.71	-2.59	0.29

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
7 to 27 degrees for 6005 Alloy Rail




Mean Roof Height 0 to 30 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2B				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
7 to 27	-0.89	-1.64	-2.53	0.48

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
27 to 45 degrees for 6005 Alloy Rail




Mean Roof Height 0 to 30 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



		GC _p Roofs Fig. 30.4-2C			
Slope in Degrees		Zone 1	Zone 2	Zone 3	Zone 1,2,3
27 to 45		-0.98	-1.18	-1.18	0.89

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



6005 Alloy Rail

Series 100

Seismic Design ASCE 7-10 Chapter 11 and 13
6005 Alloy Rail



Mean Roof Height 0 to 30 ft

ASCE 7-10 Seismic Design Section 13.6.9

Site Classification	D	Default "D"
Seismic Use Group	II	Table 11.5-1
R_p	=	2.5 Input from Table 13.6-1 ASCE 7-10
A_p	=	1.0 Input from Table 13.6-1 ASCE 7-10
I_p	=	1.0 Input from Table 11.5-1 ASCE 7-10
S_s	=	3.0 Input from USGS Program
S_1	=	1.5 Input from USGS Program
F_a	=	1.0 Site Coefficient Table 11.4-1
F_v	=	1.5 Site Coefficient Table 11.4-2
S_{ms}	=	3.0 ASCE 7-10 Section 11.4.3
S_{m1}	=	2.3 ASCE 7-10 Section 11.4.3
S_{ds}	=	2.0 ASCE 7-10 Section 11.4.3
S_{d1}	=	1.5 ASCE 7-10 Section 11.4.3
z	=	30.5 Height at point of Attachment (ft.)
h	=	30.0 Average Roof Height of Structure (ft.)

$$F_p = 0.97 W_p$$

(Eq. 13.3.1)

$$F_{p \max} = 3.20 W_p$$

$$F_{p \min} = 0.60 W_p$$

$$F_p = \frac{0.4 a_p S_{DS} W_p}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{z}{h}\right)$$

$$\text{Use } F_p = 0.97 W_p$$

(Eq. 13.3.2) $F_p = 1.6 S_{DS} I_p W_p$ **Max**

(Eq. 13.3.3) $F_p = 0.3 S_{DS} I_p W_p$ **Min**

Vertical Accelerations

$$0.20 (S_{ds}) W_p$$

Notes

- 1) Based on an average dead load of 4 psf the anticipated maximum seismic load is approximately 4 psf with a vertical accelerations of 1.6 psf wind loads govern the design of the PV system.

Series 100

Snow Loads ASCE 7-10 Chapter 7
6005 Alloy Rail



Mean Roof Height 0 to 30 ft

ASCE 7-10 Snow Loads Chapter 7


$$P_f = 0.7 C_e C_t I P_g$$

$$P_s = C_s P_f$$

Snow Load Chart			
Ground Snow P_g	Flat Roof P_f	Sloped Roof P_s Slope < 9/12	Sloped Roof P_s Slope 9/12 to 12/12
10 psf	8	8	8
20 psf	15	15	15
30 psf	23	23	23
40 psf	31	31	31
50 psf	39	39	39
60 psf	46	46	46
70 psf	54	54	54
80 psf	62	62	62
100 psf	77	77	77
120 psf	92	92	92

Calculations for Snow Loads Chapter 7

- $C_e = 1.00$ Exposure Factor (Section 7.3.1)
- $C_t = 1.10$ Thermal Factor (Section 7.3.2)
- $I = 1.00$ Importance Factor (Section 7.3.3)



7-2b: Cold roofs with $C_t=1.1$

Series 100

Rail Properties for 6005 Alloy Rail




Mean Roof Height 0 to 30 ft

Rail Properties for Downward Loads

Section Properties

A	=	0.63	in ²
S	=	0.34	in ³
I	=	0.46	in ⁴
Stresses			
F _b	=	21.9	ksi
F _v	=	21.9	ksi
E	=	10000	ksi
M _{allow}	=	7.45	k-in
V _{allow}	=	6.38	k




Rail Section

Rail Properties for Upward Loads

Section Properties

A	=	0.41	in ²
S	=	0.25	in ³
I	=	0.11	in ⁴
Stresses			
F _b	=	21.9	ksi
F _v	=	21.9	ksi
E	=	10000	ksi
M _{allow}	=	5.53	k-in
V _{allow}	=	4.16	k



SnapNrack Standard Rail
Keyed 6005 Alloy

Notes

- 1) Rail section properties determined from test data.
- 2) Rail test date performed per guidelines of chapter 17 of the 2015 IBC.
- 3) This report is using 6005 alloy rails

Series 100

PV panel Calculations & Component and Cladding Forces for 6005 Alloy Rail




Mean Roof Height 0 to 30 ft

PV Panel Calculations for 39" x 65" Panel Connections

Panel Dimensions

65" Long Panels

Panel Width	=	39.0 in
Panel Length	=	65.0 in
Panel Weight	=	70.4 #
Panel Area	=	17.6 ft ²



Universal End Clamp


Wind Loading

ASCE 7-10 Component and Cladding


Wind Speed	110 to 190 mph
Exposure Cat.	C
Edge Distance (a)	4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-22.96	-30.71	-30.71	68.51
Min	-76.21	-128.56	-197.85	12.64

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)




Adjustable End Clamp




X-Clamp

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamp	-335	-566	-871	302
Int. Clamp	-671	-1132	N/A	603

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone



Mid Clamp 1



Mid Clamp 2

6005 Alloy Rail

Series 100

PV panel Calculations & Component and Cladding Forces for 6005 Alloy Rail




Mean Roof Height 0 to 30 ft

PV Panel Calculations for 39" x 78" Panel Connections

Panel Dimensions

78" Long Panels

Panel Width	=	39.0 in
Panel Length	=	78.0 in
Panel Weight	=	84.5 #
Panel Area	=	21.1 ft ²



Universal End Clamp


Wind Loading

ASCE 7-10 Component and Cladding


Wind Speed	110 to 190 mph
Exposure Cat.	C
Edge Distance (a)	4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-22.96	-30.71	-30.71	68.51
Min	-76.21	-128.56	-197.85	12.64

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)




Adjustable End Clamp




X-Clamp

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamps	-402	-679	-1045	362
Int. Clamp	-805	-1358	N/A	724

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone



Mid Clamp 1



Mid Clamp 2

6005 Alloy Rail

Series 100

Lag Bolt Design 2012 NDS for 6005 Alloy Rail



Mean Roof Height 0 to 30 ft

Lag Bolt Calculations for Roof Connection 65" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

65" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	62.7	62.7	62.7	125.4
4 ft	31.3	31.3	31.3	62.7
6 ft	20.9	20.9	20.9	41.8
8 ft	15.7	15.7	15.7	31.3




Lag Bolt Calculations for Roof Connection 78" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

78" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	52.2	52.2	52.2	104.5
4 ft	26.1	26.1	26.1	52.2
6 ft	17.4	17.4	17.4	34.8
8 ft	13.1	13.1	13.1	26.1



Notes

- 1) Only one corner of one PV panel may be located in zone 3E

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 0 to 19 degrees for 6005 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values																Tilt Angle 0 to 19 Degrees	
Wind Load																	
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190		
q _h		15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2		
P _g	P _s	-10.7	-11.7	-12.7	-13.8	-14.9	-16.1	-17.3	-18.6	-19.9	-21.2	-22.6	-25.5	-28.6	-31.9		
0	0	140	132	125	119	114	109	104	100	96	93	89	84	79	74		
10	8	137	132	125	119	114	109	104	100	96	93	89	84	79	74		
20	15	106	106	106	106	106	106	104	100	96	93	89	84	79	74		
30	23	90	90	90	90	90	90	90	90	90	90	89	84	79	74		
40	31	79	79	79	79	79	79	79	79	79	79	79	79	79	74		
50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	72		
60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66		
70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62		
80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58		
100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52		
120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48		

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 19 to 37 degrees for 6005 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 20 to 36 Degrees	
Wind Load																
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-7.0	-7.6	-8.3	-9.0	-9.7	-10.5	-11.3	-12.1	-13.0	-13.8	-14.7	-16.6	-18.7	-20.8	
	0 0	144	144	144	144	144	141	135	129	124	119	114	107	100	94	
	10 8	134	133	132	130	129	128	127	125	124	119	114	107	100	94	
	20 15	106	106	106	106	106	106	106	105	105	104	103	101	100	94	
	30 23	90	90	90	90	90	90	90	90	90	90	90	90	89	88	
	40 31	79	79	79	79	79	79	79	79	79	79	79	79	79	79	
	50 39	72	72	72	72	72	72	72	72	72	72	72	72	72	72	
	60 46	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	70 54	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	80 62	58	58	58	58	58	58	58	58	58	58	58	58	58	58	
	100 77	52	52	52	52	52	52	52	52	52	52	52	52	52	52	
	120 92	48	48	48	48	48	48	48	48	48	48	48	48	48	48	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (Lr or S or R)
 4. D + 0.75L + 0.75(Lr or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(Lr or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 37 to 45 degrees for 6005 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values																Tilt Angle 37 to 45 Degrees		
Wind Load																		
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190			
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2			
	P _g	P _s	-6.7	-7.3	-7.9	-8.6	-9.3	-10.0	-10.8	-11.6	-12.4	-13.2	-14.1	-15.9	-17.8	-19.9		
	0	0	144	144	144	144	144	144	139	133	127	122	118	109	102	96		
	10	8	134	133	132	130	129	128	127	125	124	122	118	109	102	96		
	20	15	106	106	106	106	106	106	106	105	105	104	103	101	100	96		
	30	23	90	90	90	90	90	90	90	90	90	90	90	90	89	88		
	40	31	79	79	79	79	79	79	79	79	79	79	79	79	79	79		
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	72		
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66		
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62		
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58		
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52		
	120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48		

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (Lr or S or R)
 4. D + 0.75L + 0.75(Lr or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(Lr or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 45 to 60 degrees for 6005 Alloy Rail



Mean Roof Height 0 to 30 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angles 46 to 60 Degrees	
Wind Load																
Snow Load (psf)	V _{ult}	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	15.5	16.9	18.4	20.0	21.6	23.3	25.1	26.9	28.8	30.7	32.8	37.0	41.5	46.2	
	P _g P _s	-6.3	-6.9	-7.6	-8.2	-8.9	-9.6	-10.3	-11.0	-11.8	-12.6	-13.4	-15.2	-17.0	-18.9	
	0 0	144	144	144	144	142	139	135	132	129	126	121	113	105	99	
	10 8	128	126	124	123	121	120	118	116	115	113	112	109	105	99	
	20 15	106	106	105	104	103	102	101	100	99	98	97	95	93	91	
	30 23	90	90	90	90	90	90	90	89	88	88	87	85	84	82	
	40 31	79	79	79	79	79	79	79	79	79	79	79	79	78	77	76
	50 39	72	72	72	72	72	72	72	72	72	72	72	72	72	71	
	60 46	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	70 54	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	80 62	58	58	58	58	58	58	58	58	58	58	58	58	58	58	
	100 77	52	52	52	52	52	52	52	52	52	52	52	52	52	52	
	120 92	48	48	48	48	48	48	48	48	48	48	48	48	48	48	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (L_r or S or R)
 4. D + 0.75L + 0.75(L_r or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(L_r or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

6005 Alloy Rail

Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6005 Alloy Rail



Mean Roof Height 30 to 60 ft

Velocity Pressure 28.3.2 ASCE 7-10

Risk Category: II (Table 1.5-2)

$$q_z = q_h = 0.00256 k_z k_{zt} k_d V^2$$

Wind Exposure Category C

- $k_z = 1.13$ Velocity Pressure Exposure Coefficients (Table 26.8-1)
- $K_{zt} = 1.00$ Topographic Factor (Fig. 26.8-1)
- $K_d = 0.85$ Wind Directionality Factor (Table 26.6-1)

Velocity Pressures														
Wind Speed	110	115	120	125	130	135	140	145	150	155	160	170	180	190
q_h	29.75	32.52	35.41	38.42	41.56	44.81	48.19	51.70	55.32	59.07	62.95	71.06	79.67	88.77
ASD (0.6W)	17.85	19.51	21.24	23.05	24.93	26.89	28.92	31.02	33.19	35.44	37.77	42.64	47.80	53.26

$$P = q_h [GC_{pf} - GC_{pi}]$$

- $q_h =$ Velocity Pressure (psf)
- $GC_{pi} =$ +/- Internal Pressure Coefficient
- $GC_{pf} =$ External Pressure Coefficient

GC_{pf}		Roof Zones Fig 28.4-1 ASCE 7-10			
Pitch	Slope	Zone 2	Zone 3	Zone 2E	Zone 3E
0/12	0.0	-0.69	-0.37	-1.07	-0.53
1/12	4.8	-0.69	-0.37	-1.07	-0.53
2/12	9.5	-0.69	-0.40	-1.07	-0.53
3/12	14.0	-0.69	-0.44	-1.07	-0.53
4/12	18.4	-0.69	-0.47	-1.07	-0.54
5/12	22.6	-0.45	-0.35	-0.72	-0.65
6/12	26.6	-0.10	-0.15	-0.19	-0.58
7/12	30.3	0.21	-0.43	0.27	-0.53
8/12	33.7	0.21	-0.43	0.27	-0.53
9/12	36.9	0.21	-0.43	0.27	-0.53
10/12	39.8	0.21	-0.43	0.27	-0.53
11/12	42.5	0.21	-0.43	0.27	-0.53
12/12	45.0	0.21	-0.43	0.27	-0.53
21/12	60.0	0.32	-0.41	0.40	-0.51

Notes

- 1) GC_{pi} equal +/- 0.10 based on published data from the Solar America Board for Codes and Standards.
- 2) Wind Exposure B and C covered in this document.

6005 Alloy Rail


Series 100

Wind Design ASCE 7-10 Main Force Resisting System
6005 Alloy Rail


SnapNrack™

PV Mounting Systems

Mean Roof Height 30 to 60 ft



Transverse Direction



Longitudinal Direction

Zone Locations Main Force Resisting Systems ASCE 7-10

6005 Alloy Rail

Series 100

Wind Design ASCE 7-10 Components and Cladding Walls
6005 Alloy Rail

SnapNrack™


PV Mounting Systems

Mean Roof Height 30 to 60 ft


Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$

q_h = Velocity Pressure (psf)
 GC_{pi} = +/- Internal Pressure Coefficient
 GC_p = External Pressure Coefficient



GC _p Walls (Fig. 30.4-1)			
Slope in Degrees	Zone 4	Zone 5	Zone 4 & 5
0 to 10	-1.00	-1.27	0.91
10 to 45	-1.10	-1.39	-1.00



Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
0 to 7 degrees for 6005 Alloy Rail





Mean Roof Height 30 to 60 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$

- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2A				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
0 to 7	-0.99	-1.71	-2.59	0.29

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
7 to 27 degrees for 6005 Alloy Rail




Mean Roof Height 30 to 60 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



GC _p Roofs Fig. 30.4-2B				
Slope in Degrees	Zone 1	Zone 2	Zone 3	Zone 1,2,3
7 to 27	-0.89	-1.64	-2.53	0.48

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



6005 Alloy Rail

Series 100

Wind Design ASCE 7-10 Components and Cladding Roof
27 to 45 degrees for 6005 Alloy Rail




Mean Roof Height 30 to 60 ft

Components and Cladding Low-Rise Buildings ASCE 7-10 30.4-1

$$P = q_h [GC_p - GC_{pi}]$$


- q_h = Velocity Pressure (psf)
- GC_{pi} = +/- Internal Pressure Coefficient
- GC_p = External Pressure Coefficient



		GC _p Roofs Fig. 30.4-2C			
Slope in Degrees		Zone 1	Zone 2	Zone 3	Zone 1,2,3
27 to 45		-0.98	-1.18	-1.18	0.89

Notes

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance $a = 0.1 * LDH$ (Least Horizontal Dimension)
- 4) Based on an area equal to the maximum area of one 39" x 78" PV panel



6005 Alloy Rail

Series 100

Seismic Design ASCE 7-10 Chapter 11 and 13
6005 Alloy Rail



Mean Roof Height 30 to 60 ft

ASCE 7-10 Seismic Design Section 13.6.9

Site Classification	D	Default "D"
Seismic Use Group	II	Table 11.5-1
R_p	=	2.5 Input from Table 13.6-1 ASCE 7-10
A_p	=	1.0 Input from Table 13.6-1 ASCE 7-10
I_p	=	1.0 Input from Table 11.5-1 ASCE 7-10
S_s	=	3.0 Input from USGS Program
S_1	=	1.5 Input from USGS Program
F_a	=	1.0 Site Coefficient Table 11.4-1
F_v	=	1.5 Site Coefficient Table 11.4-2
S_{ms}	=	3.0 ASCE 7-10 Section 11.4.3
S_{m1}	=	2.3 ASCE 7-10 Section 11.4.3
S_{ds}	=	2.0 ASCE 7-10 Section 11.4.3
S_{d1}	=	1.5 ASCE 7-10 Section 11.4.3
z	=	60.5 Height at point of Attachment (ft.)
h	=	60.0 Average Roof Height of Structure (ft.)

$$F_p = 0.97 W_p$$

(Eq. 13.3.1)

$$F_{p \max} = 3.20 W_p$$

$$F_{p \min} = 0.60 W_p$$

$$F_p = \frac{0.4 a_p S_{DS} W_p}{\left(\frac{R_p}{I_p}\right)} \left(1 + 2 \frac{z}{h}\right)$$

$$\text{Use } F_p = 0.97 W_p$$

(Eq. 13.3.2) $F_p = 1.6 S_{DS} I_p W_p$ Max

(Eq. 13.3.3) $F_p = 0.3 S_{DS} I_p W_p$ Min

Vertical Accelerations

$$0.20 (S_{ds}) W_p$$

Notes

- 1) Based on an average dead load of 4 psf the anticipated maximum seismic load is approximately 4 psf with a vertical accelerations of 1.6 psf wind loads govern the design of the PV system.

Series 100

Snow Loads ASCE 7-10 Chapter 7
6005 Alloy Rail



Mean Roof Height 30 to 60 ft

ASCE 7-10 Snow Loads Chapter 7


$$P_f = 0.7 C_e C_t I P_g$$

$$P_s = C_s P_f$$

Snow Load Chart			
Ground Snow P_g	Flat Roof P_f	Sloped Roof P_s Slope < 9/12	Sloped Roof P_s Slope 9/12 to 12/12
10 psf	8	8	8
20 psf	15	15	15
30 psf	23	23	23
40 psf	31	31	31
50 psf	39	39	39
60 psf	46	46	46
70 psf	54	54	54
80 psf	62	62	62
100 psf	77	77	77
120 psf	92	92	92

Calculations for Snow Loads Chapter 7

- $C_e = 1.00$ Exposure Factor (Section 7.3.1)
- $C_t = 1.10$ Thermal Factor (Section 7.3.2)
- $I = 1.00$ Importance Factor (Section 7.3.3)



7-2b: Cold roofs with $C_t=1.1$

Series 100

Rail Properties for 6005 Alloy Rail



Mean Roof Height 30 to 60 ft


Rail Properties for Downward Loads

Section Properties

A	=	0.63	in ²
S	=	0.34	in ³
I	=	0.46	in ⁴

Stresses

F _b	=	21.9	ksi
F _v	=	21.9	ksi
E	=	10000	ksi
M _{allow}	=	7.45	k-in
V _{allow}	=	6.38	k



Rail Section


Rail Properties for Upward Loads

Section Properties

A	=	0.41	in ²
S	=	0.25	in ³
I	=	0.11	in ⁴

Stresses

F _b	=	21.9	ksi
F _v	=	21.9	ksi
E	=	10000	ksi
M _{allow}	=	5.53	k-in
V _{allow}	=	4.16	k



SnapNrack Standard Rail
Keyed 6005 Alloy

Notes

- 1) Rail section properties determined from test data.
- 2) Rail test date performed per guidelines of chapter 17 of the 2015 IBC.
- 3) This report is using 6005 alloy rails

Series 100

PV panel Calculations & Component and Cladding Forces for 6005 Alloy Rail




Mean Roof Height 30 to 60 ft

PV Panel Calculations for 39" x 65" Panel Connections

Panel Dimensions

65" Long Panels

Panel Width	=	39.0 in
Panel Length	=	65.0 in
Panel Weight	=	70.4 #
Panel Area	=	17.6 ft ²



Universal End Clamp


Wind Loading

ASCE 7-10 Component and Cladding


Wind Speed	110 to 190 mph
Exposure Cat.	C
Edge Distance (a)	4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-26.48	-35.41	-35.41	79.00
Min	-87.88	-148.24	-228.13	14.58

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance a = 4 ft based on a 40 ft least width or depth and a mean roof height less than 60 ft.




Adjustable End Clamp




X-Clamp

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamp	-387	-652	-1004	348
Int. Clamp	-774	-1305	N/A	695

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone



Mid Clamp 1



Mid Clamp 2

6005 Alloy Rail

Series 100

PV panel Calculations & Component and Cladding Forces for 6005 Alloy Rail




Mean Roof Height 30 to 60 ft

PV Panel Calculations for 39" x 78" Panel Connections

Panel Dimensions

78" Long Panels

Panel Width	=	39.0 in
Panel Length	=	78.0 in
Panel Weight	=	84.5 #
Panel Area	=	21.1 ft ²




Universal End Clamp

Wind Loading

ASCE 7-10 Component and Cladding

Wind Speed	110 to 190 mph
Exposure Cat.	C
Edge Distance (a)	4 Ft

Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
Max	-26.48	-35.41	-35.41	79.00
Min	-87.88	-148.24	-228.13	14.58




Adjustable End Clamp

X-Clamp

- 1) Roof slopes from 0° to 45°
- 2) Wind loading from 110 mph to 190 mph 3-s Gust.
- 3) Edge distance a = 4 ft based on a 40 ft least width or depth and a mean roof height less than 60 ft.

Maximum Force at Mounting Bracket				
Component and Cladding				
Loading	Zone 1	Zone 2	Zone 3	Zones 1, 2, & 3
End Clamps	-464	-783	-1205	417
Int. Clamp	-928	-1566	N/A	834

- 1) 4 brackets minimum per PV panel to rail connection
- 2) Only one corner of one PV panel may be located in zone 3
- 3) Zone 2 may have multiple panels located in this zone



Mid Clamp 1

Mid Clamp 2

6005 Alloy Rail

Series 100

Lag Bolt Design 2012 NDS for 6005 Alloy Rail



Mean Roof Height 30 to 60 ft

Lag Bolt Calculations for Roof Connection 65" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

65" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	62.7	62.7	62.7	125.4
4 ft	31.3	31.3	31.3	62.7
6 ft	20.9	20.9	20.9	41.8
8 ft	15.7	15.7	15.7	31.3




Lag Bolt Calculations for Roof Connection 78" long Panel

Bolt Connection to Roof Structure

2012 National Design Specifications
5/16" Diameter Lag Bolt 2 1/2" min. embedment
into framing member

Allowable Tension	=	258 #/in
Embedment length	=	1.81 in
Duration of Load	=	1.6 wind
Allowable Tension	=	747.2 #
Allowable Uplift	=	339.6 #

78" Long Panels				
Maximum Wind Uplift (psf) per Span Based On Lag Bolt				
Span	Zone 2	Zone 3	Zone 2E	Zone 3E
2 ft	52.2	52.2	52.2	104.5
4 ft	26.1	26.1	26.1	52.2
6 ft	17.4	17.4	17.4	34.8
8 ft	13.1	13.1	13.1	26.1



Notes

- 1) Only one corner of one PV panel may be located in zone 3E

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 0 to 19 degrees for 6005 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 0 to 19 Degrees	
Wind Load																
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190	
q_h		17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
P_g	P_s	-12.3	-13.5	-14.7	-15.9	-17.2	-18.6	-20.0	-21.4	-22.9	-24.5	-26.1	-29.4	-33.0	-36.7	
Snow Load (psf)	0	0	128	121	115	109	105	100	96	92	89	86	83	77	73	69
	10	8	128	121	115	109	105	100	96	92	89	86	83	77	73	69
	20	15	106	106	106	106	105	100	96	92	89	86	83	77	73	69
	30	23	90	90	90	90	90	90	90	90	89	86	83	77	73	69
	40	31	79	79	79	79	79	79	79	79	79	79	79	77	73	69
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	69
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52
	120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

6005 Alloy Rail

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 19 to 37 degrees for 6005 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angle 20 to 36 Degrees	
Wind Load																
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g P _s	-8.0	-8.8	-9.6	-10.4	-11.2	-12.1	-13.0	-14.0	-14.9	-16.0	-17.0	-19.2	-21.5	-24.0	
	0 0	144	144	144	142	135	129	123	118	114	109	105	98	92	87	
	10 8	132	131	129	128	127	125	123	118	114	109	105	98	92	87	
	20 15	106	106	106	106	106	105	105	104	103	102	101	98	92	87	
	30 23	90	90	90	90	90	90	90	90	90	90	90	90	89	87	86
	40 31	79	79	79	79	79	79	79	79	79	79	79	79	79	79	79
	50 39	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72
	60 46	66	66	66	66	66	66	66	66	66	66	66	66	66	66	66
	70 54	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80 62	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100 77	52	52	52	52	52	52	52	52	52	52	52	52	52	52	52
	120 92	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (Lr or S or R)
 4. D + 0.75L + 0.75(Lr or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(Lr or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

6005 Alloy Rail

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 37 to 45 degrees for 6005 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values																Tilt Angle 37 to 45 Degrees		
Wind Load																		
Vult		110	115	120	125	130	135	140	145	150	155	160	170	180	190			
q_h		17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3			
P_g	P_s	-7.7	-8.4	-9.1	-9.9	-10.7	-11.6	-12.4	-13.3	-14.3	-15.2	-16.2	-18.3	-20.6	-22.9			
Snow Load (psf)	0	0	144	144	144	144	139	133	127	122	117	112	108	101	94	89		
	10	8	132	131	129	128	127	125	124	122	117	112	108	101	94	89		
	20	15	106	106	106	106	106	105	105	104	103	102	101	99	94	89		
	30	23	90	90	90	90	90	90	90	90	90	90	90	89	87	86		
	40	31	79	79	79	79	79	79	79	79	79	79	79	79	79	79	79	
	50	39	72	72	72	72	72	72	72	72	72	72	72	72	72	72	72	
	60	46	66	66	66	66	66	66	66	66	66	66	66	66	66	66	66	
	70	54	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62	
	80	62	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58	
	100	77	52	52	52	52	52	52	52	52	52	52	52	52	52	52	52	
	120	92	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. $D + L$
 3. $D + (Lr \text{ or } S \text{ or } R)$
 4. $D + 0.75L + 0.75(Lr \text{ or } S \text{ or } R)$
 5. $D + (0.6W \text{ or } 0.75L)$
 - 6a. $D + 0.75L + 0.75(0.6W) + 0.75(Lr \text{ or } S \text{ or } R)$
 - 6b. $D + 0.75L + 0.75(0.7E) + 0.75S$
 7. $0.6D + 0.6W$
 8. $0.6D + 0.7E$
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

Series 100

Rail Spans per ASCE 7-10 Loads
Tilt Angle 45 to 60 degrees for 6005 Alloy Rail



Mean Roof Height 30 to 60 ft

Rail Spans (in) Based on Load Combinations for ASCE 7-10 Chapter 2

Load Combinations 3, 5, 6, 7 and Lag Bolt Tension Values															Tilt Angles 46 to 60 Degrees	
Wind Load																
Snow Load (psf)	Vult	110	115	120	125	130	135	140	145	150	155	160	170	180	190	
	q _h	17.9	19.5	21.2	23.1	24.9	26.9	28.9	31.0	33.2	35.4	37.8	42.6	47.8	53.3	
	P _g P _s	-7.3	-8.0	-8.7	-9.5	-10.2	-11.0	-11.9	-12.7	-13.6	-14.5	-15.5	-17.5	-19.6	-21.8	
	0 0	144	144	143	139	136	132	129	125	120	115	111	104	97	91	
	10 8	125	123	122	120	118	116	115	113	111	110	108	104	97	91	
	20 15	105	104	103	102	101	100	99	98	97	96	95	92	90	88	
	30 23	90	90	90	90	90	89	88	87	87	86	85	83	82	80	
	40 31	79	79	79	79	79	79	79	79	79	79	79	78	77	76	74
	50 39	72	72	72	72	72	72	72	72	72	72	72	72	71	70	69
	60 46	66	66	66	66	66	66	66	66	66	66	66	66	66	66	65
	70 54	62	62	62	62	62	62	62	62	62	62	62	62	62	62	62
	80 62	58	58	58	58	58	58	58	58	58	58	58	58	58	58	58
	100 77	52	52	52	52	52	52	52	52	52	52	52	52	52	52	52
	120 92	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48

Notes

- 1) Tables are based on critical rail span for load combinations as specified in chapter 2 of the ASCE 7-10 and lag bolt withdraw values per the 2012 NDS.
- 2) Basic Load Combinations from ASCE 7-10 Section 2.4 Allowable Stress Design.
 1. D
 2. D + L
 3. D + (Lr or S or R)
 4. D + 0.75L + 0.75(Lr or S or R)
 5. D + (0.6W or 0.75L)
 - 6a. D + 0.75L + 0.75(0.6W) + 0.75(Lr or S or R)
 - 6b. D + 0.75L + 0.75(0.7E) + 0.75S
 7. 0.6D + 0.6W
 8. 0.6D + 0.7E
- 3) Edge zone reductions are only required at shaded spans where reduction is 24 inches to a minimum of 32 inches.

6005 Alloy Rail

Series 100

Structural Report and Calculations



Appendix A: ASCE-2010 to 2005 conversion sheet

The 100 Series report's results have been calculated according to the ASCE-2010 guidelines. If the results would rather be examined in terms of the ASCE-2005 codes, the following conversions must be applied for the two codes' results to be of equivalence.

This appendix also applies for converting to different years for IBC codes. For 2006 and 2009 IBC, use the ASCE-2005 codes, and for the 2012 and 2015 IBC, use the ASCE-2010 codes.

Factors specific to this report

- 1) The roof-mounted solar panels are in terms of Risk Category II
- 2) The importance factor for the ASCE-2005 code is $I = 1.0$
- 3) The ASCE-2010 code has no importance factor for the wind loads
- 4) The snow load's importance factor remains the same for both the 2005 and 2010 codes
- 5) Thus, calculations that utilize wind loads are the ONLY ones that need conversions

Velocity Equivalence (mph)

$V_{3\text{-sec}}$ (ASCE7-05)	$V_{\text{ult.}}$ (ASCE7-10)
85	100
90	116
100	129
110	142
120	155
130	168
140	181
150	194


The following velocities listed in the graph refer to some V_{2005} being equal to some V_{2010} . In other words, use the following velocities in accordance with either ASCE-2005 or ASCE-2010.

SNAPNRACK SERIES 100 ON FLASHED L-FEET

FLASHED L-FEET ARE OPTIMIZED FOR QUICK AND ROBUST INSTALLATION ON STANDARD COMPOSITION SHINGLE ROOF SURFACES

FOR OTHER ROOF TYPES STANDOFFS ARE RECOMMENDED

REVISION:



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
 DRAFTER: D Ryan
 APPROVED BY: _____

SCALE: DNS
 DATE: 120113


PART NUMBER: S100 D01

DESCRIPTION: SERIES 100 OVERVIEW, ON FLASHED L-FEET

REV **F**

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

REVISION:



ROOF SHEATHING, UNDERLAYMENT,
AND ROOFING MATERIAL, TYP.

ROOF RAFTER TYP (ROOF ATTACHMENTS
SHOULD ALWAYS BE EMBEDDED INTO ROOF
RAFTERS OR STRUCTURAL MEMBERS SUCH AS
STEEL PURLINS)

SNAPNRACK MODULE
ATTACHMENT
HARDWARE

SNAPNRACK
STANDARD RAIL

SNAPNRACK STANDOFF
WITH CONE FLASHING, TYP.

SnapNrack
PV Mounting Systems

MAINSTREAM ENERGY CORP.
775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
PHONE (805) 528-9705 • FAX (805) 528-9701

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION,
DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF
MAINSTREAM ENERGY CORPORATION.

DESIGNER: G McPheeters
DRAFTER: D Ryan
APPROVED BY: _____

SCALE: DNS
DATE: 120113


PART NUMBER:
S100 D02

DESCRIPTION:
SERIES 100 OVERVIEW, ON STANDOFFS

REV
F


SNAPNRACK SERIES 100 RACKING SYSTEM SHOWN MOUNTED ON STANDOFFS WITH UNIVERSAL END CLAMPS

REVISION:



NOTES:

- STANDARD LAG BOLT SPEC ASSUMES 5/16" LAG BOLTS WITH 2.5" EMBEDMENT IN ROOF STRUCTURAL MEMBERS/RAFTERS
- TORQUE ALL 5/16" HARDWARE TO THE FOLLOWING:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- RAIL CAN MOUNT TO EITHER SIDE OF POST (UPSLOPE vs. DOWNSLOPE)
- FOR UNEVEN ROOF SURFACES, USE UP TO TWO LEVELING SPACERS PER FOOT OR STANDOFF. SEE DRAWING "STANDARD RAIL LEVELING" FOR DETAILS AND LIMITATIONS



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
 DRAFTER: D Ryan
 APPROVED BY: _____

SCALE: DNS
 DATE: 120113

PART NUMBER: S100 D03


DESCRIPTION: SERIES 100 ASSEMBLY DETAILS UEC

REV F


THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

SNAPNRACK SERIES 100 RACKING SYSTEM
 SHOWN MOUNTED ON STANDOFFS
 WITH TOP MOUNT END CLAMP

REVISION:	
F	12/02/15



NOTES:
 - STANDARD LAG BOLT SPEC ASSUMES 5/16" LAG BOLTS WITH 2.5" EMBEDMENT IN ROOF STRUCTURAL MEMBERS/RAFTERS
 - TORQUE ALL 5/16" HARDWARE TO THE FOLLOWING:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
 RAIL CAN MOUNT TO EITHER SIDE OF POST (UPSLOPE vs. DOWNSLOPE)
 - FOR UNEVEN ROOF SURFACES, USE UP TO TWO LEVELING SPACERS PER L FOOT OR STANDOFF. SEE DRAWING "STANDARD RAIL LEVELING" FOR DETAILS AND LIMITATIONS



SYSTEM SHOWN WITH STANDOFF MOUNTING
 COMPATIBLE WITH ALL ROOF TYPES
 USE FLASHED L FOOT FOR FASTER INSTALLATION
 ON COMPOSITION SHINGLE ROOFS



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G.McPheeters
 DRAFTER: D.Ryan
 APPROVED BY: G.McPheeters

SCALE: DNS
 DATE: 12/02/15

PART NUMBER:
S100 D04

DESCRIPTION:
SERIES 100 TILT KITS 0-15 DEG

REV
F

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

SNAPNRACK SERIES 100 RACKING SYSTEM TYPICAL ROOF LAYOUT

REVISION:


NOTES:
 - STANDARD LAG BOLT SPEC ASSUMES 5/16" LAG BOLTS WITH 2.5" EMBEDMENT IN ROOF STRUCTURAL MEMBERS/RAFTERS

- TORQUE ALL 5/16" HARDWARE TO THE FOLLOWING:

- SILVER S.S. 10-16 FT-LBS
- BLACK S.S. 7-9 FT-LBS

RAIL CAN MOUNT TO EITHER SIDE OF POST (UPSLOPE vs. DOWNSLOPE)

- FOR UNEVEN ROOF SURFACES, USE UP TO TWO LEVELING SPACERS PER FOOT OR STANDOFF. SEE DRAWING "STANDARD RAIL LEVELING" FOR DETAILS AND LIMITATIONS



STANDOFFS ARE BOLTED INTO ROOF RAFTERS OR STRUCTURAL MEMBER

**"RAIL SPAN"
DISTANCE BETWEEN
ROOF ATTACHMENTS**

**"RAIL END OVERHANG" (NOT TO EXCEED
34% OF ACCEPTABLE RAIL SPAN)**

REVISION:	



- 1X SNAPRACK LEVELING SPACER

- 2X SNAPRACK LEVELING SPACER


- 1X $\frac{5}{16}$ "-18 X 1" LONG SET SCREW

- 2X $\frac{5}{16}$ "-18 X 1" LONG SET SCREW


USE CARE DURING INSTALLATION TO ENSURE THAT THE SET SCREW IS ROUGHLY CENTERED BETWEEN THE TWO PIECES BEING JOINED




DETAIL A
SCALE 5:8




RAIL HEIGHT = 7.5" ABOVE ROOF SURFACE
7" STANDOFF



RAIL HEIGHT = 8.5" ABOVE ROOF SURFACE
7" STANDOFF



RAIL HEIGHT = 9.5" ABOVE ROOF SURFACE
7" STANDOFF PLUS ONE SPACER ON TOP OF STANDOFF




RAIL HEIGHT = 10.5" ABOVE ROOF SURFACE
7" STANDOFF PLUS TWO SPACERS ON TOP OF STANDOFF

STANDARD SERIES 100 ATTACHMENTS FEATURE 3" OF VERTICAL ADJUSTABILITY ON ALL MOUNTING POINTS WITH THE USE OF 1" LEVELING SPACERS


THE FIRST INCH OF ADJUSTABILITY IS ACCOMPLISHED WITH SLIDING FEATURES BUILT INTO BOTH L FOOT AND STANDOFF CLAMP COMPONENTS

FOR AN ADDITIONAL INCH OF HEIGHT ADJUSTMENT, ADD ONE LEVELING SPACER. USE OF SINGLE LEVELING SPACER NOT TO EXCEED 30% OF ATTACHMENT POINTS ON L-FEET OR 10" STANDOFFS.


FOR A SECOND ADDITIONAL INCH OF HEIGHT ADJUSTMENT, ADD ANOTHER LEVELING SPACER. USE OF TWO LEVELING SPACERS NOT TO EXCEED 10% OF ATTACHMENT POINTS ON L-FEET OR 10" STANDOFFS.




RAIL HEIGHT = 3.4" ABOVE ROOF SURFACE
ONE L FOOT



RAIL HEIGHT = 4.4" ABOVE ROOF SURFACE
ONE L FOOT





RAIL HEIGHT = 5.4" ABOVE ROOF SURFACE
ONE L FOOT PLUS ONE SPACER UNDER L FOOT





RAIL HEIGHT = 6.4" ABOVE ROOF SURFACE
ONE L FOOT PLUS TWO SPACERS UNDER L FOOT


REVISION:	

- 1X SNAPNRACK LEVELING SPACER




- 2X SNAPNRACK LEVELING SPACER

- 2X $\frac{5}{16}$ "-18 X 1" LONG SET SCREW




USE CARE DURING INSTALLATION TO ENSURE THAT THE SET SCREW IS ROUGHLY CENTERED BETWEEN THE TWO PIECES BEING JOINED




RAIL HEIGHT =12.2"
 ABOVE ROOF SURFACE
 12" HD STANDOFF



RAIL HEIGHT =13.2"
 ABOVE ROOF SURFACE
 12" HD STANDOFF



RAIL HEIGHT =14.2"
 ABOVE ROOF SURFACE
 12" HD STANDOFF
 PLUS ONE SPACER ON
 TOP OF STANDOFF



RAIL HEIGHT =15.2"
 ABOVE ROOF SURFACE
 12" HD STANDOFF
 PLUS TWO SPACERS
 ON TOP OF STANDOFF

STANDARD SERIES 100 ATTACHMENTS FEATURE 3" OF VERTICAL ADJUSTABILITY ON ALL MOUNTING POINTS WITH THE USE OF 1" LEVELING SPACERS

THE FIRST INCH OF ADJUSTABILITY IS ACCOMPLISHED WITH SLIDING FEATURES BUILT INTO BOTH L FOOT AND STANDOFF CLAMP COMPONENTS

FOR AN ADDITIONAL INCH OF HEIGHT ADJUSTMENT, ADD ONE LEVELING SPACER. USE OF SINGLE LEVELING SPACER NOT TO EXCEED 30% OF ATTACHMENT POINTS.

FOR A SECOND ADDITIONAL INCH OF HEIGHT ADJUSTMENT, ADD ANOTHER LEVELING SPACER. USE OF TWO LEVELING SPACERS NOT TO EXCEED 10% OF ATTACHMENT POINTS.

THE LIMITS ABOVE APPLY WHEN YOU ARE AT THE MAXIMUM STANDOFF HEIGHT DEPENDING ON THE STANDOFF BASE BEING USED. FOR HD STANDOFFS ON HD STANDOFF BASES, THE MAXIMUM STANDOFF HEIGHT (BEFORE APPLYING THE LIMITATIONS ABOVE) IS 12".


USE TILT KIT OPTION FOR INSTALLATIONS THAT REQUIRE MODULES TO BE TILTED ABOVE THE EXISTING ROOF SLOPE

LOW TILT SYSTEM SHOWN IS DESIGNED FOR TILT ANGLES FROM 0 TO 15 DEGREES ABOVE ROOF SURFACE


REVISION:	
F	12/02/15

USE OF ANTI-SEIZE ON TILT HARDWARE IS RECOMMENDED (PARTICULARLY FOR STAINLESS TO STAINLESS HARDWARE) TO PREVENT GALLING

MAX. REAR STANDOFF HEIGHT: 18 INCHES



USE SHORTEST POSSIBLE FRONT STANDOFF TO MEET FLASHING REQUIREMENTS




SNAPNRACK STANDOFF CLAMP

5/16" X 2" S.S. BOLT WITH SPLIT LOCK WASHER

SNAPNRACK MID CLAMP ASSEMBLY

SNAPNRACK RAIL STANDARD




SNAPNRACK CHANNEL NUT

SNAPNRACK L FOOT ALL-PURPOSE OR L FOOT COMPOSITION

5/16" FLANGE NUT, USE ANTI-SEIZE COMPOUND TO PREVENT STAINLESS TO STAINLESS GALLING

STANDOFF ASSEMBLY (THIS TILT-UP CONFIGURATION IS ALSO COMPATIBLE WITH THE FLASHED L FOOT MOUNTING OPTION)



NOTES:

- TORQUE 5/16" HARDWARE TO THE FOLLOWING UNLESS OTHERWISE NOTED:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- REFER TO ENGINEERING CHARTS FOR RAIL SPAN BASED ON MODULE TILT ANGLE, WIND SPEED, AND SNOW LOAD
- FOR HIGHER TILT APPLICATIONS SEE "SERIES 100 TILT KIT 10-45 DEG"



MAINSTREAM ENERGY CORP.
775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
DRAFTER: D Ryan
APPROVED BY: G McPheeters

SCALE: DNS
DATE: 12/02/15

PART NUMBER: S100 D08

DESCRIPTION: SERIES 100 TILT KITS 0-15 DEG

REV F

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.



USE TILT KIT OPTION FOR INSTALLATIONS THAT REQUIRE MODULES TO BE TILTED ABOVE THE EXISTING ROOF SLOPE

SYSTEM SHOWN IS DESIGNED FOR TILT ANGLES FROM 10 TO 45 DEGREES ABOVE ROOF SURFACE

USE OF ANTI-SEIZE ON TILT HARDWARE IS RECOMMENDED (PARTICULARLY FOR STAINLESS TO STAINLESS HARDWARE)

REFER TO S100 TKT SERIES 170 TILT KIT TOOL FOR A SIMPLE TOOL THAT DRAMATICALLY SIMPLIFIES TILT KIT INSTALLATION BY SUPPORTING THE UPPER RAIL AHEAD OF MODULE INSTALLATION


REVISION:



$\frac{5}{16}$ " X 2" (OR 1.5") S.S. BOLT WITH SPLIT LOCK WASHER

SNAPNRACK STANDOFF CLAMP

SNAPNRACK CHANNEL NUTS, TORQUE TO 10-16 FT-LBS WHEN USING WEEBS. WHEN USING SNAPNRACK BONDING CHANNEL NUTS, TORQUE TO 14-16 FT-LBS. WEEBS ARE NOT REQUIRED WITH BONDING CHANNEL NUTS.



SNAPNRACK L FOOT ALL-PURPOSE OR L FOOT COMPOSITION

$\frac{5}{16}$ " FLANGE NUT

$\frac{5}{16}$ " X 1" (OR 1.25") S.S. BOLT WITH SPLIT LOCK WASHER

STANDOFF ASSEMBLY (THIS CONFIGURATION ALSO COMPATIBLE WITH FLASHED L FOOT MOUNTING)

NOTES:


- TORQUE $\frac{5}{16}$ " HARDWARE TO THE FOLLOWING UNLESS OTHERWISE NOTED:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- REFER TO ENGINEERING CHARTS FOR RAIL SPAN BASED ON MODULE TILT ANGLE, WIND SPEED, AND NOW LOAD
- BACK SUPPORT "LEG" IS FABRICATED FROM A SCRAP OF RAIL. CALCULATE REQUIRED TILT LEG LENGTH AND CUT RAIL TO LENGTH
- FOR LOWER TILT APPLICATIONS SEE "SERIES 100 TILT KIT 0-15 DEG"
- SNAPNRACK RAIL COVER CAN BE USED TO COVER CHANNEL IN REAR TILT LEG

USE TILT KIT OPTION FOR INSTALLATIONS THAT REQUIRE MODULES TO BE TILTED ABOVE THE EXISTING ROOF SLOPE

SYSTEM SHOWN IS DESIGNED FOR TILT ANGLES FROM 10 TO 45 DEGREES ABOVE ROOF SURFACE

USE OF ANTI-SEIZE ON TILT HARDWARE IS RECOMMENDED (PARTICULARLY FOR STAINLESS TO STAINLESS HARDWARE)

REFER TO S100 TKT SERIES 170 TILT KIT TOOL FOR A SIMPLE TOOL THAT DRAMATICALLY SIMPLIFIES TILT KIT INSTALLATION BY SUPPORTING THE UPPER RAIL AHEAD OF MODULE INSTALLATION



REVISION:	
---	---
---	---
---	---
---	---
---	---

MAX LENGTH: 48" WITH STANDARD ENGINEERING

SNAPRACK RAIL STANDARD

SNAPRACK MID CLAMP ASSEMBLY

CUT REAR TILT LEG FROM SCRAP OF STANDARD RAIL

SNAPRACK CHANNEL NUTS, TORQUE TO 10-16 FT-LBS WHEN USING WEEBS. WHEN USING SNAPRACK BONDING CHANNEL NUTS, TORQUE TO 14-16 FT-LBS. WEEBS ARE NOT REQUIRED WITH BONDING CHANNEL NUTS.

SNAPRACK L-FOOT ALL-PURPOSE OR L-FOOT COMPOSITION

$\frac{5}{16}$ " X 1" (OR 1.25") S.S. BOLT WITH SPLIT LOCK WASHER

NOTES:

- TORQUE $\frac{5}{16}$ " HARDWARE TO THE FOLLOWING UNLESS OTHERWISE NOTED:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- REFER TO ENGINEERING CHARTS FOR RAIL SPAN BASED ON MODULE TILT ANGLE, WIND SPEED, AND SNOW LOAD
- BACK SUPPORT "LEG" IS FABRICATED FROM A SCRAP OF RAIL. CALCULATE REQUIRED TILT LEG LENGTH. USE WEEB GROUNDING WASHERS AT JOINTS BETWEEN L-FEET AND SNAPRACK STANDARD RAIL SCRAP PIECE
- FOR LOWER TILT APPLICATIONS SEE "SERIES 100 TILT KIT 0-15 DEG"
- SNAPRACK RAIL COVER CAN BE USED TO COVER CHANNEL IN REAR TILT LEG

SnapRack
PV Mounting Systems

MAINSTREAM ENERGY CORP.
775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
PHONE (805) 528-9705 • FAX (805) 528-9701

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

DESIGNER: G McPheeters
DRAFTER: D Ryan
APPROVED BY: _____

SCALE: DNS
DATE: 120113

PART NUMBER: S100 D10

DESCRIPTION: SERIES 100 TILT KITS 10-45 DEG WITH L FOOT MOUNT

REV **F**


USE TILT KIT OPTION FOR INSTALLATIONS THAT REQUIRE MODULES TO BE TILTED ABOVE THE EXISTING ROOF SLOPE

SYSTEM SHOWN IS DESIGNED FOR TILT ANGLES FROM 10 TO 45 DEGREES ABOVE ROOF SURFACE ON STANDING SEAM METAL ROOFS


USE OF ANTI-SEIZE ON TILT HARDWARE IS RECOMMENDED (PARTICULARLY FOR STAINLESS TO STAINLESS HARDWARE)

REFER TO S100 TKT SERIES 170 TILT KIT TOOL FOR A SIMPLE TOOL THAT DRAMATICALLY SIMPLIFIES TILT KIT INSTALLATION BY SUPPORTING THE UPPER RAIL AHEAD OF MODULE INSTALLATION

REVISION:




SNAPRACK CHANNEL NUTS, TORQUE TO 10-16 FT-LBS WHEN USING WEEBS. WHEN USING SNAPRACK BONDING CHANNEL NUTS, TORQUE TO 14-16 FT-LBS. WEEBS ARE NOT REQUIRED WITH BONDING CHANNEL NUTS.




CUT REAR TILT LEG FROM SCRAP OF STANDARD RAIL

SNAPRACK SEAM CLAMP WIDE OR STANDARD BASE



NOTES:

- TORQUE 5/16" HARDWARE TO THE FOLLOWING UNLESS OTHERWISE NOTED:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- REFER TO ENGINEERING CHARTS FOR RAIL SPAN BASED ON MODULE TILT ANGLE, WIND SPEED, AND SNOW LOAD
- BACK SUPPORT "LEG" IS FABRICATED FROM A SCRAP OF RAIL. CALCULATE REQUIRED TILT LEG LENGTH AND CUT RAIL TO LENGTH
- FOR LOWER TILT APPLICATIONS SEE "SERIES 100 TILT KIT 0-15 DEG"
- SNAPRACK RAIL COVER CAN BE USED TO COVER CHANNEL IN REAR TILT LEG



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

DESIGNER: G McPheeters

DRAFTER: D Ryan

APPROVED BY: _____

SCALE: DNS


DATE: 042514

PART NUMBER: S100 D11


DESCRIPTION: SERIES 100 TILT KITS 10-45 DEG SEAM CLAMP MOUNT

REV **F**


REVISION:




STEP 1:
 REMOVE TILE AND IDENTIFY
 RAFTER LOCATION WITH A
 PILOT DRILL. MOUNT STANDOFF
 ASSEMBLY TO ROOF SHEATHING
 WITH A 5/16IN LAG BOLT
 MINIMUM 2.5" EMBEDMENT TYP.
 BE SURE LAG BOLT IS FULLY
 SEATED




STEP 2:
 SLIDE FLASHING OVER POST,
 UNDER UPPER LAYER OF TILE




STEP 3:
 USE CORING BIT OR OTHER METHOD TO DRILL CLEARANCE HOLE
 IN TILE TO ALLOW IT TO BE REPLACED IN ORIGINAL LOCATION




STEP 4:
 REPLACE TILES
 SEAL TOP OF CONE FLASHING WITH
 RUBBER RAIN COLLAR, ALUMINUM
 TAPE, OR ALTERNATE METHOD







STEP 1:
 REMOVE TILE AND IDENTIFY
 RAFTER LOCATION WITH A
 PILOT DRILL. MOUNT STANDOFF
 ASSEMBLY TO ROOF SHEATHING
 WITH A 5/16IN LAG BOLT
 MINIMUM 2IN EMBEDMENT TYP.
 BE SURE LAG BOLT IS FULLY
 SEATED



STEP 2:
 SLIDE FLASHING OVER POST,
 UNDER UPPER LAYER OF TILE,
 AND FORM FLASHING TO
 MATCH CONTOUR OF TILES



STEP 3:
 USE CORING BIT TO
 DRILL 2.5" HOLE IN
 TILE TO ALLOW IT
 TO BE REPLACED IN
 ORIGINAL LOCATION





REVISION:

REVISION:	

NOTES:

- 5/16" LAG BOLTS MUST EMBED 2.5" INTO ROOF STRUCTURAL MEMBERS/RAFTERS
- TORQUE ALL 5/16" HARDWARE TO THE FOLLOWING:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- RAILS CAN MOUNT TO EITHER SIDE OF L FOOT (UPSLOPE VS DOWNSLOPE)



FLASHED L FOOT MOUNTING POINT FOR USE ON COMPOSITION ROOF SURFACES WITH LOW TO MODERATE TILT

RAILS CAN BE LEVELED UP TO 3" USING UP TO TWO LEVELING SPACERS AS SHOWN IN "SERIES 100 RAIL LEVELING"



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
 DRAFTER: D Ryan
 APPROVED BY: _____


SCALE: DNS
 DATE: 120113

PART NUMBER: S100 PEN D01

DESCRIPTION: PEN DETAIL 01, FLASHED L FOOT TO RAFTER

REV **F**

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.




NOTES:

- 5/16" LAG BOLTS MUST EMBED 2.5" INTO ROOF STRUCTURAL MEMBERS/RAFTERS
- TORQUE ALL 5/16" HARDWARE TO THE FOLLOWING:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- RAILS CAN MOUNT TO EITHER SIDE OF POST (UPSLOPE VS. DOWNSLOPE)
- RAILS CAN BE LEVELED UP TO 3" USING UP TO TWO LEVELING SPACERS AS SHOWN IN "SERIES 100 RAIL LEVELING"
- * A Poured Sealant-style Flashing may be used with SnapNrack Standoffs as an alternative to a typical cone flashing when installed per manufacturer's instructions on low-slope roof surfaces

REVISION:

FLASH POST WITH STANDARD GALVANIZED STEEL OR DEAD SOFT ALUMINUM ROOF FLASHING FOR 1" DIAMETER VENT PIPE*



COMPLETE INSTALLATION (SHOWN WITH FLASHING IN PLACE)

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

REVISION:	
---	---
---	---
---	---
---	---
---	---

NOTES:

- TEK SCREWS MUST EMBED IN ROOF STRUCTURAL MEMBERS/PURLINS


- TORQUE ALL $\frac{5}{16}$ " HARDWARE TO THE FOLLOWING:

- SILVER S.S. 10-16 FT-LBS
- BLACK S.S. 7-9 FT-LBS


- RAILS CAN MOUNT TO EITHER SIDE OF POST (UPSLOPE VS. DOWNSLOPE)

- RAILS CAN BE LEVELED UP TO 3" USING UP TO TWO LEVELING SPACERS AS SHOWN IN "SERIES 100 RAIL LEVELING"

* A Poured Sealant-Style Flashing May Be Used With SnapRack Standoffs As An Alternative To A Typical Cone Flashing When Installed Per Manufacturer's Instructions On Low-Slope Roof Surfaces




FLASH POST WITH STANDARD GALVANIZED STEEL ROOF FLASHING FOR 1" DIAMETER VENT PIPE *



	MAINSTREAM ENERGY CORP. 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA PHONE (805) 528-9705 • FAX (805) 528-9701	DESIGNER: <u>G McPheeters</u>	SCALE: <u>DNS</u>	PART NUMBER: <u>S100 PEN D03</u>	DESCRIPTION: <u>PEN DETAIL 03, STANDOFF TO PURLIN</u>	REV <u>F</u>
		DRAFTER: <u>D Ryan</u>	DATE: <u>120113</u>			
<small>THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.</small>		APPROVED BY: _____				

CAMMING SEAM CLAMPS ARE SPECIFIED WITH A BLACK OXIDE STAINLESS STEEL BOLT. IT IS IMPORTANT TO USE THE PROVIDED BOLT AND TO TIGHTEN TO 16 FT-LBS FOR FULL LOAD CAPABILITY

REVISION:	
---	---
---	---
---	---
---	---
---	---




TO DETERMINE BOLT SIZE ADD 1.17" TO THE "STACK" ON TOP OF THE CLAMP (X) AND ROUND UP TO NEAREST 1/4" BOLT SIZE


THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

USE THE SNAPRACK CORRUGATED ROOF BLOCK TO STRADDLE THE RAISED PORTIONS OF CORRUGATED METAL ROOFING MATERIALS. THIS ALLOWS AN L FOOT TO BE MOUNTED WITH THE PENETRATION AT THE HIGH POINT OF THE ROOFING MATERIAL WITHOUT CRUSHING THE ROOF PROFILE. SHOWN WITH A TEK SCREW ATTACHMENT TYPICAL OF A METAL PURLIN STRUCTURE, BUT THE SYSTEM WORKS WELL WITH A LAG BOLT INTO A WOOD RAFTER AS WELL. BE SURE TO USE PROPER SEALANT TO SEAL UP THE HOLE IN THE METAL ROOFING MATERIAL

REVISION:



PART DIMENSIONS



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
 DRAFTER: D Ryan
 APPROVED BY: _____

SCALE: DNS
 DATE: 120113

PART NUMBER:
 S100 PEN D05

DESCRIPTION:
 PEN DETAIL 05, CORRUGATED ROOF BLOCK

REV
F



THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

REVISION:	
---	---
---	---
---	---
---	---
---	---

HANGER BOLT CLAMPS HAVE BEEN DESIGNED FOR USE WITH STANDARD $\frac{3}{8}$ " STAINLESS HANGER BOLTS. THEY ARE COMPATIBLE WITH ANY $\frac{3}{8}$ " STAINLESS BOLT OR THREADED ROD.

THE CLAMPS ARE 1.5" TALL AND ENGINEERED TO HAVE A MINIMUM OF 1.25" OF THREAD IN THE CLAMP AT ALL TIMES. MAXIMUM DESIGN LOAD IS 1,000 LBS (AXIAL) OR 250 LBS IF A FACTOR OF SAFETY OF 4 IS APPLIED.



- TORQUE ALL $\frac{5}{16}$ " HARDWARE TO THE FOLLOWING:
- SILVER S.S. 10-16 FT-LBS
- BLACK S.S. 7-9 FT-LBS



REVISION:	
F	12/02/15

NOTES:

- WOOD SCREWS MUST EMBED IN ROOF STRUCTURAL MEMBERS/JOISTS. TYPICAL DESIGN UPLIFT LOAD REQUIREMENT IS 340 LBS PER ATTACHMENT
- TORQUE ALL $\frac{5}{16}$ " HARDWARE TO THE FOLLOWING:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- RAILS CAN MOUNT TO EITHER SIDE OF POST (UPSLOPE VS. DOWNSLOPE)
- RAILS CAN BE LEVELED UP TO 3" USING UP TO TWO LEVELING SPACERS AS SHOWN IN "SERIES 100 RAIL LEVELING"



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
 DRAFTER: D Ryan
 APPROVED BY: G McPheeters

SCALE: DNS
 DATE: 12/02/15

PART NUMBER: S100 PEN D07

DESCRIPTION: PEN DETAIL 07, STANDOFF TO JOIST

REV F



THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

REVISION:	
F	12/02/15

NOTES:

- LAG BOLTS MUST EMBED IN ROOF STRUCTURAL MEMBERS/RAFTERS
- TORQUE ALL $\frac{5}{16}$ " HARDWARE TO THE FOLLOWING:
 - SILVER S.S. 10-16 FT-LBS
 - BLACK S.S. 7-9 FT-LBS
- RAILS CAN MOUNT TO EITHER SIDE OF POST (UPSLOPE VS. DOWNSLOPE)
- RAILS CAN BE LEVELED UP TO 3" USING UP TO TWO LEVELING SPACERS AS SHOWN IN DRAWING S100 D07 "SERIES 100 HD STANDOFF LEVELING"

FLASH POST WITH STANDARD GALVANIZED STEEL OR DEAD SOFT ALUMINUM ROOF FLASHING FOR 1" DIAMETER VENT PIPE. A Poured SEALANT-STYLE FLASHING MAY BE USED WITH SNAPNRACK STANDOFFS AS AN ALTERNATIVE TO A TYPICAL CONE FLASHING WHEN INSTALLED PER MANUFACTURER'S INSTRUCTIONS ON LOW-SLOPE ROOF SURFACES



SNAPNRACK STANDOFF MOUNTING POINT FOR USE ON ALL ROOF SURFACES

HD STANDOFFS ARE OFTEN USED WITH FOAM ROOF INSULATION



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
 DRAFTER: D Ryan
 APPROVED BY: G McPheeters

SCALE: DNS
 DATE: 12/02/15

PART NUMBER: S100 PEN D08

DESCRIPTION: PEN DETAIL 08, HD STANDOFF

REV **F**

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.

STEP 1:
DRILL 3/16" PILOT HOLE IN
RAFTER. ENSURE AREA
SURROUNDING HOLE IS
FREE FROM METAL
SHAVINGS AND DEBRIS.


STEP 2:
ATTACH METAL ROOF BASE
TO RAFTER WITH 5/16IN
LAG BOLT. TORQUE TO
10-16 FT LBS.

STEP 3:
THREAD METAL ROOF BASE
CAP ONTO METAL ROOF
BASE BOTTOM. TAKE CARE
TO ENSURE THE BASE DOES
NOT TWIST WHEN CAP IS
TIGHTENED. ENSURE CAP IS
FULLY SEATED TO BASE.

STEP 4:
ATTACH L-FOOT TO STUD IN
METAL ROOF BASE CAP
WITH FLANGE NUT.

5/16 -18 X 1" (OR 1.25") S.S.
BOLT AND SPLIT WASHER

REVISION:	



STEP 1:
 DRILL 3/16" PILOT HOLE
 IN PURLIN. ENSURE AREA
 SURROUNDING HOLE IS
 FREE FROM METAL
 SHAVINGS AND DEBRIS.

STEP 2:
 ATTACH METAL ROOF
 BASE TO PURLIN WITH 1/4"
 TEK OR EQUIVALENT SELF
 DRILLING FASTENER.
 TORQUE TO
 MANUFACTURER
 SPECIFICATIONS.

STEP 3:
 THREAD METAL ROOF
 BASE CAP ONTO METAL
 ROOF BASE BOTTOM.
 TAKE CARE TO ENSURE
 THE BASE DOES NOT
 TWIST WHEN CAP IS
 TIGHTENED. ENSURE CAP
 IS FULLY SEATED TO
 BASE.

STEP 4:
 ATTACH L-FOOT TO STUD
 IN METAL ROOF BASE CAP
 WITH FLANGE NUT.

5/16-18 STAINLESS FLANGE
 NUT TORQUE 10-16 FT-LBS

1/4-20 TEK OR EQUIVALENT
 SELF DRILLING FASTENER.
 TORQUE TO MANUFACTURER
 SPECIFICATIONS

METAL ROOF DECK

SNAPNRACK METAL
 ROOF BASE BOTTOM


SNAPNRACK STANDARD RAIL

SNAPNRACK L-FOOT

SNAPNRACK METAL
 ROOF BASE CAP

STEEL PURLIN, TYPICAL

REVISION:



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: GMcPHEETERS
 DRAFTER: DRyan
 APPROVED BY: _____

SCALE: DNS
 DATE: 120113

PART NUMBER:
 S100 PEN D10

DESCRIPTION: PEN DETAIL 10, METAL ROOF BASE TO PURLIN

REV
F

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.


STEP 1:
DRILL 3/16" PILOT HOLE IN RAFTER. ENSURE AREA SURROUNDING HOLE IS FREE FROM METAL SHAVINGS AND DEBRIS.

STEP 2:
ATTACH METAL ROOF BASE TO RAFTER WITH 5/16IN LAG BOLT.
TORQUE TO 10-16 FT LBS.

STEP 3:
THREAD METAL ROOF BASE CAP ONTO METAL ROOF BASE BOTTOM.
TAKE CARE TO ENSURE THE BASE DOES NOT TWIST WHEN CAP IS TIGHTENED. ENSURE CAP IS FULLY SEATED TO BASE.

STEP 4:
ATTACH STANDOFF TO METAL ROOF BASE CAP. STANDOFFS UP TO 7" IN LENGTH MAY BE USED.

REVISION:	
---	---
---	---
---	---
---	---
---	---



	MAINSTREAM ENERGY CORP. 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA PHONE (805) 528-9705 • FAX (805) 528-9701	DESIGNER: <u>GMcPHEETERS</u>	SCALE: <u>DNS</u>	PART NUMBER: <u>S100 PEN D11</u>	DESCRIPTION: PEN DETAIL 11, METAL ROOF BASE WITH STANDOFF TO RAFTER	REV
		DRAFTER: <u>DRyan</u>	DATE: <u>120113</u>			F
<small>THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.</small>		APPROVED BY: _____				



STEP 1:
DRILL 3/16" PILOT HOLE IN PURLIN. ENSURE AREA SURROUNDING HOLE IS FREE FROM METAL SHAVINGS AND DEBRIS.

STEP 2:
ATTACH METAL ROOF BASE TO PURLIN WITH 1/4" TEK OR EQUIVALENT SELF DRILLING FASTENER. TORQUE TO MANUFACTURER SPECIFICATIONS.

STEP 3:
THREAD METAL ROOF BASE CAP ONTO METAL ROOF BASE BOTTOM. TAKE CARE TO ENSURE THE BASE DOES NOT TWIST WHEN CAP IS TIGHTENED. ENSURE CAP IS FULLY SEATED TO BASE.

STEP 4:
ATTACH STANDOFF TO METAL ROOF BASE CAP. STANDOFFS UP TO 7" IN LENGTH MAY BE USED.




REVISION:



NOTES:

- INSTALLATIONS OF SNAPNRACK TILE HOOKS ARE LIMITED TO A MAXIMUM WIND SPEED OF 120MPH (IBC2012) AND MAXIMUM ATTACHMENT SPAN OF 6FT.
- 5/16" LAG BOLTS MUST EMBED 2.5" INTO ROOF STRUCTURAL MEMBERS / RAFTERS
- TORQUE ALL 5/16" HARDWARE TO 10-16 FT-LBS
- RAILS CAN MOUNT TO EITHER SIDE OF TILE HOOK (UPSLOPE VS. DOWNSLOPE)
- RAILS CAN BE LEVELED UP TO 1.25" USING THE SLOT IN THE TILE HOOK



REVISION:




COMPLETED INSTALLATION

THE SNAPNRACK S TILE ROOF HOOK OFFERS A QUICK, COST EFFECTIVE SOLUTION FOR MOUNTING ON S-TILE ROOFTOPS. THE SIMPLE DESIGN HAS BEEN OPTIMIZED FOR SNAPNRACK AND THE HOOKS ARE BUILT INTO OUR SYSTEM ENGINEERING AND UL LISTING. ONCE A TILE HAS BEEN REMOVED, THE BASE PIECE IS BOLTED DOWN TO A RAFTER. ONCE THE BASE IS IN PLACE, THE TILE HOOK ARM IS INSERTED INTO THE HOOK FEATURE IN THE BASE AND ROTATED DOWN TOWARDS THE TRACK SO THAT THE BONDING CHANNEL NUT SNAPS INTO THE CHANNEL. ONCE THE ARM IS ATTACHED TO THE BASE, SLIDE IT ON THE BASE SO THAT IT ALIGNS WITH A LOW POINT IN THE S-TILES, SIMPLY TIGHTEN IT IN PLACE AND REPLACE THE TILE THAT WAS REMOVED. WITH SOME TYPES OF TILE YOU MAY WANT TO DO A LITTLE GRINDING TO HELP EVERYTHING FIT BACK TOGETHER SMOOTHLY, BUT IN MANY CASES NO GRINDING IS REQUIRED.

INSTALLATIONS OF SNAPNRACK S TILE ROOF HOOKS ARE LIMITED TO A MAXIMUM WIND SPEED OF 120MPH (IBC 2012) AND A MAXIMUM ATTACHMENT SPAN OF 6FT.



REVISION:



MAINSTREAM ENERGY CORP.
 775 FIERO LANE, SUITE 200 • SAN LUIS OBISPO, CA 93401 USA
 PHONE (805) 528-9705 • FAX (805) 528-9701

DESIGNER: G McPheeters
 DRAFTER: D Ryan
 APPROVED BY: _____

SCALE: DNS
 DATE: 031613

PART NUMBER: S100 PEN D14

DESCRIPTION: SERIES 100 PEN DETAIL 14, S-TILE HOOK

REV F

THE INFORMATION IN THIS DRAWING IS CONFIDENTIAL AND PROPRIETARY. ANY REPRODUCTION, DISCLOSURE, OR USE THEREOF IS PROHIBITED WITHOUT THE WRITTEN CONSENT OF MAINSTREAM ENERGY CORPORATION.