

Dyan-615.8135

ELECTRICAL PERMIT

City of Portland, Me.




To the Chief Electrical Inspector, Portland Maine:
 The undersigned hereby applies for a permit to make electrical installations
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,
 National Electrical Code and the following specifications:

Date 11.19.08
 Permit # 2008-4854
 CBL# 340.M.035

LOCATION: 11 Arthur St METER MAKE & # _____
 CMP ACCOUNT # 441-012-0257-012 OWNER Jim + Dyan Albano
 TENANT Jim + Dyan Albano PHONE # 207-878-9063

TOTAL EACH FEE

OUTLETS	25	Receptacles	20	Switches	7	Smoke Detector	.20	10.40
FIXTURES	17	Incandescent		Fluorescent		Strips	.20	3.40
SERVICES		Overhead		Underground		TTL AMPS <800	15.00	
		Overhead		Underground		>800	25.00	
Temporary Service		Overhead		Underground		TTL AMPS	25.00	
							25.00	
METERS		(number of)					1.00	
MOTORS		(number of)					2.00	
RESID/COM		Electric units					1.00	
HEATING		oil/gas units		Interior		Exterior	5.00	
APPLIANCES		Ranges		Cook Tops		Wall Ovens	2.00	
		Insta-Hot		Water heaters	4	Fans	2.00	8.00
		Dryers		Disposals		Dishwasher	2.00	
		Compactors		Spa		Washing Machine	2.00	
		Others (denote)					2.00	
MISC. (number of)		Air Cond/win					3.00	
		Air Cond/cent				Pools	10.00	
		HVAC		EMS	2	Thermostat	5.00	10.00
		Signs					10.00	
		Alarms/res					5.00	
		Alarms/com					15.00	
		Heavy Duty(CRKT)					2.00	
		Circus/Carnv					25.00	
		Alterations					5.00	
		Fire Repairs					15.00	
		E Lights					1.00	
		E Generators					20.00	
PANELS	1	Service		Remote		Main	4.00	
TRANSFORMER		0-25 Kva					5.00	
		25-200 Kva					8.00	
		Over 200 Kva					10.00	
TOTAL AMOUNT DUE								
MINIMUM FEE/COMMERCIAL 55.00							MINIMUM FEE	45.00



CONTRACTORS NAME Baldrige Electric MASTER LIC. # LM50017185
 ADDRESS (Josh) LIMITED LIC. # _____
 TELEPHONE 207-590-2465

SIGNATURE OF CONTRACTOR Dyan Albano

ELECTRICAL INSTALLATIONS

Permit Number 20084854

Location 11 Oaklawn St.

Owner Dyer Alderson

Date of Permit 11-19-08

Final Inspection _____

By Inspector _____

INSPECTION: Service _____ by _____
Service called in _____
Closing-in _____ by _____

PROGRESS INSPECTIONS: _____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____
_____ / _____ / _____

DATE:	REMARKS:
3-6-09	OK - rough-in electrical (Note: need GFI for sub-pump) <i>by</i>