

3/18/02 Spoke with Steve from Paul White who will submit a detail of the Truss built w/wood as the steel truss for the awning is not available. JB  
3/18/02 Wood Truss design submitted - called for more detail. JB

3/19/02 Discussed w/ Mark (Doten's) 233-9005 can not approve as submitted. Need Design Pro for Truss criteria & fastening & weight bearing. Will contact if New plans. JB OK

4/25/02 - Checked fasteners & brackets of awning OK -  
New plans from structural engineer furnished while inspecting. OK to close

CBC # 342-B-1

Permit # 02-0099