



Portland Fire Department Monthly School Inspection

Name: <u>PATHS</u>	Address: <u>196 ALLEN AVE</u>
Principal:	Emergency contact #: <u>STEVE THOMES</u> <u>874-8165</u>
Date inspected: <u>1-31-11</u>	Inspector: <u>LT D. LORD</u>
	Time in: <u>1310</u> Time out:

Fire Drills Conducted Yes No Date of last drill: Nov 15th

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<u>X</u>		
Exit signs & Emer lights properly lit	<u>X</u>		

Fire Alarm System	Pass	Fail	Notes:
Panel clear, accessible, operational	<u>X</u>		

Fire Extinguishers	Pass	Fail	Notes:
Extinguishers full & tagged annually	<u>X</u>		
Extinguishers accessible	<u>X</u>		

Heating System	Pass	Fail	Notes:
Boiler room clear of all combustibles	<u>X</u>		
Boiler room properly rated/protected	<u>X</u>		

Electrical system	Pass	Fail	Notes:
Extension cord use vs. permanent	<u>X</u>		
Electrical panels clear & accessible	<u>X</u>		
Electrical circuits clearly identified	<u>X</u>		

Sprinkler System	Pass	Fail	Notes:
Sprinkler heads >18" of clearance	<u>X</u>		
Sprinkler Rm & FDC labeled & clear	<u>X</u>		
Spare heads & wrench supplied	<u>X</u>		
Sprinkler system tagged insp. date	<u>X</u>		

House Keeping	Pass	Fail	Notes:
Furnishings & decorations flame rest	<u>X</u>		
Art work displayed < 20% wall area	<u>X</u>		
Housekeeping organized for safety	<u>X</u>		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <u>PATMS</u>	Address: <u>196 ALLEN AVE</u>
Principal:	Emergency contact #: <u>874-8165</u>

Date inspected: <u>12-08-11</u>	Inspector: <u>D. LORD</u>
Time in:	Time out:

Fire Drills Conducted Yes No Date of last drill: 11-29-11

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exit signs & Emer lights properly lit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Fire Alarm System			
Panel clear, accessible, operational	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Fire Extinguishers			
Extinguishers full & tagged annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Extinguishers accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Heating System			
Boiler room clear of all combustibles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Boiler room properly rated/protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Electrical system			
Extension cord use vs. permanent	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical panels clear & accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical circuits clearly identified	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Sprinkler System			
Sprinkler heads >18" of clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler Rm & FDC labeled & clear	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Spare heads & wrench supplied	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler system tagged insp. date	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

House Keeping			
Furnishings & decorations flame rest	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Art work displayed < 20% wall area	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housekeeping organized for safety	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Additional Safety Concerns: