

Portland Fire Department Monthly School Inspection

Name: <u>PATMS</u>	Address: <u>196 ALLEN AVE</u>
Principal:	Emergency contact #: <u>874-8765 STEVE THOMAS</u>

Date inspected: <u>3-14-12</u>	Inspector: <u>LT D. LORD L4</u>
Time in: <u>1300</u>	Time out: <u>1352</u>

Fire Drills Conducted Yes No Date of last drill: 2-12-12

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<u>A</u>		
Exit signs & Emer lights properly lit	<u>A</u>		<u>REAR EXIT MAIN OFFICE</u>

Fire Alarm System
Panel clear, accessible, operational

<u>A</u>	
----------	--

Fire Extinguishers
Extinguishers full & tagged annually
Extinguishers accessible

<u>A</u>	
<u>K</u>	

Heating System
Boiler room clear of all combustibles
Boiler room properly rated/protected

<u>A</u>	
<u>A</u>	

Electrical system
Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

<u>A</u>	
<u>K</u>	
<u>A</u>	


Sprinkler System
Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

<u>A</u>	
<u>K</u>	
<u>A</u>	
<u>K</u>	

House Keeping
Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

<u>A</u>	
<u>A</u>	
<u>K</u>	

Additional Safety Concerns: MAINTENANCE NOTIFIED OF PROBLEM W/ EMER. LIGHTS IN OFFICE.



Portland Fire Department Monthly School Inspection

Name: <u>PATH</u>	Address: <u>196 ALLEN AVE</u>
Principal:	Emergency contact #: <u>874-8165</u> <u>STEVE THOMAS</u>
Date inspected: <u>7-30-12</u>	Inspector: <u>LT D. LORD</u>
Time in:	Time out:

Fire Drills Conducted Yes No Date of last drill: _____

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<u>X</u>		
Exit signs & Emer lights properly lit	<u>X</u>		

Fire Alarm System	Pass	Fail	Notes:
Panel clear, accessible, operational	<u>X</u>		

Fire Extinguishers	Pass	Fail	Notes:
Extinguishers full & tagged annually	<u>X</u>		
Extinguishers accessible	<u>X</u>		


Heating System	Pass	Fail	Notes:
Boiler room clear of all combustibles	<u>X</u>		
Boiler room properly rated/protected	<u>X</u>		

Electrical system	Pass	Fail	Notes:
Extension cord use vs. permanent	<u>X</u>		
Electrical panels clear & accessible	<u>X</u>		
Electrical circuits clearly identified	<u>X</u>		

Sprinkler System	Pass	Fail	Notes:
Sprinkler heads >18" of clearance	<u>X</u>		
Sprinkler Rm & FDC labeled & clear	<u>X</u>		
Spare heads & wrench supplied	<u>X</u>		
Sprinkler system tagged insp. date	<u>X</u>		

House Keeping	Pass	Fail	Notes:
Furnishings & decorations flame rest	<u>X</u>		
Art work displayed < 20% wall area	<u>X</u>		
Housekeeping organized for safety	<u>X</u>		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <i>PATMS</i>	Address: <i>196 ALLEN AVE</i>
Principal:	Emergency contact #: <i>STEVE THOMES 874-8165</i>

Date inspected: <i>11-27-12</i>	Inspector: <i>LT D. LORA</i>
Time in: <i>1340</i>	Time out: <i>1415</i>

Fire Drills Conducted Yes No Date of last drill: _____

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<i>X</i>		
Exit signs & Emer lights properly lit	<i>X</i>		

Fire Alarm System			
Panel clear, accessible, operational	<i>X</i>		

Fire Extinguishers			
Extinguishers full & tagged annually	<i>X</i>		
Extinguishers accessible	<i>X</i>		

Heating System			
Boiler room clear of all combustibles		<i>X</i>	<i>BOXES OF FILTERS</i>
Boiler room properly rated/protected	<i>X</i>		

Electrical system			
Extension cord use vs. permanent	<i>X</i>		
Electrical panels clear & accessible	<i>X</i>		
Electrical circuits clearly identified	<i>X</i>		

Sprinkler System			
Sprinkler heads >18" of clearance	<i>X</i>		
Sprinkler Rm & FDC labeled & clear	<i>X</i>		
Spare heads & wrench supplied	<i>X</i>		
Sprinkler system tagged insp. date	<i>X</i>		

House Keeping			
Furnishings & decorations flame rest	<i>X</i>		
Art work displayed < 20% wall area	<i>X</i>		
Housekeeping organized for safety	<i>X</i>		

Additional Safety Concerns: