

•
•
•
•
•
•
•

389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal


To: Elliot Chamberlain **From:** Mike Nugent

Fax: 282-8568 **Date:** November 26, 2002

Phone: 282-7377 **Pages:** 1

Re: Building "N" Delaware Ct.

Urgent For Review Please Comment Please Reply Please Recycle



I have completed the review and have the following questions/comments?

- 1)The thickness of the footings appears to scale at less than 8"(detail 1/A2)
- 2)Crawl space ventilation is not shown.
- 3)What is the spacing of the anchor bolts?
- 4)What type of door is being used from the garage living space.
- 5)Safety Glazing for the windows in the interior stairways may be required (need more detail)
- 6)Attic Access is not shown.
- 7)Treads and risers on exterior stairs not shown
- 8) If there are two 7 3/4 inch risers going to the main entry, guards are required.

• • • • •