389 Congress St.Rm 315
Portland, ME 04101
Phone: (207)874-8700
Fax: (207)874-8716

facsimile transmittal

To: Elliot Chamberlain **From:** Mike Nugent

Fax: 282-6568 **Date:** December 17, 2002

Phone: 282-7377 **Pages:** 1

Re: Building "N" Delaware Ct.

☐ **Urgent** ☐ **For Review** ☐ **Please Comment** ☑ **Please Reply** ☐ **Please Recycle**

My apologies for just getting back to you now, it's been very busy. I had a couple of questions left over that were not addressed on your response:

1) The size and location of the of the crawl space vents.
2) the Fire door from the garage must be a 45 min door , because there's living space above.
3) Attic access is required based on the height on the attic space.
4) your're answer to #8 was N/A?? I don't get it!
5) Please provide a schedule of the fasteners (nails) used in the structural member and sheating and roofing.

Thanks