
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager Birchlane Llc		Inspector Jon Rioux	Inspection Date 4/6/2007
Locatation 12 WHITE BIRCH LN	CBL 343 D016001	Status Re-Inspect 10 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1)	Exterior				
Violation:					
Notes: 6.34j of the Portland Code states that all services located on the exterior shall not be located where subject to physical damage. (Originally cited on 2/26/07)					

Comments: 04-06-07 Inspection found previous dug underground wire trench only partially covered by soil, still creating a 1ft + trip hazard throughout the entire length. JGR.