
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager BIRCHLANE LLC		Inspector Suzanne Hunt	Inspection Date 2/26/2007
Location 12 WHITE BIRCH LN	CBL 343 D016001	Status	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1)	Exterior				
Violation:					
Notes: section 6.34j of Portland Code states that all services located on the exterior shall not be located where subject to physical damage. The trench containing electric conduit must be filled.					

Comments: