Fire Department

Chief Frederick J. LaMontagne, Jr.

Marion Puglisi 295 Allen Avenue Portland, ME 04103

April 20, 2010

Greetings,

The Fire Department accepts you request for a plan of action. The boiler protection will be installed by June 1, 2010. The 60-minute listed fire door assemblies will be installed by January 1, 2010. I have attached an explanation of both requirements: where and how.

Please feel free to contact Captain Gautreau or myself with any questions you may have.

Stay Safe,

Benjamin A. Wallace Jr., FPO (207)756-8096 wallaceb@portlandmaine.gov