

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK CITY OF PORTLAND

BUILDING INSPECTION

PERMIT

Please Read Application And Notes, If Any, Attached

PERMIT ISSUED

Permit Number: 051426
OCT 21 2005

CITY OF PORTLAND

This is to certify that NORTH DEERING CONGREGATIONAL CHURCH/Simplex / Gri

has permission to Install a Pyro-Chem Kitchen Hood Fire Suppression System

AT 1354 WASHINGTON AVE

L 344 C006001

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification inspection must given and written permission procured before this building or part thereof loaded or occupied. **HOLD FOR NOTIFICATION REQUIRED.**

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. Capt. Greg Cuss 10-11-05 (FD)

Health Dept. _____

Appeal Board _____

Other _____

Department Name _____

[Signature] 10/20/05

Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD



Commercial Building Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: 1364 Washington Avenue		
Total Square Footage of Proposed Structure	Square Footage of Lot	
Tax Assessor's Chart, Block & Lot Chart# Block# Lot#	Owner: No. Deering Congregational Church	Telephone: 797-2487
Lessee/Buyer's Name (If Applicable)	Applicant name, address & telephone: Simplex Grinnell 20 Thomas Drive Westbrook, ME 04092 842-6440	Cost Of Work: \$ 1,875 Fee: \$ 39.00
Current Specific use: _____		
Proposed Specific use: _____		
Project description: Installation of a Pyro-Chem wet chemical Kitchen hood Fire Suppression system per NFPA 17A + 96 and UL300 to protect a 6' hood, exhaust duct, range + griddle in the basement kitchen. Connection to fire alarm panel by others.		
Contractor's name, address & telephone: Simplex Grinnell		
Who should we contact when the permit is ready: Tim Hinman		
Mailing address: 20 Thomas Drive Westbrook, ME 04092		Phone: 842-6440 ext 220

Please submit all of the information outlined in the Residential Application Checklist. Failure to do so will result in the automatic denial of your permit.

At the discretion of the Planning and Development Department, additional information may be required prior to permit approval. For further information stop by the Building Inspections office, room 315 City Hall or call 874-8703.

I hereby certify that I am the Owner of record of the named property, or that the owner of record authorizes the proposed work and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

 SEP 23 2005 RECEIVED	Signature: Tim Hinman Date: _____ Permit Fee: \$30.00 for the first \$1000.00 Construction Cost, \$9.00 per additional \$1000.00 cost This is not a Permit; you may not commence any work until the Permit is issued.
---	--

✓ # 1464