



PLUMBING FIXTURE SCHEDULE

THE FOLLOWING PLUMBING PROGRAM FIXTURES, ASSOCIATED ACCESSORIES REQUIRED FOR A COMPLETE INSTALLATION AND OTHER PLUMBING ITEMS BELOW SHALL BE PURCHASED THROUGH THE TRANE NATIONAL ACCOUNT PLUMBING PROGRAM. CONTACT THEM AT 800-453-6954 TO OBTAIN A QUOTATION, ORDER AND TO COORDINATE DELIVERY.

ERS-1 EMPLOYEE ROOM SINK: (ADA COMPLIANT) ELKAY NO. LRAD-1522-55-3 LUSTERTONE SINGLE BOWL SINK W/LK35 STRAINER AND STOP AND CHICAGO FAUCET NO. 786-E-3 DECK MOUNT FAUCET WITH GOOSE NECK SPOUT AND WATER BLADE HANDLES.	WH-1G GAS FIRED WATER HEATER: 40 GALLONS, 18" DIA X 60" HIGH, 40,000 BTUH IMPUT, 41 GPH RECOVERY @ 90 DEG F. RISE, 3" FLUE UP THROUGH ROOF, 6 YEAR WARRANTY FOR PARTS AND TANK PER BRADFORD WHITE MODEL M-1-4076BN, STATE MODEL G5640YBRT OR A.O. SMITH MODEL GCV-40																									
EW-1 ELECTRIC WATER COOLER: (SPLIT LEVEL) ELKAY NO. EZSL18C, HANDICAP ACCESSIBLE, SELF CONTAINED, WALL HUNG, TWO LEVEL ELECTRIC REFRIGERATED WATER COOLERS. ACCEPTABLE ALTERNATE MANUFACTURER: OASIS-PBAMSL; HALSEY TAYLOR-HACBFL-Q; HAWS-HWACBL; SUNROC-NWCA-8F-BL.	WH-1E ELECTRIC WATER HEATER: 40 GALLONS, 18" DIA X 60" HIGH, 40 GPH RECOVERY @ 90 DEG F. RISE, TWO 4.5 KW ELEMENTS @ 208 VOLT 3 PHASE, WIRED FOR SIMULTANEOUS OPERATION WITH 6 YEAR WARRANTY FOR PARTS AND TANK PER BRADFORD WHITE MODEL M-1-4076BN, STATE MODEL E56-46-D8RT OR A.O. SMITH MODEL ECT-40.																									
LAV-1 LAVATORY: AMERICAN STANDARD NO. 0355.012 "LUCERNE" 20"x18" VITREOUS CHINA, WALL HUNG LAVATORY, WITH CHICAGO FAUCET, #802-665, 4" CENTERS AND 5 GPM AERATOR WITH 1/4" CHROME PLATED, BRASS (17 GAUGE) P-TRAP, WALL HUNGER, ETC. ACCEPTABLE ALTERNATE MANUFACTURERS: CRANE-1-412-V HARWICH; ELJER-SIGNATURE 051-2108 KOHLER-K-2005 KINGSTON; FAUCETS FOR ALL ABOVE LAVS.	DOMESTIC WATER PIPING HB-1 FREEZELESS WALL HYDRANT WOODFORD MODEL B65 CONCEALED BOX TYPE NON-FREEZE, FLUSH WALL HYDRANT. ALL BRASS OR BRONZE CONSTRUCT. WITH BRASS ROUGH BRONZE OR NICKLE BRONZE EXTERIOR FINISH INCLUDING BOX AND HINGE DOOR. FURNISH WITH COPPER TUBE CASING, INTEGRAL AUTOMATIC DRAINING, ANTI SIPHON VACUUM BREAKER, LOOSE KEY-HANDLE, 3/4" COLD WATER INLET AND 3/4" GARDEN HOSE OUTLET. VERIFY WALL THICKNESS BEFORE ORDERING. ACCEPTABLE ALTERNATES OF EQUAL PRODUCT ARE JOSAM, SMITH, WADE, ZURN.																									
PH-1 POST HYDRANT: ZURN NO. Z-1385-VB (3/4" HOSE CONNECTION) EXPOSED HEAD, NON FREEZE POST HYDRANT, KEY OPERATED, VACUUM BREAKER, 24" ABOVE ROOF LINE. ACCEPTABLE ALTERNATE MANUFACTURER: WADE 8610.	HB-2 HOSE BIB (2): HOSE BIBB (HB-1) WALL FAUCET W/ 3/4" MALE HOSE THREADED VACUUM BREAKER, WITH POLISHED CHROME FINISH; LOOSE KEY. WOODFORD MANUF. CO. MDL. NO. 24P-3/4. ROUGH-IN: 3/4" COLD WATER ALTERNATE MANUFACTURERS: JOSAM, J.R. SMITH, ZURN.																									
SK-1 PHARMACY SINK: THIS SHALL BE A SPECIAL RX CABINET SINK COMPLETE WITH FAUCET, ETC. FURNISHED BY WALGREENS, WITH STORE FIXTURES AND INSTALLED BY CONTRACTOR. (SEE DETAIL 1/P2.1).	FLOOR DRAINS / FUNNELS FD-1 - WITHOUT FUNNEL, CAST IRON BODY, 6" DIA. STRAINER OF NICKEL-BRONZE, 3" SIZE UNLESS ORDERED DIFFERENT PER: JOSAM 30000 SERIES SMITH 2010 SERIES WADE 1100 SERIES ZURN Z-415 SERIES FD-1P - WITHOUT FUNNEL, PVC BODY WITH 6" DIA STRAINER, 3" SIZE UNLESS ORDERED DIFFERENT PER: SIOUX CHIEF 842-36PNR FD-2 - WITH 4" NICKEL-BRONZE FUNNEL, CAST IRON BODY 6" DIA STRAINER PF NICKEL-BRONZE, 3" UNLESS ORDERED JOSAM 30000 SERIES SMITH 2010 SERIES WADE 1100 SERIES ZURN Z-415 SERIES FD-2P - WITH 4" NICKEL-BRONZE FUNNEL, PVC BODY DING AND 6" DIA STRAINER, 3" SIZE UNLESS ORDERED DIFFERENT PER: SIOUX CHIEF 842-36PNR & 863-FN																									
MB-1 MOP BASIN: FLORESTONE NO. MSR-2424, 24x24. FURNISH AND INSTALL MOLDED MOP SERVICE RECEPTOR WITH INTEGRAL DRAIN SUCH AS MANUFACTURED BY FLORESTONE PRODUCT CO. MOLDING SHALL BE DONE UNDER HEAT AND PRESSURE USING MATCHED METAL DIES. THE UNIT TO BE ONE PIECE WITH NO SEAMS. SHOULDERS SHALL BE NOT LESS THAN 1" WIDE, AND 9 1/2" INSIDE. UNIT SHALL HAVE RIBBED UNDERBODY AND INTEGRAL DRAIN PROVIDED FOR NON-CAULKING CONNECTION (LEAD CAULKED OPTIONAL) TO A 3" PIPE. DRAIN SHALL BE 18 GAUGE STAINLESS, FLAT TYPE, #430. MODEL SHALL CONFORM TO ANSI-Z-124.2 AND Z-124-6. AMERICAN STANDARD MODEL NO. 8344.112 (ADA) AND VACUUM BREAKER AT 3'-0" A.F.F. OR PER CODE REQUIREMENT. ACCEPTABLE ALTERNATE MANUFACTURER: E.L. MUSTEE -63 M; SWAN-MS 2424-3; ADVANCE TABCO-9-OP-20; ZURN-Z-1996 24x24; FIAT - MSB 2424.	CLEANOUTS FCO-1 - FLOOR TYPE WITH CAST IRON BODY, NICKEL-BRONZE RING AND SECURED COVER PER: JOSAM 55000 SERIES SMITH 4020 SERIES WADE 6000 SERIES ZURN ZN-1400 SERIES FCO-1P - FLOOR TYPE WITH PVC BODY, NICKEL-BRONZE RING AND SECURED COVER, PER: SIOUX CHIEF 842-4PNR. WCO-1 - WALL TYPE WITH 6" ROUND SS COVER PLATE, SCREW CAST IRON BODY, ABS THREADED PLUG PER: JOSAM 58600 SERIES SMITH 4710 SERIES WADE 8480 SERIES ZURN ZN-1400 SERIES WCO-1P - WALL TYPE, PVC BODY, WITH BRASS CLEANOUT PLUG, ROUND SS COVER PLATE AND OTHER FEATURES SIM TO WCO-1 PER SIOUX CHIEF 873-460. WCO-2 - WALL TYPE WITH SMOOTH FACE COVER PLATE, SQUARE FRAME, CAST IRON BODY, 8"x8" NICKEL-BRONZE RING PER: JOSAM 58640 SERIES SMITH 4730 SERIES WADE 8480S SERIES ZURN ZN-1400 SERIES GCO-1 GRADE CLEAN OUT, YARD TYPE WITH CAST IRON BODY, RING AND COVER PER: JOSAM 55000 SERIES SMITH 4100 SERIES WADE 6000 SERIES ZURN ZN-1400 SERIES																									
UR-1 URINAL: (ADA COMPLIANT) AMERICAN STANDARD NO. 6501.010 "WASHBROOK" VITREOUS CHINA, WALL HUNG URINAL, 1.0 GPF, COMPLETE WITH SLOAN "ROYAL" 186-1 FLUSH VALVE WITH VACUUM BREAKER AND SCREW DRIVER STOP, WALL HANGER, ETC. ACCEPTABLE ALTERNATE MANUFACTURERS: KOHLER-K-4960-ET BARDON; CRANE-7160 EMBASSY; ELJER-161-1090 SAVON.	STORM DRAINAGE PIPING RD-1 - ROOF DRAINS - COATED CAST IRON BODY (PVC IS NOT PERMITTED) WITH ADJUSTABLE EXTENSION, LOW SILHOUETTE POLYPROPYLENE VANDAL PROOF SECURED DOME, CAULKED OUTLET AND A METAL UNDER DECK CLAMP. PER: JOSAM 21500 SERIES SMITH 1015 SERIES WADE 3000 SERIES ZURN Z-100 SERIES																									
US-1 UTILITY SINK: FLORESTONE MODEL "FM", 23" X 22" FIBERGLASS REINFORCED POLYESTER RESINS, FLOOR UTILITY SINK WITH RUST FREE LEGS, LEVELERS, BACK "SHELF" (APPROX. 4" WIDE X 23" LONG SHALL BE "PLAIN" (NO SOAP DISH ETC.)) FOR MOUNTING FAUCETS & EYE WASH) FAUCETS SHALL BE ON RIGHT SIDE WITH THE EYE WASH ON THE LEFT SIDE. CHICAGO FAUCET ASSEMBLY NO. 895 WITH 3 1/2" SPOUT.	REVISIONS <table border="1"> <thead> <tr> <th>NO.</th> <th>DATE</th> <th>BY</th> <th>DESCRIPTION</th> <th>CONST</th> </tr> </thead> <tbody> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> <tr> <td> </td> <td> </td> <td> </td> <td> </td> <td> </td> </tr> </tbody> </table>	NO.	DATE	BY	DESCRIPTION	CONST																				
NO.	DATE	BY	DESCRIPTION	CONST																						
P-1 PUMP: PUMP FOR H.W. RECIRCULATION SYSTEM - BELL & GOSSET MODEL NFB-85/LW, 1/40 H.P., .38FLA., 115V, 1 PH RATED @ 4 GOM, @ 4' OF HEAD; BRONZE IN-LINE. TACO AS ALT. CONTROL OF PUMP SHALL BE BY CONNECTING IT TO ELECTRICAL CIRCUIT DESIGNATED "GENERAL SALES MAINTENANCE LIGHTS"	CERTIFICATION AND SEAL I HEREBY CERTIFY THAT THIS PLAN AND SPECIFICATION WAS PREPARED BY ME OR UNDER MY DIRECT SUPERVISION AND THAT I AM A DULY REGISTERED ARCHITECT OR ENGINEER UNDER THE LAWS OF THE STATE OF MAINE AS SIGNIFIED BY MY HAND AND SEAL.																									
EW-1 EYE WASH: EYE WASH (FAUCET MOUNT), BRADLEY MODEL S19-270HD. EYE WASH SHALL BE SUPPLIED THRU A MIXING VALVE THAT WILL FAIL TO IOEN IN COLD WATER BYPASS PER ANSI Z358.1. POWER MODEL ES150RB, BRADLEY OR LAWLOR EQUAL. SET FLOW PER EYE WASH RECOMMENDATION (APPROX. 1 GPM) AT 90 DEG. F	FISCAL 2007 CRITERIA - STORE #12326 WALGREENS (NWC) WASHINGTON & ALLEN AVES. PORTLAND, MAINE																									
WC-1 WATER CLOSET: (ADA COMPLIANT) AMERICAN STANDARD NO. 3043.102 TOP SPUD, MANDERA 17"H ELONGATED; 1.6 GPF SLOAN ROYAL # 111 FLUSH VALVE; SIPHON JET; FLOOR MOUNTED; VITREOUS CHINA WATER CLOSET; CHURCH # 295C OR EQ. BY BEMIS. SOLID PLASTIC, OPEN FRONT SEAT LESS COVER WITH CHECK HINGES & CHINA BOLT CAPS. INSTALL 1" WATER SUPPLY PIPE @ 28 3/4" A.F.F. ACCEPTABLE ALTERNATE MANUFACTURERS: CRANE -3H701 HYMONT ELJER-111-2145 SIGNATURE 17" KOHLER-K-4302-HIGHCREST.	PLUMBING SCHEDULES, NOTES AND DETAILS DRAWING TITLE																									
WC-2 WATER CLOSET: AMERICAN STANDARD NO. 2234.015 TOP SPUD; MADERA ELONGATED, 1.6 GPF, SLOAN # 111 FLUSH VALVE; SIPHON JET; FLOOR MOUNTED; VITREOUS CHINA WATER CLOSET; CHURCH NO.295C OR EQ BY BEMIS. SOLID PLASTIC OPEN FRONT SEAT LESS COVER WITH CHECK HINGE AND CHINA BOLT CAPS. INSTALL WATER SUPPLY PIPE @ 25 5/8" A.F.F. ACCEPTABLE ALTERNATE MANUFACTURERS: CRANE-3325 WHIRLTON ELJER-111-2125 SIGNATURE. KOHLER-K-4350-WELL COMME.	CADD PLOT: _____ SCALE: AS NOTED DRAWING NO.: _____ VOID PLOT: _____ DRAWN BY: TD DATE: 3-26-09 RELEASED TO CONSTRUCTION: _____ REVIEWED BY: SAM																									
NOTE: ALL PLUMBING FIXTURES SHALL BE WHITE UNLESS OTHERWISE NOTED.	P2.1																									

DRAWINGS/SPECIFICATIONS BY:
 WALGREENS
 LANDLORD'S CONSULTANT

ALL CONSTRUCTION WORK, UNLESS NOTED OTHERWISE, BY:
 WALGREENS CONTRACTOR
 LANDLORD'S CONTRACTOR (TURNKEY CONSTRUCTION)

STORE	BUILDING
NEW <input type="checkbox"/>	NEW <input checked="" type="checkbox"/>
REMODELING <input type="checkbox"/>	EXISTING <input type="checkbox"/>
RELOCATION <input type="checkbox"/>	NEW SHELL ONLY <input type="checkbox"/>
OTHERS <input type="checkbox"/>	