CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/21/16

1 hour fire protection to continue up wall to underside of roof sheathing parallel to dwelling

approxiamate location for 36"x36" hatch to storage attic space above

per conversation with contractor, door to be removed. no access to attic space above breezeway

Upper Floor Plan
1/4" = 1'-0"

WAYNE PARADIS INC.
Custom Design Service
Tel: 892-3424
Cell: 229-7641
wparadis13@twc.com
http://wayneparadis.net/index.html

Garage Addition
Plan For: Dana Cunningham
4/5
Drawn by: Wayne Paradis
Nov. 28, 2015