Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/21/16

Upper story may not have kitchen until ZBA approval for an additional dwelling unit has been secured and until a change of use permit has been approved.

Deck framed with 2x10 @ 16" O.C. on joist hangers

Upper Floor Plan