DISPLAY	THIS	CARD	ON	PRINCIPA	L FRON	TAGE	OF WORK	

CITY OF PORTLAND UILDING PERM



This is to certify that

Located at

DIDONATO FRANK & SANTO DIDONATO

82 Skylark Rd

CBL: 347 A019001

PERMIT ID: 2017-01745 **ISSUE DATE:** 12/07/2017

has permission to Install boiler.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and	written permission procured	A final inspection must be completed before this building or
before this building or part the	reof is lathed or otherwise	part thereof is occupied. If a certificate of occupancy is
closed-in. 48 hour notice is re-	quired.	required, it must be procured prior to occupancy.

/s/ Greg Gilbert

/s/ Greg Gilbert

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning single-family

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 or email: buildinginspections@portlandmaine.gov

Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

Cit	ty of Portland, Maine - Building or Use Permit	Permit No:	Date Applied For:	CBL:				
	9 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 8	2017-01745	11/03/2017	347 A019001				
Proj	pposed Use:	Proposed	Proposed Project Description:					
Same. Single Family.			Install boiler.					
	• • •	eviewer:	Christina Stacey	Approval Da				
					Ok to Issue:			
	Conditions:							
	Dept: Building Inspecti Status: Approved w/Conditions R Note: Image: Conditional Status: Condite: Conditional	leviewer:	Greg Gilbert	Approval Da	ate: 12/07/2017 Ok to Issue: ✓			
	Conditions:				OK to Issue:			
	M1804.2.5 Direct vent terminations. Vent terminals for direct-ve manufacturer's installation instructions.	ent applian	ces shall be installe	ed in accordance with	h the			
2)	Maintain proper setback(s) from property lines/buildings and pro	oper cleara	nces from vertical	openings when direc	t venting			
3)	The installation must comply with UL, the Manufacturers' Listin	ıg, MUBE(C (IRC, 2009), and	l State of Maine Gas	Regulations.			
4)	Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.							
5)	5) Review and approval by the Authority having Jurisdiction shall not relieve the applicant of the responsibility of compliance with this Code							
6)) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.							
D	Dept: Fire Status: Approved w/Conditions R	eviewer:	Greg Gilbert	Approval Da	ate: 12/07/2017			
N	lote:		-		Ok to Issue: 🗹			
С	Conditions:							
1)	City of Portland Code Chapter 10 section 10-3 (i) all new single- ionization (photoelectric) type. Smoke Alarms shall be installed installed in the following locations 1. Inside all sleeping rooms.							
	 Outside each separate sleeping area, in the immediate vicin On each level of the dwelling unit, including basements bu 			snaces				
	Fire extinguishers are required per NFPA 1 (2009 Edition) Table accordance with NFPA 1, 13.6.8.				l be in			
2)	 City of Portland Code Chapter 10 section 10-3 (L) all residential occupancies, and all new multiple occupancies containing attached parking structures or fuel burning appliances shall be protected in accordance with NFPA 720, Standard for the Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition. Detectors shall be provided in the following areas. Outside each separate sleeping area, in the immediate vicinity of the sleeping areas On each level of the dwelling unit, including basements but excluding attics and crawl spaces. 							
3)	All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101 Life Safety C All construction shall comply with 2009 NFPA 1, Fire Code.	Code, Chaj	pter # 43					
	This review and approval by the AHJ shall not relieve the applica (section 1.14.4).	ant of the 1	responsibility of co	mpliance with this C	ode. NFPA 1			