

From: Arthur Rowe
To: Frank Brancely
Date: 5/14/2007 4:01:43 PM
Subject: Re: 4 Oramel Ave CBL 349 D006 Sandra Sargent, owner

Frank. You have provided the necessary information, as always. Thank you very much!!

>>> Frank Brancely 5/14/2007 2:37:35 PM >>>
Good Afternoon Arthur,

I have attached a cropped section from sheet #I-14, of the I & I maps. The closest sewer to Oramel is on Skylark Road, near the intersection of Skylark Road and Pennell Avenue. This is a minimum of 634+/-feet to the intersection of Coolidge and Oramel, to a maximum of 1,143+/- feet to C.B.L.#: 349-D-006, half way down Davenport Avenue. Both of these scaled differences exceed the 200 feet specified in City Ordinance: Section 24-36.

Frank

Frank Brancely,
Senior Engineering Technician,
Department of Public Works,
55 Portland Street,
Portland, Maine 04101-2991
(207) 874-8832 (phone),
(207) 874-8852 (fax),
<fjb@portlandmaine.gov>

>>> Arthur Rowe 5/10/2007 2:38:13 PM >>>
She has a defective Leach field and has to replace it or tie in to the city sewer if it is close enough. Can you tell me how close the city sewer is ??

Oramel is way down in the woods in the area of Skylark and Collidge St.

Thanks!!

CC: David Peterson; Jeanie Bourke; Jonathan Rioux